

# Columbus Airport

## Work Orders: Custom Report

ID	Category	Location	Status	Date/Time Submitted	Submitted By	Description	Date/Time Completed	Completed By	Date/Time Closed	Closed By
174	Other	Hangar	In Progress	2020-01-02 14:31	Michele Renfroe	9A water leaking into hangar. possible under doors, up through concrete and back wall				
175	Other	Hangar	In Progress	2020-01-02 14:31	Michele Renfroe	9B water in hangar. possible coming up through concrete				
238	Lighting	Crash Station	In Progress	2020-01-15 14:45	Raymond Keeler	Recessed light assembly is missing in the bathroom between 113 & 117 at Crash Station				
248	Door/Gate	Hangar	In Progress	2020-01-21 08:59	Michele Renfroe	14B left side door on top has door stop missing so the doors move freely. Bolt and plates need to be replaced so the left door will lock properly.				
266	Navigational Aids - RENLs/VGSI systems	Airside	In Progress	2020-01-23 13:05	Daniel Thomas Sr.	REMOVE AIRPORT OWNED, OLD NOT WORKING VGSI SYSTEMS OUT OF DELTA 1 SAFETY AND FOXTROT 4 SAFETY AREA.				
278	Wildlife	Hangar	In Progress	2020-01-27 08:14	Michele Renfroe	7A has noticed where pigeons have started getting into hangar recently. They have never had an issue with this in the past. Jose: Assess and mitigate entry point.				
290	Door/Gate	Hangar	In Progress	2020-02-03 16:41	Garry Parker	RH Door Frame is bent at the bottom, The gap is allowing air and water to enter the hangar when the doors are closed.				
291	Lighting	Hangar	In Progress	2020-02-04 09:26	Garry Parker	Hangar 18-A exterior light is not working: Repair or Replace/upgrade fixture.				
293	Navigational Aids - RENLs/VGSI systems	Airside	In Progress	2020-02-07 16:03	Eric Rivers	Pappi system RW 13 not working. Notified tower of Pappi system being out while on my day time inspection				

2 9 5	Door/Gate	Terminal Building	In Progress	2020-02-10 10:24	Kelvin Mullins	Security Checkpoint Doors needs (2) Two new stoppers on the floor so door want slide close while open.				
2 9 6	Other	Hangar	In Progress	2020-02-10 10:25	Michele Renfroe	15B latch needs to be removed and replaced with new shorter latch to make it connect to the eyelet for locking.				
2 9 7	Other	Hangar	In Progress	2020-02-10 10:29	Michele Renfroe	15B was cleaned but doors and floor needs to be pressure washed to remove pigeon matter on doors and floors.				
2 9 8	Other	Hangar	In Progress	2020-02-10 16:41	Michele Renfroe	16A- Open screw holes on the door, left side panel in several locations, back wall at top. Photos attached.				
2 9 9	Roof	Hangar	In Progress	2020-02-10 16:43	Michele Renfroe	16A - Roof leak on right side of hangar over car could not tell where it was coming from. Leak in middle of hangar at the roof near beam. Photo attached.				
3 0 0	Door/Gate	Terminal Building	In Progress	2020-02-10 16:44	Marion Anderson	The handle on far right door adjacent to the main entrance had been pulled off the fitting. The handle is on the desk in the Public Safety office. This incident happen on 02/06/2020.				
3 0 1	Lighting	Hangar	In Progress	2020-02-10 16:46	Michele Renfroe	2A - Back light in hangar is blown and fixture seems to be coming out of the ceiling. Customer stated the fixture is spinning and light bulb will not come out of the housing.				
3 0 4	Facilities	Hangar	In Progress	2020-02-10 16:51	Michele Renfroe	6C Back of hangar angle iron rusted out with holes present. Photos attached				
3 0 5	Door/Gate	Hangar	In Progress	2020-02-10 16:56	Michele Renfroe	6C - 2nd door gets stuck when opening hangar 1/2 way down				
3 0 6	Roof	Hangar	In Progress	2020-02-10 16:58	Michele Renfroe	6C Front right side of hangar has new roof leaks. Photos attached.				
3 0 7	Door/Gate	Hangar	In Progress	2020-02-10 16:59	Michele Renfroe	21B- Right door hanging up on other door @ top when open all the way. When trying to close it pulls both doors where it is hanging up on top making it hard to close the 1st door. Debbie would prefer to be present on Friday's when looking at the hangar.				

3 0 9	Plumbing	Parking Lot	Work Complete	2020-02-11 16:33	Garry Parker	Water line underground has burst near the Sauer Construction trailer and is spewing above ground. Shut off the water and assess if we can repair this in-house.	2020-02-21 00:00	Garry Parker		
3 1 1	Roof	Hangar	In Progress	2020-02-12 11:39	Michele Renfro	4B - Roof is leaking in several locations. Photos attached				
3 1 2	Facilities	Crash Station	In Progress	2020-02-13 09:55	Andre Parker	Crash Station water heater is not working. Fault Code: Blower Prover Open - The blower prover switch remains open after the blower has been energized.				