

## Work Orders: Custom Report

ID	Category	Location	Status	Date/Time Submitted	Submitted By	Description	Actual Cost	Labor Hours	Date/Time Completed	Completed By	Date/Time Closed	Closed By
61	Lighting	Hangar	Work Complete	2019-10-31 08:56	Garry Parker	Hangar 4-C : Light isn't working.	\$ 0.00	0.0	2019-11-20 00:00	Garry Parker		
62	Electrical	Hangar	Work Complete	2019-10-31 08:58	Garry Parker	Hangar 16-H Light is not working.	\$ 0.00	0.0	2019-11-20 00:00	Garry Parker		
63	Lighting	Hangar	Work Complete	2019-10-31 09:01	Garry Parker	Hangar 5-D: Light is not working.	\$ 0.00	0.0	2019-12-30 00:00	Garry Parker		
64	Door/Gate	Hangar	Work Complete	2019-10-31 09:04	Garry Parker	Hangar 4-C: Door is hard to open.	\$ 0.00	0.0	2020-02-03 00:00	Garry Parker		
65	Door/Gate	Hangar	Work Complete	2019-10-31 09:15	Garry Parker	Hangar 5-F New door seal needs to be adjusted as water is still entering the hangar when it rains.	\$ 0.00	0.0	2019-11-13 00:00	Garry Parker		
67	Lighting	Hangar	Work Complete	2019-11-05 09:23	Garry Parker	Hangar 21 : several exterior lights are out.	\$ 0.00	0.0	2019-11-14 00:00	Garry Parker		
68	Plumbing	Terminal Building	Work Complete	2019-11-05 12:56	Garry Parker	Downstairs Terminal: MALE RRtoilet in handicap stall needs to be re-mounted.	\$ 0.00	0.0	2019-11-13 00:00	Garry Parker		
69	Wildlife	Hangar	Work Complete	2019-11-06 08:19	Garry Parker	Hangar 11 PIGEONS. scheduled hangar entry for November 8th. Email notification sent to tenant John Walden on Friday, November 1st.	\$ 0.00	0.0	2019-11-14 00:00	Garry Parker		
70	HVAC	Terminal Building	Work Complete	2019-11-13 08:43	Garry Parker	No heat at the AVIS rental car counter. See Sabrina - Avis Manager.	\$ 0.00	0.0	2019-11-13 00:00	Garry Parker		
71	Plumbing	Terminal Building	Work Complete	2019-11-13 10:38	Garry Parker	The ceiling is leaking in front of the glass double doors near the TSA checkpoint. Sheetrock will need to be removed to access the piping.	\$ 0.00	0.0	2020-01-15 00:00	Garry Parker		
72	Lighting	Hangar	Work Complete	2019-11-20 09:07	Garry Parker	Hangar 4B no Light is working	\$ 0.00	0.0	2019-12-03 00:00	Garry Parker		
73	Roof	Hangar	Work Complete	2019-11-20 12:22	Garry Parker	Hangar 14D Roof is leaking	\$ 0.00	1.0	2020-03-06 00:00	Jose Aviles		
74	Roof	Hangar	Work Complete	2019-11-20 12:23	Garry Parker	Hangar 14E roof is leaking.	\$ 0.00	1.0	2020-03-06 00:00	Jose Aviles		
75	Roof	Hangar	Work Complete	2019-11-20 12:25	Garry Parker	Hangar 2C roof is leaking	\$ 0.00	3.0	2020-03-11 00:00	Jose Aviles		
76	Wildlife	Hangar	Work Complete	2019-11-22 16:17	Garry Parker	Hangar 14-A Pigeons have returned. Ensure ends of doors are closed off to prevent pigeon entry. Inspect hangar for signs of roosting locations and apply bird gel.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles		
77	Facilities	Hangar	Work Complete	2019-11-22 16:22	Garry Parker	Hangar 7 (AJ Jain) back wall is rusted and water seeps in during rain. Clean and seal the bottom of the sheet metal wall at the outside rear of the hangar.	\$ 0.00	5.0	2020-05-26 00:00	Jose Aviles		
78	Door/Gate	Hangar	Work Complete	2019-11-22 16:25	Garry Parker	Hangar 1-B Doord sticks and sheet metal is loose near the tracks.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles		
79	Door/Gate	Hangar	Work Complete	2019-11-22 16:27	Garry Parker	Hangar 2-C door is sticking.	\$ 0.00	0.0	2020-07-15 00:00	Garry Parker		
80	Door/Gate	Hangar	In Progress	2019-11-22 16:31	Garry Parker	Hangar 11 bay 2 (John Walden) Thicker door stopper required. Weld in place. 1/4" flat bar should protrude an inch more than the current door stopper.	\$ 0.00	0.0				

81	Facilities	Hangar	Work Complete	2019-11-22 16:34	Garry Parker	Hangar 8-B back wall is extruding beyond the concrete pad because the angle iron frame is missing. Anchor new angle iron onto the concrete, attach the sheet metal.	\$ 0.00	2.0	2020-05-26 00:00	Jose Aviles		
82	Door/Gate	Hangar	Work Complete	2019-11-25 09:28	Garry Parker	Hangar 13 door (tower side) door stop weld is broken. needs to be re-enforced and re-welded.	\$ 0.00	0.0	2019-12-05 00:00	Garry Parker		
83	Door/Gate	Hangar	Work Complete	2019-11-25 09:37	Garry Parker	Hangar 11 Bay 5: Bottom door roller 3rd door on the left, interior roller. Roller is wobbly, unsturdy. needs to be adjusted, repaired, or replaced.	\$ 0.00	0.0	2019-12-03 00:00	Garry Parker		
84	Door/Gate	Hangar	Work Complete	2019-11-25 09:43	Garry Parker	Hangar 2-D (Facing gate 6) RH door sagging. Nut is missing from I-bolt on the top.	\$ 0.00	0.0	2019-12-03 00:00	Garry Parker		
85	Roof	Hangar	Work Complete	2019-11-25 13:13	Garry Parker	Hangar 4 C gutter is sagging. Repair/ Readjust to straighten gutter so that water flows to the downspout.	\$ 0.00	0.0	2019-11-25 00:00	Garry Parker		
90	Lighting	Terminal Building	Work Complete	2019-12-03 08:14	Garry Parker	Stairwell near the elevator, 2 lights out T12 bulbs. Admin Hallway near FAA: One fluorescent U-Bulb is out.	\$ 0.00	0.0	2019-12-03 00:00	Garry Parker		
91	Facilities	Hangar	Work Complete	2019-12-03 16:47	Garry Parker	Hangar 16-A Metal flashing is hanging off the corner of the hangar; straighten and/or re-attach.	\$ 0.00	0.0	2019-12-12 00:00	Garry Parker		
92	Lighting	Hangar	Work Complete	2019-12-03 16:53	Michele Renfroe	4D lights are out	\$ 0.00	0.0	2019-12-13 00:00	Garry Parker		
93	Door/Gate	Hangar	Work Complete	2019-12-03 16:59	Garry Parker	Hangar 17-A Sheet metal on side of the building is crumpled at the bottom; sheet metal on the door is bent and rubber seal is torn/missing. Straighten sheet metal and fabricate, install new rubber door seal.	\$ 0.00	0.0	2019-12-12 00:00	Garry Parker		
94	Lighting	Terminal Building	Work Complete	2019-12-04 09:45	Garry Parker	Multiple lights are out in the 2F FAA offices.	\$ 0.00	0.0	2019-12-09 00:00	Garry Parker		
96	Electrical	Terminal Building	Work Complete	2019-12-05 11:22	Garry Parker	Propellers Restaurant: Feedback Now gateway is not operational. Install new gateway that was provided by Feedback Now.	\$ 0.00	0.0	2019-12-05 00:00	Garry Parker		
97	Plumbing	Terminal Building	Work Complete	2019-12-06 13:25	Garry Parker	Womens restroom stall, center right flush valve inoperable. needs new flush valve replacement.	\$ 0.00	0.0	2019-12-06 00:00	Garry Parker		
98	Plumbing	Hangar	Work Complete	2019-12-06 13:27	Garry Parker	Portable restroom southwest ramp: toilet is clogged.	\$ 0.00	0.0	2019-12-06 00:00	Garry Parker		
99	Lighting	Terminal Building	Work Complete	2019-12-06 15:45	Amber Clark	Two lights are out by terminal and gate "Y"	\$ 0.00	0.0	2020-01-07 00:00	Garry Parker		
100	Lighting	Hangar	Work Complete	2019-12-06 15:48	Amber Clark	Hangar 7C: 3 out of 4 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0	2020-01-02 00:00	Garry Parker		
101	Lighting	Hangar	Work Complete	2019-12-06 16:33	Amber Clark	Hangar 8A: 3 out of 4 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0	2019-12-31 00:00	Garry Parker		
102	Lighting	Hangar	Work Complete	2019-12-06 16:34	Amber Clark	hangar 11: 3 out of 4 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	3.0	2020-05-27 00:00	Jose Aviles		
103	Lighting	Hangar	Work Complete	2019-12-06 16:35	Amber Clark	hangar 12: 1 out of 5 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	24.0	2020-06-08 00:00	Jose Aviles		
104	Lighting	Hangar	Work Complete	2019-12-06 16:35	Amber Clark	hangar 14C: exterior overhead lights missing (safety issue for aircraft and FBO)	\$ 0.00	0.0	2020-02-06 00:00	Garry Parker		
105	Lighting	Hangar	Work Complete	2019-12-06 16:36	Amber Clark	hangar 16C: exterior overhead lights are missing (safety issue for aircraft and FBO)	\$ 0.00	0.0	2020-02-03 00:00	Garry Parker		
106	Lighting	Hangar	Work Complete	2019-12-06 16:38	Amber Clark	hangar 16G: 2 out of 3 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0	2020-02-03 00:00	Garry Parker		
107	Lighting	Hangar	Work Complete	2019-12-06 16:39	Amber Clark	hangar 18B: 2 out of 3 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0	2020-01-03 00:00	Garry Parker		
108	Lighting	Hangar	Work Complete	2019-12-06 16:41	Amber Clark	hangar 18J: 2 out of 3 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0	2020-01-03 00:00	Garry Parker		

110	Lighting	Hangar	Work Complete	2019-12-06 16:42	Amber Clark	hangar 21F: 2 out of 3 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0	2019-12-12 00:00	Garry Parker		
111	Lighting	Hangar	Work Complete	2019-12-06 16:43	Amber Clark	Bathroom on Southside by hangar 21: motion detected overhead lights are out	\$ 0.00	0.0	2020-01-24 00:00	Garry Parker		
112	Lighting	Hangar	Work Complete	2019-12-06 16:44	Amber Clark	hangar 57: 2 out of 3 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0	2020-01-10 00:00	Garry Parker		
113	Lighting	Hangar	Work Complete	2019-12-06 16:46	Amber Clark	maintenance hangar: 2 out of 3 exterior overhead lights are out	\$ 0.00	0.0	2020-05-27 00:00	Jose Aviles		
114	Other	Flightways	Work Complete	2019-12-09 12:55	Michele Renfroe	removal of orange barrier fence at fuel farm	\$ 0.00	0.0	2020-01-08 00:00	Daniel Thomas Sr.		
115	Roof	Hangar	Work Complete	2019-12-09 13:05	Michele Renfroe	17A roof has hole that is leaking into hangar	\$ 0.00	2.0	2020-03-16 00:00	Jose Aviles		
116	Other	Hangar	Work Complete	2019-12-09 13:06	Michele Renfroe	17A leaking from back panel of hangar	\$ 0.00	2.0	2020-03-16 00:00	Jose Aviles		
117	Lighting	Hangar	Work Complete	2019-12-09 13:06	Michele Renfroe	Hangar 4D lights are not working. Has some florescent and regular lights.	\$ 0.00	0.0	2019-12-13 00:00	Garry Parker		
118	Other	Hangar	Work Complete	2019-12-09 13:08	Michele Renfroe	5D is leaking water into hangar on outside wall as well as under the door. Customer vacated hangar and needs to be fixed before a new tenant can move in.	\$ 0.00	4.0	2020-04-01 00:00	Jose Aviles		
119	Wildlife	Hangar	Work Complete	2019-12-09 13:09	Michele Renfroe	15C Pigeon issues at present time	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles		
120	Plumbing	Hangar	Work Complete	2019-12-09 13:11	Michele Renfroe	CAP building on hill, water will not cut off in the sink so it is flowing continuously, under sink valves not working properly. this is also causing septic tank issues.	\$ 0.00	0.0	2020-01-10 00:00	Garry Parker		
121	Other	Hangar	Work Complete	2019-12-09 13:12	Michele Renfroe	8D has leak by left interior pole. Tenant has vacated the hangar and it needs to be fixed before new tenant can move in.	\$ 0.00	2.0	2020-04-02 00:00	Jose Aviles		
122	Wildlife	Hangar	In Progress	2019-12-09 13:13	Michele Renfroe	16H pigeons in hangar	\$ 0.00	0.0				
123	Door/Gate	Hangar	Work Complete	2019-12-09 13:16	Michele Renfroe	H21 missing top portion of door seal.	\$ 0.00	9.0	2020-09-08 00:00	Jose Aviles		
124	Door/Gate	Hangar	Work Complete	2019-12-09 13:18	Michele Renfroe	16A outside panel on corner has missing screws. Screws need to be replaced to keep the panel from blowing off the side of hangar.	\$ 0.00	0.0	2020-01-22 00:00	Garry Parker		
125	Lighting	Hangar	In Progress	2019-12-10 08:36	Amber Clark	Metro Narcotics (Helicopter Hangar on the top of the hill): 2 out of 2 exterior overhead lights are out (safety issue for aircraft and FBO)	\$ 0.00	0.0				
126	HVAC	Hangar	In Progress	2019-12-10 08:38	Michele Renfroe	Office beside 15F needs to have AC/Heating unit replaced and pan put under to catch the drainage water from dripping into the hangar.	\$ 0.00	0.0				
127	Lighting	Terminal Building	Work Complete	2019-12-10 08:40	Garry Parker	Light bulbs over the back door of the stairwell near public safety are out and need to be replaced. NOTE: These are 3' T12 bulbs	\$ 0.00	0.0	2019-12-13 00:00	Garry Parker		
129	Lighting	Terminal Building	Work Complete	2019-12-10 15:19	Garry Parker	Downstairs Ladies (Public) Restroom in the secure Area near TSA light bulbs are out.	\$ 0.00	0.0	2019-12-11 00:00	Garry Parker		
130	Facilities	Terminal Building	Work Complete	2019-12-11 12:36	Garry Parker	Upstairs holding area: Ladies room first stall handle is leaking .	\$ 0.00	0.0	2020-01-15 00:00	Garry Parker		
131	Lighting	Terminal Building	Work Complete	2019-12-11 12:41	Garry Parker	HR Office needs 5- florescent light bulbs replaced with 'Daylight' bulbs	\$ 0.00	0.0	2019-12-13 00:00	Garry Parker		
132	Door/Gate	Hangar	Work Complete	2019-12-12 08:53	Garry Parker	Hangar 3-A Sheet metal hanging off the building	\$ 0.00	0.0	2019-12-12 00:00	Garry Parker		
133	Lighting	Hangar	Work Complete	2019-12-13 10:07	Garry Parker	Hangar 15-A Exterior Lights out	\$ 0.00	0.0	2020-02-03 00:00	Garry Parker		

134	Lighting	Hangar	Work Complete	2019-12-13 10:14	Garry Parker	Hangar 16-D Exterior Lights are not working	\$ 0.00	0.0	2020-01-24 00:00	Garry Parker		
159	Facilities	Terminal Building	Work Complete	2019-12-20 11:32	Garry Parker	Wasps are present in HR office; several have been terminated over the past week however the entry point hasn't been found. KNOX pest control has been contacted to eliminate the wasps.	\$ 0.00	0.0	2019-12-31 00:00	Garry Parker		
160	Door/Gate	Terminal Building	Work Complete	2019-12-23 08:12	Garry Parker	An outside sliding door near TSA / Delta ticket counter is off track. The door will not close automatically, Automated Door Company is our service provider for this door. Parts that came off the sliding door have been placed in the Airport Police Office located in the terminal	\$ 0.00	0.0	2019-12-30 00:00	Garry Parker		
172	Door/Gate	Hangar	Work Complete	2020-01-02 13:04	Garry Parker	Hangar 7A (office) door needs a new bottom seal. Office gets wet when it rains.	\$ 0.00	0.0	2020-01-07 00:00	Garry Parker		
173	Door/Gate	Hangar	Work Complete	2020-01-02 14:30	Michele Renfroe	Hangar 21J-water is leaking down off roof onto interior door frame causing rust to drip on aircraft both sides. Can we spray rustoleum paint on the red iron frame to make it so it will cover the rust. Customer has mentioned this several times in the commission meetings.	\$ 0.00	0.0	2020-02-03 00:00	Garry Parker		
174	Other	Hangar	In Progress	2020-01-02 14:31	Michele Renfroe	9A water leaking into hangar. possible under doors, up through concrete and back wall	\$ 0.00	0.0				
175	Other	Hangar	In Progress	2020-01-02 14:31	Michele Renfroe	9B water in hangar. possible coming up through concrete	\$ 0.00	0.0				
176	Facilities	Terminal Building	Work Complete	2020-01-02 14:41	Raymond Keeler	Down escalator is not working. Sub-contractor was out on Monday and got the down escalator to work on Monday, but it is out of order again today.	\$ 0.00	0.0	2020-01-10 00:00	Garry Parker		
177	HVAC	Crash Station	Work Complete	2020-01-02 14:43	Raymond Keeler	Heater in Bay 1 is not working	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.		
178	Roof	Terminal Building	Work Complete	2020-01-03 11:46	Garry Parker	The administration supply closet roof is leaking. Assess and repair roof leak, replace damaged ceiling tiles.	\$ 0.00	0.0	2020-01-10 00:00	Garry Parker		
179	Plumbing	Terminal Building	Work Complete	2020-01-03 11:48	Garry Parker	The administration kitchen sink is spraying. Adjust or replace the faucet.	\$ 0.00	0.0	2020-01-07 00:00	Garry Parker		
180	Lighting	Terminal Building	Work Complete	2020-01-03 11:50	Garry Parker	Terminal Parking Lot computer room near pay parking kiosk: Replace light bulbs.	\$ 0.00	0.0	2020-01-22 00:00	Garry Parker		
181	Facilities	Terminal Building	Work Complete	2020-01-03 11:51	Garry Parker	FAA Control Tower Cab: Replace ceiling fan with lighted ceiling fan.	\$ 0.00	0.0	2020-01-17 00:00	Garry Parker		
182	Facilities	Terminal Building	Work Complete	2020-01-03 14:38	Garry Parker	FAA Generator Room. Wall and floor need to be sealed and waterproofed after groundwater has stopped seeping through the floor. Electric control cabinet needs to be sealed and waterproofed at the bottom (one inch from the floor.)	\$ 0.00	0.0	2020-05-27 00:00	Jose Aviles		
192	Facilities	Crash Station	Work Complete	2020-01-06 10:10	Raymond Keeler	Water fountain is leaking	\$ 0.00	0.0	2020-02-03 00:00	Garry Parker		
193	Lighting	Hangar	Work Complete	2020-01-06 10:11	Raymond Keeler	Hanger 16-F exterior light is out, was working on 01/02/2019.	\$ 0.00	2.0	2020-03-16 00:00	Jose Aviles		
194	Lighting	Terminal Building	Work Complete	2020-01-06 10:36	Raymond Keeler	Light out above Delta Airlines baggage door, near Gate Y	\$ 0.00	1.0	2020-05-27 00:00	Jose Aviles		
195	Lighting	Terminal Building	Work Complete	2020-01-06 10:36	Raymond Keeler	2 lights out in corner of terminal building above and next to the bay door near staff parking	\$ 0.00	3.0	2020-05-27 00:00	Jose Aviles		
196	Lighting	Terminal Building	Work Complete	2020-01-06 10:37	Raymond Keeler	Light out above Maint. door at Terminal near Gate Y	\$ 0.00	1.0	2020-05-27 00:00	Jose Aviles		
197	Plumbing	Hangar	Work Complete	2020-01-06 14:54	Michele Renfroe	SW restroom toilet is having a drainage issue. The water takes a while to go down and seems to have a clog in the pipe.	\$ 0.00	4.0	2020-09-08 00:00	Jose Aviles		

213	Signs - Damaged/retroreflective	Airside	In Progress	2020-01-08 09:45	Richard Baran	168 - Airfield signs #1, 2, 9, 11, 13, 14, 20, 23, 25, 30, 40, 41, 42, 43, 44, 45, 48, 50, 53, 55, 59, 97, 98, 107, 108, 109, D3, D9, D10, F5, F17, F18, F99, D06, D16, D22, D61, F12, and F13 are fading	\$ 0.00	0.0			
215	Paved Areas - Cracks/spalling/heaves	Airside	In Progress	2020-01-08 09:48	Raymond Keeler	146 - Runway 13/31 has surface cracks	\$ 0.00	0.0			
216	Paved Areas - Cracks/spalling/heaves	Airside	In Progress	2020-01-08 09:48	Raymond Keeler	147 - All of Taxiway C has long seam cracks	\$ 0.00	0.0			
217	Paved Areas - Cracks/spalling/heaves	Airside	In Progress	2020-01-08 09:48	Raymond Keeler	148 - Taxiway F has surface cracks	\$ 0.00	0.0			
226	Safety Areas - Frangible bases	Airside	In Progress	2020-01-09 10:59	Eric Rivers	145 - Multiple ingrown transformer can lids bolts are missing or broken off in the RSA of RWY 24/6 and Taxiway - C areas. Replace missing and broken off can lid bolts. GP - 12-21-18 # 2270, 2271, 2269	\$ 0.00	0.0			
227	Paved Areas - Rubber deposits	Airside	In Progress	2020-01-10 13:06	Daniel Thomas Sr.	Runway 24/6 touch down zones are building up rubber deposits and starting to cover up runway markings in them areas.	\$ 0.00	0.0			
234	Lighting	Terminal Building	Work Complete	2020-01-13 14:44	Garry Parker	FAA Offices: Mens restroom light bulbs are not working. Replace T12 40w bulbs.	\$ 0.00	0.0	2020-01-13 00:00	Garry Parker	
235	Other	Ramp	Work Complete	2020-01-14 16:14	Garry Parker	Remove large section of old tarp on the passenger boarding bridge. Replace with new roof vinyl. Will need thin nylon rope to lace and secure the vinyl awning to the frame, using the provided grommets. Pull the awning tight to prevent pooling from rain.	\$ 0.00	0.0	2020-01-16 00:00	Garry Parker	
237	Hazard	Terminal Building	Work Complete	2020-01-15 12:12	Raymond Keeler	Recess lighting hanging by wire, recess lighting missing, and recess lighting out	\$ 0.00	0.0	2020-01-15 00:00	Garry Parker	
238	Lighting	Crash Station	Work Complete	2020-01-15 14:45	Raymond Keeler	Recessed light assembly is missing in the bathroom between 113 & 117 at Crash Station	\$ 0.00	0.0	2020-03-05 00:00	Garry Parker	
240	Safety Areas - Ruts/humps/erosion	Airside	In Progress	2020-01-16 17:20	Daniel Thomas Sr.	RSA of RWY 6, access road needs more millings that got washed away by rain causing ruts.	\$ 0.00	0.0			
241	Safety Areas - Ruts/humps/erosion	Airside	In Progress	2020-01-16 17:20	Daniel Thomas Sr.	RSA of RWY 6, back right corner needs more millings that got washed away by rain causing ruts. wait to do this until the RSA of runway 6 dries out. Its to wet right now and will cause more ruts.	\$ 0.00	0.0			
242	Safety Areas - Ruts/humps/erosion	Airside	In Progress	2020-01-16 17:20	Daniel Thomas Sr.	Charlie-5 RSA needs more millings that got washed away by rain causing ruts. The ruts are forming on the side of the hill by the drain area. Wait until this area dries out from all the rain we had. Don't want to cause new ruts.	\$ 0.00	0.0			
248	Door/Gate	Hangar	In Progress	2020-01-21 08:59	Michele Renfroe	14B left side door on top has door stop missing so the doors move freely. Bolt and plates need to be replaced so the left door will lock properly.	\$ 0.00	0.0			
256	Markings - Runway marking	Airside	In Progress	2020-01-23 13:05	Daniel Thomas Sr.	RUNWAY 24/6 AND RUNWAY 13/13 PAINTED MARKINGS HAVE POOR REFLECTIVITY	\$ 0.00	0.0			
257	Markings - Taxiway marking	Airside	In Progress	2020-01-23 13:05	Daniel Thomas Sr.	TAXIWAYS FOXTROT PAINTED MARKINGS HAVE POOR REFLECTIVITY	\$ 0.00	0.0			
258	Markings - Taxiway marking	Airside	In Progress	2020-01-23 13:05	Daniel Thomas Sr.	TAXIWAY DELTA PAINTED MARKINGS HAVE POOR REFLECTIVITY	\$ 0.00	0.0			
259	Markings - Holding position marking	Airside	In Progress	2020-01-23 13:05	Daniel Thomas Sr.	TAXIWAY FOXTROT AND DELTA HAS POOR REFLECTIVITY AT THE HOLDING POSITION TO RUNWAY 13/31	\$ 0.00	0.0			
262	Signs - Damaged/retroreflective	Airside	In Progress	2020-01-23 13:05	Daniel Thomas Sr.	AIRFIELD SIGNS ON TAXIWAYS C, D, F, AND A HAVE POOR RETROREFLECTIVE AND LIGHTING. CHECK SIGN LIGHT BULBS (ALL), DIRT ON INSIDE/OUTSIDE OF PANELS, AND CHECK POWER AMPS .	\$ 0.00	0.0			

266	Navigational Aids - RENLs/VGSI systems	Airside	In Progress	2020-01-23 13:05	Daniel Thomas Sr.	REMOVE AIRPORT OWNED. OLD NOT WORKING VGSI SYSTEMS OUT OF DELTA 1 SAFETY AND FOXTROT 4 SAFETY AREA.	\$ 0.00	0.0				
267	Paved Areas - Cracks/spalling/heaves	Airside	In Progress	2020-01-24 05:15	Eric Rivers	RW 24/6 has surface cracks	\$ 0.00	0.0				
268	Paved Areas - Ponding/edge dams	Airside	In Progress	2020-01-24 05:15	Eric Rivers	Ponding at D2 entering onto the taxiway	\$ 0.00	0.0				
276	Hazard	Airside	In Progress	2020-01-27 08:09	Raymond Keeler	Drainage grate fell into drainage hole near the maintenance vehicle area behind Hanger 11. This is a safety hazard for anyone driving or walking in area. Eric: You and Cameron remove the grate from the drain and place barricades around the opening. Measure the grate opening so that a new one can be ordered to size.	\$ 0.00	0.0				
278	Wildlife	Hangar	Work Complete	2020-01-27 08:14	Michele Renfroe	7A has noticed where pigeons have started getting into hangar recently. They have never had an issue with this in the past. Jose: Assess and mitigate entry point.	\$ 0.00	0.0	2020-08-10 00:00	Garry Parker		
279	Other	Hangar	Work Complete	2020-01-27 08:34	Michele Renfroe	15B needs to be cleaned from customer move out. Shelves in back of hangar can also be thrown out. Customer waiting to move in.	\$ 0.00	0.0	2020-01-29 00:00	Garry Parker		
280	Roof	Hangar	Work Complete	2020-01-27 08:35	Michele Renfroe	7A back right corner has roof leak as well as back wall.	\$ 0.00	0.0	2020-01-30 00:00	Garry Parker		
281	Other	Hangar	Work Complete	2020-01-27 08:37	Michele Renfroe	18H needs to be cleaned customer move out.	\$ 0.00	0.0	2020-01-29 00:00	Garry Parker		
289	Door/Gate	Terminal Building	Work Complete	2020-02-03 15:47	Raymond Keeler	Police office door in terminal will not close properly. You have to hold the door close and then give a tug for the latch to catch to secure the office door.	\$ 0.00	0.0	2020-03-05 00:00	Garry Parker		
290	Door/Gate	Hangar	Work Complete	2020-02-03 16:41	Garry Parker	RH Door Frame is bent at the bottom, The gap is allowing air and water to enter the hangar when the doors are closed.	\$ 0.00	4.0	2020-02-27 00:00	Garry Parker		
291	Lighting	Hangar	Work Complete	2020-02-04 09:26	Garry Parker	Hangar 18-A exterior light is not working: Repair or Replace/upgrade fixture.	\$ 0.00	0.0	2020-03-16 00:00	Jose Aviles		
295	Door/Gate	Terminal Building	Work Complete	2020-02-10 10:24	Kelvin Mullins	Security Checkpoint Doors needs (2) Two new stoppers on the floor so door want slide close while open.	\$ 0.00	0.0	2020-02-26 00:00	Garry Parker		
296	Other	Hangar	Work Complete	2020-02-10 10:25	Michele Renfroe	15B latch needs to be removed and replaced with new shorter latch to make it connect to the eyelet for locking.	\$ 0.00	1.0	2020-03-06 00:00	Jose Aviles		
297	Other	Hangar	Work Complete	2020-02-10 10:29	Michele Renfroe	15B was cleaned but doors and floor needs to be pressure washed to remove pigeon matter on doors and floors.	\$ 0.00	3.0	2020-04-03 00:00	Jose Aviles		
298	Other	Hangar	Work Complete	2020-02-10 16:41	Michele Renfroe	16A- Open screw holes on the door, left side panel in several locations, back wall at top. Photos attached.	\$ 0.00	2.0	2020-03-16 00:00	Jose Aviles		
299	Roof	Hangar	Work Complete	2020-02-10 16:43	Michele Renfroe	16A - Roof leak on right side of hangar over car could not tell where it was coming from. Leak in middle of hangar at the roof near beam. Photo attached.	\$ 0.00	2.0	2020-03-16 00:00	Jose Aviles		
300	Door/Gate	Terminal Building	Work Complete	2020-02-10 16:44	Marion Anderson	The handle on far right door adjacent to the main entrance had been pulled off the fitting. The handle is on the desk in the Public Safety office. This incident happen on 02/06/2020.	\$ 0.00	0.0	2020-08-10 00:00	Garry Parker		
301	Lighting	Hangar	Work Complete	2020-02-10 16:46	Michele Renfroe	2A - Back light in hangar is blown and fixture seems to be coming out of the ceiling. Customer stated the fixture is spinning and light bulb will not come out of the housing.	\$ 0.00	2.0	2020-03-10 00:00	Jose Aviles		
303	Pavements	Taxiway	Work Complete	2020-02-10 16:49	Michele Renfroe	Between Hangar 15 & 6 water backing up into taxi lane due to water not being able to flow through grass and soil to make it to the drainage ditch. Photos attached.	\$ 0.00	0.0	2020-11-03 00:00	Daniel Thomas Sr.		
304	Facilities	Hangar	Work Complete	2020-02-10 16:51	Michele Renfroe	6C Back of hangar angle iron rusted out with holes present. Photos attached	\$ 0.00	8.0	2020-05-28 00:00	Jose Aviles		

305	Door/Gate	Hangar	Work Complete	2020-02-10 16:56	Michele Renfro	6C - 2nd door gets stuck when opening hangar 1/2 way down	\$ 0.00	2.0	2020-05-28 00:00	Jose Aviles		
306	Roof	Hangar	Work Complete	2020-02-10 16:58	Michele Renfro	6C Front right side of hangar has new roof leaks. Photos attached.	\$ 0.00	2.0	2020-05-28 00:00	Jose Aviles		
307	Door/Gate	Hangar	Work Complete	2020-02-10 16:59	Michele Renfro	21B- Right door hanging up on other door @ top when open all the way. When trying to close it pulls both doors where it is hanging up on top making it hard to close the 1st door. Debbie would prefer to be present on Friday's when looking at the hangar.	\$ 0.00	8.0	2020-09-28 00:00	Jose Aviles		
309	Plumbing	Parking Lot	Work Complete	2020-02-11 16:33	Garry Parker	Water line underground has burst near the Sauer Construction trailer and is spewing above ground. Shut off the water and assess if we can repair this in-house.	\$ 0.00	0.0	2020-02-21 00:00	Garry Parker		
310	Lighting	Terminal Building	Work Complete	2020-02-12 08:56	Raymond Keeler	Light is hanging by wire at underpass to main entrance. See photo	\$ 0.00	0.0	2020-02-12 00:00	Garry Parker		
311	Roof	Hangar	Work Complete	2020-02-12 11:39	Michele Renfro	4B - Roof is leaking in several locations. Photos attached	\$ 0.00	0.0	2020-03-09 00:00	Jose Aviles		
312	Facilities	Crash Station	Work Complete	2020-02-13 09:55	Andre Parker	Crash Station water heater is not working. Fault Code: Blower Prover Open - The blower prover switch remains open after the blower has been energized.	\$ 0.00	4.0	2020-03-09 00:00	Jose Aviles		
314	Paved Areas - Ponding/edge dams	Airside	In Progress	2020-02-19 17:47	Daniel Thomas Sr.	Ponding at Delta-1, both sides of Delta-1	\$ 0.00	0.0				
316	Paved Areas - Ponding/edge dams	Airside	In Progress	2020-02-19 17:47	Daniel Thomas Sr.	Ponding at Delta-5 by RWY-31	\$ 0.00	0.0				
317	Paved Areas - Ponding/edge dams	Airside	In Progress	2020-02-19 17:47	Daniel Thomas Sr.	Ponding at Foxtrot-4 by RWY-31	\$ 0.00	0.0				
319	Paved Areas - Ponding/edge dams	Airside	In Progress	2020-02-19 17:47	Daniel Thomas Sr.	Ponding in the RSA 1,000 foot area of RWY 24/6	\$ 0.00	0.0				
334	Paved Areas - Ponding/edge dams	Airside	In Progress	2020-02-20 11:36	Eric Rivers	Ponding at C2 and TW C	\$ 0.00	0.0				
340	Landscaping	Landscaping	Work Complete	2020-02-25 09:32	Raymond Keeler	On Friday, February 14, 2020 an Avis Rental vehicle tried to turn around on Earnie Shelton Drive just pass Flightways entrance and got the vehicle stuck on the shoulder of Earnie Shelton Drive. The Avis Rental vehicle was driven by customer and while attempting to get the vehicle unstuck it caused approximately \$500 to \$750 in damage to airport property. Avis stated the vehicle incurred front end damage while being removed from the damaged airport property.	\$ 0.00	0.0	2020-02-26 00:00	Garry Parker		
341	Lighting	Terminal Building	Work Complete	2020-02-25 15:44	Garry Parker	fluorescent u bulb (f8) is out in front of Mary's desk.	\$ 0.00	0.0	2020-02-26 00:00	Garry Parker		
343	Lighting	Terminal Building	Work Complete	2020-03-03 08:26	Amber Clark	This is a test	\$ 0.00	0.0	2020-03-03 00:00	Amber Clark		
352	Lighting	Terminal Building	Work Complete	2020-03-03 12:26	Garry Parker	FAA Hallway offices: 2 light fixtures need U bulbs replaced.	\$ 0.00	0.0	2020-03-05 00:00	Garry Parker		
353	Roof	Hangar	Work Complete	2020-03-04 15:03	Michele Renfro	5F roof leaking over right wing of aircraft.	\$ 0.00	1.0	2020-03-06 00:00	Jose Aviles		
354	Roof	Hangar	Work Complete	2020-03-04 15:43	Garry Parker	Hangar 57 has multiple roof leaks that have worsened in a brief period of time. The RFP was published and a contract for Roof Overlay project was awarded to Thayer-Bray Construction.	\$ 50,000.00	0.0	2020-07-31 00:00	Garry Parker		
355	Roof	Terminal Building	Work Complete	2020-03-05 15:44	Garry Parker	Roof leaking in FAA copier room. Contact Steve Clark (FAA Tech Ops) for details.	\$ 0.00	1.0	2020-04-21 00:00	Jose Aviles		
356	Door/Gate	Hangar	Work Complete	2020-03-06 08:12	Amber Clark	21-1 Doors need to be sealed --when others crank up their plane all kinds of stuff is blown into the hangar, even with the doors closed	\$ 0.00	16.0	2020-09-08 00:00	Jose Aviles		

357	Other	Hangar	In Progress	2020-03-06 08:15	Amber Clark	16G Lip in the concrete at the entrance makes getting the aircraft in difficult- needs to be grinded down	\$ 0.00	0.0			
358	Door/Gate	Hangar	In Progress	2020-03-06 08:18	Amber Clark	16G-Doors do not seal	\$ 0.00	0.0			
359	Other	Hangar	In Progress	2020-03-06 08:22	Amber Clark	Hangar 16G- Standing water in hangar- Unsure as to the cause, please check when it has been raining	\$ 0.00	0.0			
366	Door/Gate	Terminal Building	Work Complete	2020-03-10 09:05	Jose Aviles	Double glass door by TSA checkpoint needs new door stops.	\$ 0.00	0.0	2020-03-10 00:00	Jose Aviles	
367	Other	Terminal Building	Work Complete	2020-03-11 08:29	Jose Aviles	Due to recent heavy rain. There has been some leaking in some areas next to the 2nd floor FAA entry doors affecting the ceiling tiles. Maintenance has replaced all damaged tiles. During terminal renovations the roof of the terminal is going to be new and will address ceiling leaks affecting ceiling tiles. End of report.	\$ 0.00	1.0	2020-03-11 00:00	Jose Aviles	
368	Lighting	Terminal Building	Work Complete	2020-03-11 10:18	Jose Aviles	U bulb T8 bulb needs to be replaced in mens restroom by the conference meeting area in terminal.	\$ 0.00	1.0	2020-03-11 00:00	Jose Aviles	
373	HVAC	Terminal Building	Work Complete	2020-03-13 16:14	Jose Aviles	Propellers Restaurant: HVAC unit in the ceiling inside Propellers kitchen condensate drip pan for the HVAC unit is too full of water thus leaking into the kitchen area from above. Maintenance investigated the unit and discovered that this is no drain line for the condensate drain thus collecting water into pan and not being able to drain elsewhere and spilling over the top of the pan. Maintenance also discovered an water alarm device to the drain pan that possibly disabled the unit when the pan is completely full. Thus no one ever noticing that there was no active drain line for the condensate water due to the water alarm disabling the unit. Possibly the water alarm device is malfunctioning or inoperable not disabling the unit as it was installed originally. Maintenance team will have to install an condensate line from the pan into an available drain/sewer line in the general vicinity by cutting an 6-12 length on the 2 inch cast iron drain/sewer line and adding an pvc fitting to plumb the drain pan water into the drain/sewer line. In the mean time the unit as been disabled and notified the personnel at Propellers to not use the unit until the issue has been resolved. End of report.	\$ 0.00	0.0	2020-04-21 00:00	Jose Aviles	
379	Plumbing	Terminal Building	Work Complete	2020-03-16 09:21	Jose Aviles	Emergency Call Propellers Restaurant: Maintenance notified of leak from inside Propellers at coffee maker location spraying water saturating the carpet, floors, walls and inside the cavity of the cabinet where the coffee maker and fountain soda dispenser sit on. Electrical components were wet and being diagnose to ensure proper operation after water is eliminated. Public safety identified where the location of the leak was occurring and disabled the water source feeding that particular line. Maintenance and Public safety cleaned up the area and maintenance continued through the diagnoses and ensured no other possible leaks would occur. Correction needed is to replace the water filter and water filter water line feeding the coffee maker. End of report	\$ 0.00	0.0	2020-04-22 00:00	Jose Aviles	
380	Other	Hangar	Work Complete	2020-03-16 09:49	Garry Parker	Multiple leaks are present due to side walls being open and exposed as the the rubber seals have deteriorated on walls and doors facing the parking lot. Hangar 57 Install new rubber seals that are backordered when they arrive.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.	
390	Hazard	Parking Lot	Work Complete	2020-03-18 15:08	Daniel Thomas Sr.	There are small leftover metal fence materials pieces in the roadway by the SAUER parking lot fence. This was seen and emailed to Amber by John in the tower	\$ 0.00	1.0	2020-03-18 00:00	Daniel Thomas Sr.	
391	Plumbing	Crash Station	Work Complete	2020-03-20 11:48	Andre Parker	Bunker gear washing machine drain is backing up.	\$ 0.00	3.0	2020-09-14 00:00	Jose Aviles	
392	Lighting	Hangar	Work Complete	2020-03-20 11:49	Jose Aviles	Hangar 2A: Maintenance recently replaced 2 light sockets and 2 3-way light switches. Light sources currently in the hangar is not efficient enough lighting up the hangar. Especially when working on their aircraft. Recommend installing an LED fixture to provide adequate lighting in the area. End of report.	\$ 0.00	12.0	2020-08-17 00:00	Jose Aviles	



401	Door/Gate	Hangar	Work Complete	2020-03-25 14:54	Garry Parker	Hangar 17A: Check the sheet metal placement at top of the door to ensure that it isn't preventing the door from closing. If so, adjust as necessary or remove and place Bird Gel Disc at the entry point	\$ 0.00	0.0	2020-03-25 00:00	Jose Aviles		
425	Lighting	Terminal Building	Work Complete	2020-03-27 09:49	Raymond Keeler	Multiple lights out at Delta ticket counter. See attached photo	\$ 0.00	1.0	2020-04-29 00:00	Jose Aviles		
426	Lighting	Terminal Building	Work Complete	2020-03-27 09:50	Raymond Keeler	Multiple lights out at TSA checkpoint. See attached photo.	\$ 0.00	1.0	2020-04-29 00:00	Jose Aviles		
427	Landscaping	Landscaping	Work Complete	2020-03-27 09:54	Garry Parker	Grass is overgrown in the courtyard near hangar 12.	\$ 0.00	0.0	2020-04-15 00:00	Daniel Thomas Sr.		
431	Facilities	Crash Station	Work Complete	2020-03-31 15:25	Richard Baran	Station air-compressor located in maintenance-room 131(Cascade) is inoperative. Switching power-switch from "On" to "Off", then back to "On" had no effect. Shutting power off at breaker, then re-applying power had no effect. Air-compressor is used to provide a constant air-source to apparatus Crash-2.	\$ 0.00	1.0	2020-03-31 00:00	Jose Aviles		
433	Facilities	Terminal Building	Work Complete	2020-04-02 11:18	Jose Aviles	Men Restroom- Located by the conference airport employee meetings 2 T8 u light bulbs need to be replaced, and correct the leak in ceiling in the left stall.	\$ 0.00	2.0	2020-04-02 00:00	Jose Aviles		
434	Other	Hangar	Work Complete	2020-04-02 11:42	Jose Aviles	18H-Need to seal an 2x2 inch hole that allowing water too enter the hangar, as well as seal multiple holes on the back side wall of the hangar and on the roof.	\$ 0.00	2.0	2020-04-02 00:00	Jose Aviles		
435	Other	Hangar	Work Complete	2020-04-02 11:52	Jose Aviles	21G-Random holes on back wall of hangar, hangar doors difficult moving.	\$ 0.00	2.0	2020-04-02 00:00	Jose Aviles		
436	Other	Hangar	Work Complete	2020-04-02 11:55	Jose Aviles	21A- Due too the ground/dirt exceeding past the floor level of the hangar's floor on the side of the wall. When raining would occur water would easily make its way inside the hangar. Maintenance simply dug away the ground/dirt away from the side walls to prevent easy water entry. End of report.	\$ 0.00	1.0	2020-04-02 00:00	Jose Aviles		
437	Door/Gate	Terminal Building	Work Complete	2020-04-04 08:21	Richard Baran	north side-doors(next to Avis RC) do not operate. They were discovered open 04/03/2020 by this officer. Avis RC manager stated that she'd forced them open because Avis employees do not get enough fresh air, and that the lack of airflow is causing moister/mold to drip down out of their AC vents. NOTE: photograph attached for reference.	\$ 0.00	2.0	2020-04-06 00:00	Jose Aviles		
438	Facilities	Crash Station	In Progress	2020-04-04 08:23	Richard Baran	Station air-compressor does not shut off regardless of stored pressure.	\$ 0.00	0.0				
441	Lighting	Terminal Building	Work Complete	2020-04-06 15:47	Jose Aviles	The following lights have been changed out due too being out Outside HR's Office (T8 U Bulb) Outside elevator door 2nd floor next too FAA's doors (T8 U Bulb) Outside Marketing Office (T12 U Bulb) All bulbs were changed out and is in full operational order. End of report.	\$ 0.00	2.0	2020-04-06 00:00	Jose Aviles		
442	Roof	Terminal Building	Work Complete	2020-04-07 11:26	Jose Aviles	Nail needs to be removed from the roof and seal hole.	\$ 0.00	1.0	2020-04-07 00:00	Jose Aviles		
443	Plumbing	Terminal Building	Work Complete	2020-04-08 09:48	Jose Aviles	The women and men's restrooms located at the terminal are clogged at the mainline thus backing up into both restrooms floor drains.	\$ 0.00	2.0	2020-04-08 00:00	Jose Aviles		
444	Plumbing	Terminal Building	Work Complete	2020-04-08 09:53	Jose Aviles	Marketing Manager's Office-When raining water leaks into the corner of the office damaging the ceiling tiles and carpet below.	\$ 0.00	0.0	2020-05-27 00:00	Jose Aviles		
447	HVAC	Flightways	Work Complete	2020-04-09 09:21	Jose Aviles	HVAC system filters need to be replaced.	\$ 0.00	1.0	2020-04-09 00:00	Jose Aviles		
448	Other	Terminal Building	Work Complete	2020-04-09 10:41	Jose Aviles	Install 4 hand sanitizer stations in designated areas.	\$ 0.00	2.0	2020-04-09 00:00	Jose Aviles		
449	HVAC	Terminal Building	Work Complete	2020-04-10 14:17	Jose Aviles	Airport terminal is 80-85 degrees when thermostats are calling for cool.	\$ 0.00	4.0	2020-04-10 00:00	Jose Aviles		

451	Door/Gate	Terminal Building	Work Complete	2020-04-13 09:51	Richard Baran	North sliding doors(by AVIS rental car office) cannot be secured regardless of door-key position. Doors can be opened by hand from both inside and outside the terminal. No locking mechanism whatsoever.	\$ 0.00	1.0	2020-04-21 00:00	Jose Aviles		
453	Roof	Terminal Building	Work Complete	2020-04-13 10:57	Jose Aviles	Ceiling tiles are wet and falling down onto the carpet on the 2nd floor next to FAA doors.	\$ 0.00	2.0	2020-04-13 00:00	Jose Aviles		
454	HVAC	Terminal Building	Work Complete	2020-04-13 14:11	Jose Aviles	Terminal Welcome Center HVAC Unit: Currently not operational need diagnoses to assess further access.	\$ 0.00	2.0	2020-04-13 00:00	Jose Aviles		
456	Landscaping	Landscaping	Work Complete	2020-04-14 10:15	Garry Parker	4034 Desoto Dr. Lot is overgrown, needs to be cut.	\$ 0.00	0.0	2020-04-16 00:00	Daniel Thomas Sr.		
465	Roof	Terminal Building	Work Complete	2020-04-20 09:18	Jose Aviles	Due too recent heavy rain on 4/19/2020 1 ceiling tile was damaged and fell down in the admin hallway next too FAA's doors.	\$ 0.00	1.0	2020-04-20 00:00	Jose Aviles		
466	Lighting	Hangar	Work Complete	2020-04-20 10:59	Garry Parker	Hangar 19 has several lights out that need to be replaced. Point of contact Robert or Jack.	\$ 0.00	1.0	2020-04-21 00:00	Jose Aviles		
467	Other	Hangar	Work Complete	2020-04-21 08:18	Jose Aviles	Hanger 19 (CAS) interior light need to be replaced, roof leaking.	\$ 0.00	3.0	2020-04-21 00:00	Jose Aviles		
470	Landscaping	Perimeter Fence	Work Complete	2020-04-21 14:18	Garry Parker	Cut the grass around the hangars and fenceline on Ernie Shelton Drive. Extremely overgrown with weeds several feet high on the fenceline.	\$ 0.00	0.0	2020-05-18 00:00	Daniel Thomas Sr.		
471	Facilities	Terminal Building	Work Complete	2020-04-21 14:21	Garry Parker	Marshall, Please pick up paystubs from the government center first thing Wednesday morning. Place them in my mailbox in the admin copy room upstairs. Thank you.	\$ 0.00	0.0	2020-04-24 00:00	Daniel Thomas Sr.		
480	Roof	Terminal Building	Work Complete	2020-04-27 15:53	Jose Aviles	FAA Admin; Rain water leak in FAA copier room and outside FAA 2nd floor doors.	\$ 0.00	4.0	2020-05-27 00:00	Jose Aviles		
481	Lighting	Hangar	Work Complete	2020-04-28 09:54	Michele Renfroe	15B tenant called and stated the light is still missing as well as the inside portion of the doors still have pigeon matter on them and could it please be pressure washed to remove prior dirt and debris.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles		
482	Other	Hangar	Work Complete	2020-04-28 20:31	Michele Renfroe	6A hangar needs to be cleaned for tenant move in on May 1st. Please check to make sure the light is working on on the wooden side partitions are secured with nails and not rotten. or falling over.	\$ 0.00	4.0	2020-09-08 00:00	Jose Aviles		
483	Wildlife	Hangar	In Progress	2020-04-28 20:34	Michele Renfroe	11 Bay 4 Skip Williams called and stated he has been seeing pigeons in his hangar right by the office door to the right.	\$ 0.00	0.0				
486	Lighting	Terminal Building	Work Complete	2020-04-29 11:22	Jose Aviles	Terminal Male Restroom: Lights out in middle stall.	\$ 0.00	1.0	2020-04-29 00:00	Jose Aviles		
487	Roof	Hangar	Work Complete	2020-04-29 14:07	Garry Parker	Hangar 12: Multiple Holes in the roof and side panels . Technicians need to gain access to the hangar during rain. #1. Utilizing the lift, identify the holes at roof level and follow up with repair. #2. Pigeon mitigation and entry prevention: Expel pigeons and close points of entry. #3. Replace center door seals facing G.A. apron. Point of contact for hangar entry is tenant/representative Greg Russell: gwr@ldl.net	\$ 0.00	8.0	2020-06-08 00:00	Jose Aviles		
492	Facilities	Hangar	Work Complete	2020-05-04 09:38	Garry Parker	Hangar 7A, 7B, 4B all bays. Install chicken wire barrier at the gaps separating hangars (from wall to roof). Prevent birds from crossing from one bay to the next. Coordinate with Michele and Daniel.	\$ 0.00	0.0	2020-09-17 00:00	Jose Aviles		
494	Facilities	Terminal Building	Work Complete	2020-05-05 10:07	Jose Aviles	Removed 2 ceiling mounted TVs after the TSA checkpoint.	\$ 0.00	2.0	2020-05-05 00:00	Jose Aviles		
495	Roof	Hangar	In Progress	2020-05-05 10:14	Michele Renfroe	7A Customer states work order was completed and closed in January on roof leak but roof is still leaking on right side of hangar.	\$ 0.00	0.0				
496	Facilities	Terminal Building	Work Complete	2020-05-05 10:21	Garry Parker	Jose, Purchase 6 ea. 2x4x8 framing lumber. Place the lumber in marketing office.	\$ 0.00	0.0	2020-05-14 00:00	Garry Parker		

497	Landscaping	Landscaping	Work Complete	2020-05-05 10:24	Garry Parker	Armour Road up to Gate 16 is overgrown and needs to be cut.	\$ 0.00	0.0	2020-05-08 00:00	Garry Parker		
498	Landscaping	Landscaping	Work Complete	2020-05-05 10:26	Garry Parker	Fuel Farm Landscaping: Remove barriers and fenceposts, cut the grass around the fuel farm and around the new retaining wall.	\$ 0.00	0.0	2020-05-14 00:00	Garry Parker		
499	Other	Hangar	In Progress	2020-05-05 10:51	Michele Renfroe	7A Customer states that water is still coming in on back wall as well as seeping up through the floor on the back right side of hangar.	\$ 0.00	0.0				
500	Door/Gate	Hangar	In Progress	2020-05-06 12:14	Michele Renfroe	3A Customer states left inner door is hard to push and open all the way	\$ 0.00	0.0				
501	Other	Terminal Building	Work Complete	2020-05-07 09:48	Sonya Overton	Point of contact is Sonya Overton: Jose, please coordinate with Sonya and assign facilities and custodial staff as needed. Need assistance from housekeeping and maintenance to help clean and move the Marketing materials, Christmas decorations, etc. from the back room to the front storage closet in the West Terminal. Shelving needs to also be moved which will require some breaking down of shelving.	\$ 0.00	0.0	2020-08-10 00:00	Garry Parker		
502	Other	Terminal Building	Work Complete	2020-05-07 09:53	Sonya Overton	Jose, please coordinate with Sonya Overton and assign facilities and custodial staff as needed. Cyber spot breakdown. Everything in the Cyber Spot needs to be safely removed and placed in the upstairs closet at the end of the Delta gate with the padlock. aka Christmas closet. This includes all clocks, magazine racks, poster frames, tables, chairs and television. The black chair may be damaged, if so it can be placed in the trash. Everything else needs to be kept.	\$ 0.00	0.0	2020-07-01 00:00	Daniel Thomas Sr.		
503	Lighting	Hangar	Work Complete	2020-05-07 09:57	Michele Renfroe	Jose, Please coordinate with Michele for hangar entry authorization from the tenant. 3A Customer states light is out in hangar	\$ 0.00	1.0	2020-06-16 00:00	Jose Aviles		
504	Plumbing	Hangar	Work Complete	2020-05-07 11:18	Garry Parker	Plumbing/pipe leak in the offices at Hangar 57. Point of contact is Richard Desportes.	\$ 0.00	5.0	2020-05-13 00:00	Jose Aviles		
506	Other	Terminal Building	Work Complete	2020-05-08 09:40	Sonya overton	Need assistance with the catering boxes located behind the gate area next to Propellers. Most of the catering materials have been packed however the boxes are very heavy. Need maintenance to help move the small boxes to Monica's closet and the larger boxes to go upstairs in the Delta gate area. Coordinate with Sonya to moved as soon as possible as they are out in the open.	\$ 0.00	4.0	2020-05-15 00:00	Jose Aviles		
511	Other	Hangar	In Progress	2020-05-11 09:24	Michele Renfroe	5F Customer states when raining water pours in under the outside wall panel by the grass area of the hangar into the storage area that is connected to the hangar.	\$ 0.00	0.0				
512	Door/Gate	Hangar	In Progress	2020-05-11 13:57	Michele Renfroe	7C pigeons getting through holes at top of door. Customer stated he had noticed bird matter on his plane	\$ 0.00	0.0				
513	Other	Hangar	In Progress	2020-05-11 14:33	Michele Renfroe	4C outside gutter needs to be sealed at crack, photo attached	\$ 0.00	0.0				
514	Fence	Flightways	Work Complete	2020-05-11 14:35	Michele Renfroe	Walk through gate above wire and pole has been knocked down by repeated wind. The end caps rusted and broke causing the pole in between the wire to come down.	\$ 0.00	1.0	2020-05-14 00:00	Daniel Thomas Sr.		
515	Door/Gate	Hangar	Work Complete	2020-05-11 14:37	Michele Renfroe	H13 Metal on door panel was caught on door frame and rip the metal away from the screws. Also welding iron on door and bottom frame to make door close.	\$ 0.00	18.0	2020-08-17 00:00	Jose Aviles		
516	Facilities	Hangar	Work Complete	2020-05-11 14:39	Michele Renfroe	6A Original work order was completed and close but hangar was not completed. Hangar still needs to be cleaned for new tenant move in.	\$ 0.00	0.0	2020-08-11 00:00	Garry Parker		
517	Facilities	Hangar	Work Complete	2020-05-11 14:41	Michele Renfroe	1F Customer has moved out. Please have entire hangar cleaned for new customer rental.	\$ 0.00	4.0	2020-06-24 00:00	Jose Aviles		

518	Facilities	Hangar	Work Complete	2020-05-11 14:43	Michele Renfroe	7A Please see attached photos of back wall angle iron rusted as well as water under the painted floor surface. Needs to be sealed along back wall and side wall to prevent water from getting under painted floor. Photos also show corner post.	\$ 0.00	3.0	2020-05-27 00:00	Jose Aviles		
522	Electrical	Hangar	Work Complete	2020-05-14 13:01	Michele Renfroe	5B Customer states switch to let the door up and down has been failing. Today when he came back in the door let down but the switch will not reengage to let the door back up.	\$ 0.00	0.0	2020-05-27 00:00	Jose Aviles		
523	Plumbing	Terminal Building	Work Complete	2020-05-14 14:29	Jose Aviles	2 1/2 inch copper cooling tower return line is leaking inside the cyber spot area.	\$ 0.00	3.0	2020-05-14 00:00	Jose Aviles		
524	Other	Terminal Building	Work Complete	2020-05-18 08:16	Sonya Overton	Social distancing signs for seating have been created and need to be placed in the terminal gate boarding seating area. The signs need to be adhered to the seats with some form of double sided sticky tape that doesn't remove easily. This area will also need to be reconfigured to practice social distancing and to maximize seating.	\$ 0.00	0.0	2020-06-01 00:00	Garry Parker		
525	Facilities	Terminal Building	Work Complete	2020-05-18 08:18	Sonya Overton	JOSE: Please contact Sonya Overton to collaborate exact details of placement. 6 ft. distancing floor decals are in the Marketing office and need to be placed in the terminal in the following areas: Security Checkpoint, Each rental car counter (3 each for a total of 12) and Delta ticket counter 5 or 6 will need to be used here. The majority of the decals will be used at the checkpoint and in the gate area for boarding. Please remove any tape currently on the floor before installing.	\$ 0.00	0.0	2020-05-22 00:00	Garry Parker		
532	Lighting	Hangar	Work Complete	2020-05-18 09:12	Garry Parker	Jose, Contact Michele Renfroe for access if necessary. Hangar 18A exterior light is out.	\$ 0.00	0.0	2020-05-28 00:00	Jose Aviles		
533	Lighting	Terminal Building	Work Complete	2020-05-18 09:14	Garry Parker	Terminal Light is out over Delta back door (exterior)	\$ 0.00	1.0	2020-08-26 00:00	Jose Aviles		
534	Lighting	Terminal Building	Work Complete	2020-05-18 09:19	Garry Parker	Exterior terminal light over the Maintenance door is out.	\$ 0.00	1.0	2020-08-26 00:00	Jose Aviles		
535	Lighting	Perimeter Fence	Work Complete	2020-05-18 09:21	Garry Parker	Light is out at Gate Z	\$ 0.00	1.0	2020-08-26 00:00	Jose Aviles		
536	Other	Perimeter Fence	Work Complete	2020-05-18 09:55	Daniel Thomas Sr.	1. A dead tree branch is on top of the perimeter fence. 2. Cut tree limbs growing thought the perimeter fence. 1 and 2 are located by the F-1 area. Removed dead tree branch, limbs growing thought fence line, and cut grass and weeds by the perimeter fence line.	\$ 0.00	0.0	2020-05-19 00:00	Daniel Thomas Sr.		
537	Signs	Landscaping	Work Complete	2020-05-19 10:52	Garry Parker	CONTACT Sonya Overton please. Sonya will meet near the road at 2:30 pm today 5/19/2020 Three 2x4x8 boards need to be purchased for an additional 'under construction' sign. Fluorescent marking paint is required. Purchase if necessary. Sonya will provide specific instruction on site to mark areas for sign posts.	\$ 0.00	0.0	2020-05-19 00:00	Daniel Thomas Sr.		
542	Door/Gate	Hangar	Work Complete	2020-05-26 09:10	Michele Renfroe	9F Customer stated that within the last couple of weeks the third door is extremely hard to open. Could you please check to see if something is jamming the rollers or the track.	\$ 0.00	2.0	2020-06-23 00:00	Jose Aviles		
543	Other	Terminal Building	Work Complete	2020-05-26 09:12	Raymond Keeler	Rope for Georgia state flag is off the wheel at the top of the flag pole. Unable to lower or move the Georgia state flag.	\$ 0.00	1.0	2020-09-08 00:00	Jose Aviles		
546	Door/Gate	Hangar	Work Complete	2020-05-28 14:00	Jack Bartholet	Hangar 1B, door out of adjustment	\$ 0.00	8.0	2020-08-17 00:00	Jose Aviles		
547	Erosion	Hangar	Work Complete	2020-05-28 14:06	Garry Parker	Hangar 19 NW side has an opening in the asphalt that causes debris and fod to wash out on to the taxiway.	\$ 0.00	0.0	2020-05-29 00:00	Daniel Thomas Sr.		
551	Other	Terminal Building	Work Complete	2020-06-03 09:30	Adrian Sellers	The ice cream machine that sits in front of Propellers has to be moved, please coordinate with Ben on the new location of the machine. It has to be moved Wednesday 6/3/2020 in order for the wall to go up for contractors to start demo on the restaurant.	\$ 0.00	2.0	2020-06-08 00:00	Jose Aviles		

552	Other	Terminal Building	Work Complete	2020-06-03 09:31	Adrian Sellers	The coke machine that sits in front of Propellers has to be moved. please coordinate with Ben on the new location of the machine. It has to be moved Wednesday 6/3/2020 in order for the wall to go up for contractors to start demo on the restaurant.	\$ 0.00	2.0	2020-06-08 00:00	Jose Aviles		
553	Other	Terminal Building	Work Complete	2020-06-03 09:31	Adrian Sellers	The Relay For Life Case moved to the end of the west side of the terminal near the food truck area. Coordinate with Adrian if you have any questions. This needs to be moved by 10am wednesday 6/3/2020 because the wall is going up to start demo on propellers.	\$ 0.00	1.0	2020-06-08 00:00	Jose Aviles		
557	Signs	Parking Lot	Work Complete	2020-06-04 09:59	Andre Parker	POC is Chief Parker. Please coordinate with Chief for the exact location requirements for sign placement. We have some Tow Warning signs to be posted at the entrance to our parking lots. State Law requires that signs be posted for 24 hours before we can have a vehicle towed from our property. We have purchased 6 signs to be placed at the parking lot entrances and curbside.	\$ 0.00	0.0	2020-06-08 00:00	Daniel Thomas Sr.		
558	Lighting	Ramp	Work Complete	2020-06-04 16:04	Daniel Thomas Sr.	Rotating Beacon light has to be turned on and off by the tower only	\$ 0.00	0.0	2020-06-04 00:00	Daniel Thomas Sr.		
561	Other	Terminal Building	Work Complete	2020-06-08 11:54	Adrian Sellers	Pardon Our Progress sign that needs to go up in the check point on the wall that was extended ASAP. Please give me a call if you need to. Jose, contact Adrian for details.	\$ 0.00	1.0	2020-06-08 00:00	Jose Aviles		
562	Roof	Hangar	In Progress	2020-06-08 16:40	Jose Aviles	12- has 2 roof leaks identified by maintenance.	\$ 0.00	0.0				
563	NAVAIDS	Runway	Work Complete	2020-06-08 17:00	Daniel Thomas Sr.	RWY -24 RSA, THE TWO REILS PAINT IS FADING AND NEEDS TO BE REPAINTED AIRPORT ORANGE.	\$ 0.00	0.0	2020-06-08 00:00	Daniel Thomas Sr.		
564	Hazard	Hangar	Work Complete	2020-06-09 08:40	Jack Barholet	Hangar 1B - upper hangar wall is falling in	\$ 0.00	3.0	2020-08-17 00:00	Jose Aviles		
567	Signs	Landscaping	Work Complete	2020-06-11 14:49	Michele Renfro	Gate 10 - On Ernie Shelton side of gate there is an old sign frame that no longer has anything on it. Please remove .	\$ 0.00	0.0	2020-06-11 00:00	Daniel Thomas Sr.		
568	Other	Landscaping	Work Complete	2020-06-11 14:50	Michele Renfro	4A Dirt mound at end of hangar needs to be shoveled down to keep ants from getting into hangar and building a mound.	\$ 0.00	0.0	2020-06-11 00:00	Daniel Thomas Sr.		
569	Other	Hangar	Work Complete	2020-06-11 14:51	Michele Renfro	1B - 12 ft Panel running left to right on back left side of wall is falling away from the ceiling. Hazard could fall on plane.	\$ 0.00	0.0	2020-08-10 00:00	Garry Parker		
570	Door/Gate	Hangar	In Progress	2020-06-11 14:51	Michele Renfro	15 Hangar- All door panels with rollers on all bays needs screws to be put in to keep the panel that holds on the rollers from bowing. 3/4 of the screws that hold the door panel with rollers that holds the door to the hangar is missing. Extreme concern with a heavy wind the door may fall if screws not replaced.	\$ 0.00	0.0				
571	Door/Gate	Hangar	In Progress	2020-06-11 14:52	Michele Renfro	14 Hangar- All door panels with rollers on all bays needs screws to be put in to keep the panel that holds on the rollers from bowing. 3/4 of the screws that hold the door panel with rollers that holds the door to the hangar is missing. Extreme concern with a heavy wind the door may fall if screws not replaced.	\$ 0.00	0.0				
573	Door/Gate	Crash Station	In Progress	2020-06-11 14:54	Raymond Keeler	Bay Door 3 is not closing properly and the close must be pressed until door is completely closed.	\$ 0.00	0.0				
575	Other	Terminal Building	Work Complete	2020-06-12 15:05	Jose Aviles	FAA: 1) Lights out, one on the Admin Wing on the back hallway by the restrooms and one on the stairwell between the second and third floor. 2) The thumb knob for the water fountain on the back hallway broke off. *** MADE A NEW WORK ORDER FOR THIS 12/31/2020 DT***	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.		
584	Lighting	Terminal Building	Work Complete	2020-06-15 11:27	Garry Parker	Light bulbs are out in Ladies Restroom in Administration office.	\$ 0.00	2.0	2020-06-23 00:00	Jose Aviles		

586	Signs	Parking Lot	Work Complete	2020-06-16 14:28	Raymond Keeler	Cole's Towing & Recovery provided seven (7) towing signs today. Coordinated with Operations to have the signs hung up and the old signs to be given back to Cole's Towing & Recovery to be refurbished.	\$ 0.00	0.0	2020-06-16 00:00	Daniel Thomas Sr.		
587	Lighting	Hangar	Work Complete	2020-06-16 16:18	Jose Aviles	3A interior light out need to be replaced	\$ 0.00	1.0	2020-06-16 00:00	Jose Aviles		
588	Lighting	Hangar	Work Complete	2020-06-18 15:38	Garry Parker	Hangar 19 - one light out. Please contact Robert Boehlein	\$ 0.00	0.0	2020-08-11 00:00	Garry Parker		
592	Pavements	Flightways	Work Complete	2020-06-19 14:41	Daniel Thomas Sr.	The parking lot in front of the FBO (landside) needs to be swept with the street sweeper. There are small rocks, sand, and debris in the parking lot-by Daniel Thomas Sr.	\$ 0.00	0.0	2020-06-19 00:00	Daniel Thomas Sr.		
593	Sweeping	Parking Lot	Work Complete	2020-06-19 14:48	Daniel Thomas Sr.	Use the street sweeper to sweep the long term parking lot, short term parking lot, and all roads leading in and out of the Columbus Airport (landside). By Daniel Thomas Sr.	\$ 0.00	0.0	2020-06-19 00:00	Daniel Thomas Sr.		
599	Signs	Landscaping	Work Complete	2020-06-24 13:17	Sonya Overton	The bushes have overgrown covering the wayfinding sign to the terminal across the street from Long Term parking. They need to be cut.	\$ 0.00	0.0	2020-06-26 00:00	Daniel Thomas Sr.		
600	Electrical	Terminal Building	Work Complete	2020-06-24 13:18	Monica Stone	The electrical socket on the right side of the wall needs to be checked out. It is to push a plug into the outlet. Thank you	\$ 0.00	1.0	2020-09-08 00:00	Jose Aviles		
601	Other	Hangar	Work Complete	2020-06-24 13:19	Michele Renfroe	5D end all the way down hangar needs to be caulked to help the water from going under the metal and entering the hangar.	\$ 0.00	2.0	2020-06-24 00:00	Jose Aviles		
602	Door/Gate	Hangar	Work Complete	2020-06-24 13:20	Michele Renfroe	6B Customer stated 3rd hangar door hanging up on screws and 2nd door. Hard to open with one person	\$ 0.00	0.0	2020-09-22 00:00	Jose Aviles		
603	Other	Hangar	Work Complete	2020-06-24 13:20	Michele Renfroe	15F Hangar needs to be cleaned on floor and doors from pigeon matter, Michele must call tenant to move aircraft before cleaning.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles		
604	Other	Hangar	Work Complete	2020-06-24 13:21	Michele Renfroe	15C Hangar needs to be cleaned on floor and doors from pigeon matter	\$ 0.00	4.0	2020-06-24 00:00	Jose Aviles		
605	Other	Hangar	Work Complete	2020-06-24 13:21	Michele Renfroe	15A Hangar needs to be cleaned from pigeon matter on floor and doors	\$ 0.00	4.0	2020-06-24 00:00	Jose Aviles		
607	FOD	Airside	Work Complete	2020-06-26 10:44	Daniel Thomas Sr.	Sweep the GA ramp areas, Commercial ramp area, and around all the hangers for any FOD.	\$ 0.00	0.0	2020-06-26 00:00	Daniel Thomas Sr.		
616	HVAC	Terminal Building	Work Complete	2020-07-01 08:33	Raymond Keeler	A/C unit in the temporary Police office is not working.	\$ 0.00	1.0	2020-07-22 00:00	Jose Aviles		
620	Lighting	Terminal Building	Work Complete	2020-07-08 11:27	Amber Clark	Light out at second floor stairwell	\$ 0.00	0.0	2020-07-08 00:00	Daniel Thomas Sr.		
625	Lighting	Crash Station	Work Complete	2020-07-09 19:37	Raymond Keeler	Bathroom light between room 113 & 117 is out. Jose was working on the light but never completed the work order. Did not see the work order "In Progress" in PRODIGI-Q so I am resubmitting work request.	\$ 0.00	0.0	2021-04-02 00:00	Daniel Thomas Sr.		
630	Lighting	Hangar	Work Complete	2020-07-11 19:04	Daniel Thomas Sr.	WORK REQUEST # 223 BY ANDREW RAMBO SERRANO ON JUNE 30, 2020 AT 20:36. Outside light above hangar 5-C is filling with water. The lower set of LEDs in the light assembly has already shorted out and no longer works. The area is now very dark at night.	\$ 0.00	0.0	2020-07-20 00:00	Daniel Thomas Sr.		
634	HVAC	Flightways	Work Complete	2020-07-13 16:03	Michele Renfroe	HVAC system lines need to be blown out so water can drain properly. Possible overflow of pan	\$ 0.00	0.0	2020-07-15 00:00	Daniel Thomas Sr.		
636	Roof	Hangar	In Progress	2020-07-14 10:15	Michele Renfroe	2C - Customer states that the 2 front roof seams are leaking on the wings of his aircraft. Could we please seal the seams?	\$ 0.00	0.0				
637	Facilities	Crash Station	In Progress	2020-07-14 10:17	Richard Baran	Ice Machine inoperative - no power.	\$ 0.00	0.0				
638	Facilities	Crash Station	Work Complete	2020-07-14 10:21	Richard Baran	Station air-compressor will not build pressure beyond 60psi, will not shut off.	\$ 0.00	0.0	2020-08-10 00:00	Garry Parker		

639	HVAC	Crash Station	Work Complete	2020-07-14 16:31	Richard Baran	HP-3 does not seem to be working. Air conditioning for dorm rooms 118-124 is not working.	\$ 0.00	2.0	2020-08-17 00:00	Jose Aviles		
646	Lighting	Hangar	Work Complete	2020-07-16 15:31	Garry Parker	Hangar # 19 - Replace inoperative overhead lights with LED upgrades.	\$ 0.00	0.0	2020-08-05 00:00	Garry Parker		
647	Roof	Hangar	In Progress	2020-07-16 15:35	Garry Parker	Hangar# 19 - Multiple holes in the roof causing leaks. Assess and repair. If temporary and fast repair is possible, annotate this on the work order and leave the work order open until a permanent repair is complete.	\$ 0.00	0.0				
648	Other	Terminal Building	Work Complete	2020-07-17 11:28	Adrian Sellers	The TV(broken one) that is mounted in the baggage claim area closest to the new public safety office needs to be taken down and taken to the crash station and coordinate with myself(Adrian) for placement at the crash station. 706-617-0339 I do not want it mounted at the crash station just taken there.	\$ 0.00	1.0	2020-09-17 00:00	Jose Aviles		
650	Other	Terminal Building	Work Complete	2020-07-21 08:43	Marion Anderson	The rope is stuck in the top pulley on the flagpole preventing the Georgia State flag from being lowered or raised.	\$ 0.00	1.0	2020-09-08 00:00	Jose Aviles		
651	Fence	Perimeter Fence	Work Complete	2020-07-21 16:45	Jose Aviles	Flightways gate into the airfield is malfunctioning and staying in the open position. Public safety and CSG Facilities secured the gate with chain and lock with safety cones blocking off entrance.	\$ 0.00	2.0	2020-09-17 00:00	Jose Aviles		
659	Door/Gate	Terminal Building	Work Complete	2020-07-27 10:23	Marion Anderson	The inner automatic doors at the main entrance toward the TSA checkpoint area are out of order. The doors are currently switch off in the open position.	\$ 0.00	0.0	2020-08-03 00:00	Garry Parker		
660	Roof	Hangar	In Progress	2020-07-27 14:33	Austin Edwards	17-A Leaking hangar. See pictures attached.	\$ 0.00	0.0				
663	Door/Gate	Hangar	In Progress	2020-07-31 08:33	Michele Renfroe	11 Bay 3 - Customer states that the doors are still extremely hard to open and close especially with one person. This is the feedback they received from a survey they sent out to all the RCAC members. They would like to see the motors could be put on the doors to help with opening and closing them.	\$ 0.00	0.0				
664	Door/Gate	Hangar	Work Complete	2020-07-31 08:34	Robert Boehnlein	Hangar 19 doors are becoming almost impossible to open without machinery.	\$ 0.00	0.0	2020-08-17 00:00	Garry Parker		
668	Signs	Terminal Building	Work Complete	2020-08-05 11:22	Sonya Overton	Please remove the Hometown Airport Banner from above the main entrance of the terminal so that we can move the orange directional signage above the doorway. We are having issues with passengers not understanding the direction due to the current placement of the orange signs. Please place the banner in the marketing office. Thank you.	\$ 0.00	0.0	2020-08-05 00:00	Garry Parker		
669	Other	Terminal Building	Work Complete	2020-08-05 11:25	Adrian Sellers	They have removed all the lettering as well as the overhead heaters in Phase B1 Sonya wanted to keep, can you please move them upstairs into the locked room on the 2nd floor when you get a chance. They are located in the locked vestibule in a box.	\$ 0.00	0.0	2020-08-26 00:00	Jose Aviles		
683	Herbicide Weed Killer Spraying	Flightways	Work Complete	2020-08-16 20:59	Darryl Graham	Fuel Farm - grass and weeds	\$ 0.00	0.0	2020-08-17 00:00	Daniel Thomas Sr.		
684	Door/Gate	Hangar	Work Complete	2020-08-16 21:01	David E. Hammonds (Rick)	Hangar 3F - door is off track	\$ 0.00	0.0	2020-08-17 00:00	Garry Parker		
685	Door/Gate	Terminal Building	Work Complete	2020-08-18 07:11	Andre Parker	The main automatic doors will not open when approached. I opened the doors and turned the doors off with the switch located under the top panel left side.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.		
687	Facilities	Foxtrot GA Ramp Area	Work Complete	2020-08-19 08:56	Debbie. Hgr 21B	regarding the SW-side bathroom situation, is there any way we can have the building opened up for use of the sink, until the septic/sewer upgrade is complete? (Maybe some way to disable use of toilet until repair is complete but still allow sink usage for hand-washing?) Or install a temporary outside faucet or something... Also, has anyone been checking inside the building for infestations (ants, wasps, mice, snakes, etc	\$ 0.00	1.0	2020-08-26 00:00	Jose Aviles		

688	Other	Hangar	Work Complete	2020-08-19 09:05	Michele Renfroe	3C - Customer moved out and needs to be cleaned for new customer move in. Please empty final contents, clean floors, back of doors and tracks.	\$ 0.00	3.0	2020-09-08 00:00	Jose Aviles		
689	Other	Hangar	Work Complete	2020-08-20 12:25	Michele Renfroe	11 Bay 6 needs to be cleaned for tenant move out	\$ 0.00	4.0	2020-09-08 00:00	Jose Aviles		
690	Door/Gate	Hangar	In Progress	2020-08-20 12:26	Michele Renfroe	10C - customer states doors are jumping track and have a gap each time he opens the hangar.	\$ 0.00	0.0				
693	Lighting	Terminal Building	Work Complete	2020-08-24 11:47	Jose Aviles	Hertz car rental interior led light fixture flickering on and off continuously.	\$ 0.00	1.0	2020-08-24 00:00	Jose Aviles		
694	Other	Delta GA Ramp Area	Work Complete	2020-08-25 15:27	Jose Aviles	Terminal swing bridge breaking mechanism is inoperable, damaged tarp on swing bridge needs to be removed and install new tarp, wasp nest under swing bridge needs to be addressed. Hazard for passengers and Delta personnel.	\$ 0.00	4.0	2020-08-25 00:00	Jose Aviles		
698	Other	Terminal Building	Work Complete	2020-08-28 15:41	Shaundra Goodwin	Some lights out in Shaundra's office.	\$ 0.00	1.0	2020-09-08 00:00	Jose Aviles		
699	Other	Terminal Building	Work Complete	2020-08-28 15:42	Adrian Sellers	A few of the hand sanitizing stations are out of sanitizer. I know of the one in front of Monica's office is out and the one that was in front of the main entrance doors when you walk in, but it was missing so i'm not sure where it went.	\$ 0.00	0.0	2020-09-19 00:00	Daniel Thomas Sr.		
700	Hazard	Airside	Work Complete	2020-08-31 12:47	Daniel Thomas Sr.	The passenger swing bridge has a flat tire and can not be used. the tire needs to be replaced. Tire size 5.30-12	\$ 0.00	0.0	2020-09-01 00:00	Daniel Thomas Sr.		
708	Plumbing	Crash Station	Work Complete	2020-09-17 07:43	Richard Baran	Bathroom between rooms 119 and 123. Shower. When running, shower-head emits a high-pitched whistle. Shower-head is not adjustable.	\$ 0.00	1.0	2020-09-23 00:00	Jose Aviles		
709	Plumbing	Crash Station	Work Complete	2020-09-17 07:44	Richard Baran	Bathroom between rooms 119 and 123. Toilet. flush valve or pipe below flush valve leaks whenever toilet is flushed. Flush valve is become more and more difficult to actuate.	\$ 0.00	1.0	2020-09-23 00:00	Jose Aviles		
710	Lighting	Hangar	Work Complete	2020-09-17 11:19	Jose Aviles	16D exterior light affecting pilots field of vision. Adjusted light. If any issues still occur. It will be addressed.	\$ 0.00	2.0	2020-09-17 00:00	Jose Aviles		
711	HVAC	Terminal Building	Work Complete	2020-09-17 11:25	Jose Aviles	FAA/Delta storage room has a steady stream leak from the ceiling.	\$ 0.00	3.0	2020-09-17 00:00	Jose Aviles		
712	Roof	Terminal Building	Work Complete	2020-09-17 11:30	Jose Aviles	TSA equipment room has a ceiling leak.	\$ 0.00	1.0	2020-09-17 00:00	Jose Aviles		
713	Other	Hangar	Work Complete	2020-09-17 11:35	Jose Aviles	14A back wall angle iron is rusted out allowing bugs and water to enter the wall.	\$ 0.00	4.0	2020-09-17 00:00	Jose Aviles		
714	Wildlife	Hangar	Work Complete	2020-09-21 16:23	Jose Aviles	Hangar 21J door gap needs to be closed for birds.	\$ 0.00	3.0	2020-09-21 00:00	Jose Aviles		
715	Wildlife	Hangar	Work Complete	2020-09-21 16:25	Jose Aviles	Hangar 21G door gaps need to be enclosed due to birds.	\$ 0.00	3.0	2020-09-21 00:00	Jose Aviles		
716	Other	Hangar	Work Complete	2020-09-21 16:28	Jose Aviles	Hangar 17A backwall seeping in water when raining.	\$ 0.00	2.0	2020-09-21 00:00	Jose Aviles		
717	Wildlife	Hangar	Work Complete	2020-09-21 16:30	Jose Aviles	Hangar 12 has bird dropping all over floor need to clean.	\$ 0.00	4.0	2020-09-21 00:00	Jose Aviles		
718	Electrical	Hangar	Work Complete	2020-09-21 16:32	Jose Aviles	Hangar 21J electrical outlet needs to be replaced, as well as the light switch.	\$ 0.00	2.0	2020-09-21 00:00	Jose Aviles		
719	Door/Gate	Hangar	Work Complete	2020-09-22 16:23	Jose Aviles	Hangar 6B 3rd inner door is sticking. Hard to move.	\$ 0.00	1.0	2020-09-22 00:00	Jose Aviles		
723	HVAC	Crash Station	Work Complete	2020-09-23 16:20	Jose Aviles	Conduct HVAC condenser(outside units) coil cleaning preventive maintenance on all crash station units.	\$ 0.00	4.0	2020-09-23 00:00	Jose Aviles		



724	Electrical	Parking Lot	Work Complete	2020-09-23 16:41	Jose Aviles	Car rental wash station bay 2 electrical light switch is arcing causing smoke.	\$ 0.00	1.0	2020-09-23 00:00	Jose Aviles		
725	Erosion	Hangar	In Progress	2020-09-25 08:58	Michele Renfroe	H57 - Customer sent pictures showing that during the last hard rain he had mud come through the walls from the outside where the dirt is piled higher than the hangar in side the fence.	\$ 0.00	0.0				
727	Other	Parking Lot	Work Complete	2020-09-30 14:37	Daniel Thomas Sr.	The America and Georgia flag poles need new hardware and ropes. The ropes are about to break and the top pulleys are not working right, making it very hard to lower or raise the flags.	\$ 0.00	0.0	2020-09-25 00:00	Daniel Thomas Sr.		
728	Door/Gate	Hangar	Work Complete	2020-10-04 21:44	Michele Renfroe	H20 - Travis w/ FWC called and stated that when closing the door on 10/04/20 one of the door straps broke. Pictures are attached.	\$ 0.00	6.0	2020-10-09 00:00	Jose Aviles		
732	Door/Gate	Terminal Building	Work Complete	2020-10-07 08:32	Richard Baran	This WR applies to the SIDA exit doors that were recently moved during construction from the area next to the first floor entrance to Admin(elevator vestibule) to the area beside TSA screening. This WR applies to the door on the left if you are outside the SIDA looking towards the flight line. That door will not fully close(engage the magnetic lock) if not forcefully pulled closed. The door-frame on top appears to be misaligned, which 'snags' the door approximately 1/2" before it would close and engage the magnetic lock.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles		
733	Door/Gate	Terminal Building	Work Complete	2020-10-07 08:33	Richard Baran	Westernmost front door(to right of Delta Airlines area sliding door) latch failing; door can be forced open even when locked.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.		
734	Door/Gate	Terminal Building	Work Complete	2020-10-07 08:33	Richard Baran	Main entrance sliding doors open very slowly, and occasionally stick open. When this happens the door needs to be closed manually and then electrically reset.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.		
737	Other	Terminal Building	Work Complete	2020-10-09 09:05	Jose Aviles	Enterprise car rental counter is experiencing water leaks when the airport is experiencing rainfall.	\$ 0.00	6.0	2020-10-09 00:00	Jose Aviles		
739	Door/Gate	Parking Lot	Work Complete	2020-10-12 13:22	Richard Baran	At 1545 on 10/11/20 "Peter"(refused to provide his last name over phone) called to report that he had not been given a receipt at the parking lot gate(station 4) when he paid. I informed him that he'd be able to contact Administration on Tuesday to obtain a receipt.	\$ 0.00	0.0	2020-10-30 00:00	Daniel Thomas Sr.		
740	Hazard	Hangar	In Progress	2020-10-13 15:37	Michele Renfroe	7C - Customer states that water comes in back of hangar when it rains really hard. Need to check for the angle iron on back side of interior wall.	\$ 0.00	0.0				
741	HVAC	Hangar	In Progress	2020-10-13 15:37	Michele Renfroe	6D - Customer states air-conditioner is not working in the office area.	\$ 0.00	0.0				
742	HVAC	Hangar	Work Complete	2020-10-13 15:38	Michele Renfroe	H57 - Heaters inside hangar does not work. Panels were taken down and never replaced or fixed. Picture is attached.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.		
743	Door/Gate	Hangar	Work Complete	2020-10-13 15:38	Michele Renfroe	H57 - Door seal on bottom of parking lot side of door not complete. Seal is hanging and screws are missing from panel. Pictures are attached.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles		
744	Door/Gate	Hangar	In Progress	2020-10-13 15:38	Michele Renfroe	H57-Ramp side door is rubbing on gas line running down side of building. Hazard and pictures are attached.	\$ 0.00	0.0				
745	Door/Gate	Hangar	In Progress	2020-10-13 15:39	Michele Renfroe	H57- Door gaps and seals need to be replaced on both sides ramp and parking lot side. Pictures are attached	\$ 0.00	0.0				
746	Door/Gate	Hangar	In Progress	2020-10-13 15:39	Michele Renfroe	H57- Rollers on all doors need to be greased and possibly adjusted to open smoother. Doors are hard to open and get stuck when trying to open. Pictures are attached	\$ 0.00	0.0				
747	Lighting	Hangar	Work Complete	2020-10-13 15:40	Michele Renfroe	H57- Light at end of hangar on ramp side of 57 was just hanging from where the new roof was put on and in the last big wind it blew off. Housing and light bulb needs to be replaced. Pictures attached.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.		

748	Facilities	Airside	Work Complete	2020-10-13 17:21	Daniel Thomas Sr.	The southside hangar outside restroom needs a french drain install to remove surface rainwater. Rainwater is flooding the septic tank area to the restroom.	\$ 0.00	0.0	2020-10-30 00:00	Daniel Thomas Sr.		
749	Hazard	Airside	In Progress	2020-10-13 17:39	Daniel Thomas Sr.	The diesel fueling tank by CRASH needs a new fueling hose and tank stickers	\$ 0.00	0.0				
750	Door/Gate	Terminal Building	Work Complete	2020-10-14 14:17	Daniel Thomas Sr.	2nd-floor delta holding area jet bridge is not locking. The door needs to be able to lock for security and safety reasons.	\$ 0.00	0.0	2020-10-14 00:00	Daniel Thomas Sr.		
752	HVAC	Terminal Building	Work Complete	2020-10-14 16:45	Daniel Thomas Sr.	The A/C is not working in Shaundra Office, Monica Office, and Daniel Office.	\$ 0.00	3.0	2020-10-15 00:00	Jose Aviles		
753	Lighting	Terminal Building	Work Complete	2020-10-14 16:52	Daniel Thomas Sr.	Good afternoon, here at the work counter at hertz we had our over head lights that have been flickering and hurting our eyes Christopher Winslow Branch manager Columbus metro airport O:7063242725	\$ 0.00	1.0	2020-10-15 00:00	Jose Aviles		
754	HVAC	Terminal Building	Work Complete	2020-10-15 16:23	Jose Aviles	2nd floor Delta holding area HVAC mechanical room air handler belt broke.	\$ 0.00	3.0	2020-10-15 00:00	Jose Aviles		
755	Lighting	Terminal Building	Work Complete	2020-10-15 16:26	Jose Aviles	2nd floor delta holding area's mechanical room interior lights is inoperable.	\$ 0.00	1.0	2020-10-15 00:00	Jose Aviles		
758	Lock	Hangar	In Progress	2020-10-21 17:56	Michele Renfroe	1B - Customer states that when the doors were worked on it has caused an issue with being able to lock the door. The latch does not line up with each other so it prevents him from locking his hangar doors. Picture attached.	\$ 0.00	0.0				
759	Wildlife	Hangar	Work Complete	2020-10-21 17:56	Michele Renfroe	H57 Office - Customer stated that he is still seeing presence of mice/rats in the office area at hangar 57.	\$ 0.00	0.0	2021-03-10 00:00	Daniel Thomas Sr.		
760	Wildlife	Hangar	In Progress	2020-10-21 17:57	Michele Renfroe	6E - Customer stated he saw fecal matter from pigeons but no birds present.	\$ 0.00	0.0				
761	Holes	Hangar	In Progress	2020-10-21 17:58	Michele Renfroe	7C - Angle iron is rusted at back wall of hangar allowing water to come into the hangar. Some parts are rusted out and needs to be replaced. Side walls also need to be caulked.	\$ 0.00	0.0				
762	Other	Terminal Building	Work Complete	2020-10-22 19:47	Monica Stone	In the women's bathroom, the toilet in the first stall is not flushing. The handle is not working.	\$ 0.00	0.0	2020-11-17 00:00	Daniel Thomas Sr.		
771	HVAC	Terminal Building	Work Complete	2020-10-23 14:17	Monica Stone	A/C on the 2nd floor (CSG) in HR, Badging, and Maintenance Manager offices is not cooling. It gets very hot in the offices.	\$ 0.00	2.0	2021-01-05 00:00	Jose Aviles		
772	Lighting	Terminal Building	Work Complete	2020-10-23 16:48	Daniel Thomas Sr.	FAA-On the 4th floor. The lights are out. the ceiling is high and you will need the 12' foot ladder to reach the lights.	\$ 0.00	0.0	2020-11-13 00:00	Daniel Thomas Sr.		
773	Lighting	Terminal Building	Work Complete	2020-10-23 16:51	Daniel Thomas Sr.	FAA-2nd floor men's restroom. The light is flickering	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.		
774	Lighting	Terminal Building	Work Complete	2020-10-23 16:53	Daniel Thomas Sr.	FAA-2nd floor men's locker room. The lights are out	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.		
775	Holes	Terminal Building	In Progress	2020-10-23 16:57	Daniel Thomas Sr.	FAA-2nd floor walls. There are a lot of small holes from hanging up pictures on the wall. Fill in the small holes in the walls with sheetrock mud and do a very small touch up paint.	\$ 0.00	0.0				
776	Facilities	Terminal Building	Work Complete	2020-10-23 17:01	Daniel Thomas Sr.	FAA-2nd floor kitchen. the bottom left side cabinet door is missing screws and about to fall off. check all cabinet doors in the kitchen for loose or missing screws.	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.		
777	Lighting	Terminal Building	Work Complete	2020-10-23 17:07	Daniel Thomas Sr.	FAA-5th floor stairwell to the CAP (ATCT Control Room). The lower steps (feet) lights are mostly out. It's getting hard to see where the stair-step are.	\$ 0.00	0.0	2020-11-13 00:00	Daniel Thomas Sr.		
780	HVAC	Terminal Building	Work Complete	2020-10-26 21:52	Shaundra Goodwin	AC is not working.	\$ 0.00	1.0	2020-10-30 00:00	Jose Aviles		

781	Plumbing	Terminal Building	Work Complete	2020-10-27 17:20	Sonya Overton	Toilet in the Women's Bathroom located in the Administrative office needs to be repaired. Not sure what the issue is but the lid of the tank is on the toilet and the stall is unusable.	\$ 0.00	0.0	2020-11-14 00:00	Daniel Thomas Sr.		
782	Lighting	Terminal Building	Work Complete	2020-10-27 17:20	Sonya Overton	The light is out in the elevator located behind TSA next to the escalator. Completely dark and needs to be replaced.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.		
783	Wildlife	Hangar	In Progress	2020-10-28 08:34	Michele Renfroe	12 - Customer called and stated that an owl had gotten in the hangar as well as pigeons. Pictures are attached.	\$ 0.00	0.0				
784	Roof	Hangar	In Progress	2020-10-28 08:35	Michele Renfroe	16A - Customer states that water is leaking from the roof as well as coming in under the door. Also states that the peg board is starting to fall off the wall due to moisture. Pictures are attached.	\$ 0.00	0.0				
785	Holes	Hangar	In Progress	2020-10-30 08:13	Michele Renfroe	16C - Holes in the ceiling all the way down one panel, on doors and water comes in on each side of hangar walls.	\$ 0.00	0.0				
786	Other	Hangar	In Progress	2020-10-30 08:14	Michele Renfroe	17A - Customer states when heavy rain water is leaking center back section of hangar at floor level. Picture attached	\$ 0.00	0.0				
787	Wildlife	Hangar	Work Complete	2020-10-30 15:29	Jose Aviles	Southwest hangar rat bait boxes need to be refilled.	\$ 0.00	2.0	2020-10-30 00:00	Jose Aviles		
788	Door/Gate	Hangar	In Progress	2020-10-31 07:39	Daniel Thomas Sr.	5-E. this is RDs hangar. The clamshell-style hangar door controller is not working correctly. you flip the switch on the direction of door travel and then you will have to hold in the electrical contactor to power up the door. If you don't let go of the contactor in enough time. you will break the door cables because the doorstop safety switches don't work. a Correct working clamshell-style hangar door just uses the switch only and without holding it to make it work or stop.	\$ 0.00	0.0				
790	Other	Hangar	In Progress	2020-11-03 14:28	Jose Aviles	1F- Hangar door slides off door tracks.	\$ 0.00	0.0				
791	Other	Hangar	In Progress	2020-11-03 14:31	Jose Aviles	1D- Far right hangar door jumps off track when heavy winds are occurring.	\$ 0.00	0.0				
792	Electrical	Hangar	In Progress	2020-11-03 14:35	Jose Aviles	2C- Hangar interior electrical needs to be removed and install new wire, conduit, outlets, light switches and interior lights.	\$ 0.00	0.0				
793	Other	Hangar	In Progress	2020-11-03 14:39	Jose Aviles	4D- Gutter needs to be adjusted and sealed in some areas	\$ 0.00	0.0				
794	Other	Hangar	In Progress	2020-11-03 14:40	Jose Aviles	4E- Gutter needs to be adjusted and sealed in some areas.	\$ 0.00	0.0				
795	Door/Gate	Terminal Building	Work Complete	2020-11-03 16:55	Ashley Jankiewicz	Check point Sliding doors to the entrance of checkpoint. The left side will not push open.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.		
796	Door/Gate	Hangar	In Progress	2020-11-04 05:03	Michele Renfroe	16H - Door seals need to be replaced	\$ 0.00	0.0				
797	Door/Gate	Hangar	In Progress	2020-11-04 05:04	Michele Renfroe	16G - Door seals need to be replaced	\$ 0.00	0.0				
798	Door/Gate	Hangar	In Progress	2020-11-04 05:04	Michele Renfroe	16F - Door seals need to be replaced	\$ 0.00	0.0				
799	Door/Gate	Hangar	In Progress	2020-11-04 05:05	Michele Renfroe	16E - Door seals need to be replaced	\$ 0.00	0.0				
800	Door/Gate	Hangar	In Progress	2020-11-04 05:05	Michele Renfroe	16D - Door seals need to be replaced	\$ 0.00	0.0				
801	Door/Gate	Hangar	In Progress	2020-11-04 05:06	Michele Renfroe	16C - Door seals need to be replaced	\$ 0.00	0.0				
802	Door/Gate	Hangar	In Progress	2020-11-04 05:06	Michele Renfroe	16B - Door seals need to be replaced	\$ 0.00	0.0				
803	Door/Gate	Hangar	In Progress	2020-11-04 05:07	Michele Renfroe	16A - Door seals need to be replaced	\$ 0.00	0.0				
804	Door/Gate	Hangar	In Progress	2020-11-04 05:07	Michele Renfroe	17J - Door seals need to be replaced	\$ 0.00	0.0				
805	Door/Gate	Hangar	In Progress	2020-11-04 05:08	Michele Renfroe	17I - Door seals need to be replaced	\$ 0.00	0.0				



840	Door/Gate	Hangar	In Progress	2020-11-04 06:51	Michele Renfroe	15F - Door seals need to be replaced	\$ 0.00	0.0			
841	Door/Gate	Hangar	In Progress	2020-11-04 06:51	Michele Renfroe	15E - Door seals need to be replaced	\$ 0.00	0.0			
842	Door/Gate	Hangar	In Progress	2020-11-04 06:52	Michele Renfroe	15D - Door seals need to be replaced	\$ 0.00	0.0			
843	Door/Gate	Hangar	In Progress	2020-11-04 06:52	Michele Renfroe	15C - Door seals need to be replaced	\$ 0.00	0.0			
844	Door/Gate	Hangar	In Progress	2020-11-04 06:52	Michele Renfroe	15B - Door seals need to be replaced	\$ 0.00	0.0			
845	Door/Gate	Hangar	In Progress	2020-11-04 06:53	Michele Renfroe	15A - Door seals need to be replaced	\$ 0.00	0.0			
846	Door/Gate	Hangar	In Progress	2020-11-04 06:53	Michele Renfroe	5F- Door seals need to be replaced	\$ 0.00	0.0			
847	Door/Gate	Hangar	In Progress	2020-11-04 06:53	Michele Renfroe	5E - Door seals need to be replaced	\$ 0.00	0.0			
848	Door/Gate	Hangar	In Progress	2020-11-04 06:53	Michele Renfroe	5D - Door seals need to be replaced	\$ 0.00	0.0			
849	Door/Gate	Hangar	In Progress	2020-11-04 06:54	Michele Renfroe	5C - Door seals need to be replaced	\$ 0.00	0.0			
850	Door/Gate	Hangar	In Progress	2020-11-04 06:54	Michele Renfroe	5B- Door seals need to be replaced	\$ 0.00	0.0			
851	Door/Gate	Hangar	In Progress	2020-11-04 06:54	Michele Renfroe	5A - Door seals need to be replaced	\$ 0.00	0.0			
852	Door/Gate	Hangar	In Progress	2020-11-04 06:54	Michele Renfroe	3C - Door seals need to be replaced	\$ 0.00	0.0			
853	Door/Gate	Hangar	In Progress	2020-11-04 06:55	Michele Renfroe	2C - Door seals need to be replaced under the front of the door to keep rain from blowing in under the doors	\$ 0.00	0.0			
854	Lighting	Terminal Building	Work Complete	2020-11-10 16:34	Daniel Thomas Sr.	FAA TOWER 5TH FLOOR BATHROOM LIGHT IS OUT.	\$ 0.00	0.0	2020-11-13 00:00	Daniel Thomas Sr.	
855	Hazard	Terminal Building	Work Complete	2020-11-10 16:36	Daniel Thomas Sr.	FAA TOWER 5TH FLOOR THE HANDRAIL THAT LEADS TO THE CAP, IS COMING OFF THE WALL	\$ 0.00	0.0	2020-11-13 00:00	Daniel Thomas Sr.	
856	Lighting	Terminal Building	Work Complete	2020-11-12 08:59	Daniel Thomas Sr.	FAA 3rd floor, there are no lights on	\$ 0.00	0.0	2020-12-29 00:00	Daniel Thomas Sr.	
857	Lighting	Terminal Building	Work Complete	2020-11-12 09:03	Daniel Thomas Sr.	FAA Egress Stairwell has light bulbs out. check the whole stairwell for out lights. Replace burned-out bulbs	\$ 0.00	0.0	2020-11-13 00:00	Daniel Thomas Sr.	
858	Wildlife	Terminal Building	Work Complete	2020-11-12 09:07	Daniel Thomas Sr.	FAA Tower CAB 5th floor. there is a lot of wasp flying around inside and outside of the tower CAB.	\$ 0.00	0.0	2020-12-29 00:00	Daniel Thomas Sr.	
859	Lighting	Terminal Building	Work Complete	2020-11-13 16:15	Daniel Thomas Sr.	FAA TOWER - as soon as you get off of the elevator. there are lights out in the ceiling.	\$ 0.00	0.0	2020-11-13 00:00	Daniel Thomas Sr.	
860	Other	Terminal Building	Work Complete	2020-11-14 12:08	Adrian Sellers	The sign (Ft.Benning Liaison) at the end of the east side of the terminal by the temporary LEO office needs to be taken down and trashed. It's old and no longer applies here. Can we get this done ASAP. Soldiers have been calling the number on the sig and asking for the liaison.	\$ 0.00	0.0	2021-01-28 00:00	Daniel Thomas Sr.	
862	Plumbing	Terminal Building	Work Complete	2020-11-17 09:17	Monica Stone	Troy - a toilet in the men's bathroom upstairs is not flushing. A Delta agent requested a plunger and a toilet repair.	\$ 0.00	0.0	2020-11-17 00:00	Daniel Thomas Sr.	
863	Door/Gate	Hangar	In Progress	2020-11-17 14:47	Michele Renfroe	H13 door tracks on both sides where doors open on and roll need to be welded and door stops need to be welded on the doors, weld stop needs to be added on FWC side where phone lines go from office to ground so doors can't be opened to far to clip the phone lines.	\$ 0.00	0.0			
864	Holes	Delta GA Ramp Area	Work Complete	2020-11-17 14:47	Michele Renfroe	Delta 1 and Delta 2 between by Fed Ex aircraft. Old tiedown holes in asphalt are getting deeper and could be possible hazard in future when pulling planes around that area.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.	
865	Other	Parking Lot	Work Complete	2020-11-17 19:18	Daniel Thomas Sr.	the American flag is ripped at the end and the Georgia flag is faded and ripped. Both flags need to be replaced.	\$ 84.32	0.0	2020-11-17 00:00	Daniel Thomas Sr.	
866	Lighting	Hangar	In Progress	2020-11-19 08:28	Marion Anderson	13 . Hangar 13 Light is out.	\$ 0.00	0.0			

867	Lighting	Hangar	In Progress	2020-11-19 08:29	Marion Anderson	18-G .The light above 18G is out.	\$ 0.00	0.0			
868	Lighting	Hangar	In Progress	2020-11-19 08:29	Marion Anderson	18-B .The light above 18-B is out.	\$ 0.00	0.0			
869	Lighting	Hangar	In Progress	2020-11-19 08:30	Marion Anderson	5-C .The light above 5C is out.	\$ 0.00	0.0			
870	Door/Gate	Hangar	In Progress	2020-11-19 12:45	Michele Renfroe	15B - Customer states that he is having issues with pigeon's accessing his hangar through the doors.	\$ 0.00	0.0			
871	Wildlife	Hangar	In Progress	2020-11-19 12:46	Michele Renfroe	15B - Customer states that he is having issues with rats building nest inside his aircraft. Thinks the trash at the ends of the hangars is keeping them around the building.	\$ 0.00	0.0			
872	Lighting	Parking Lot	Work Complete	2020-11-19 12:48	Michele Renfroe	Ga power light on Ernie Shelton Drive on the corner turning going towards Walmart by gate 10. The light on the pole is going out and flickering. The Pole number is 714076. ***GP fixed this problem	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.	
873	Lighting	Terminal Building	Work Complete	2020-11-23 15:16	Robert Blair	Replacement of bulbs needed in Avis Counter rental area	\$ 0.00	0.0	2021-01-27 00:00	Daniel Thomas Sr.	
879	Other	Hangar	In Progress	2020-12-04 14:10	Michele Renfroe	3C - Holes on left side of panel wall	\$ 0.00	0.0			
880	Door/Gate	Hangar	In Progress	2020-12-04 14:11	Michele Renfroe	3C - Door seals need to be replaced, worn.	\$ 0.00	0.0			
881	Lighting	Hangar	In Progress	2020-12-04 14:11	Michele Renfroe	3C - electrical fixtures need to be rewired. Has extra fixtures installed but are being ran by extension cords.	\$ 0.00	0.0			
884	Lighting	Terminal Building	Work Complete	2020-12-09 01:51	Monica Stone	Lights are out in the elevator. This elevator is in the TSA checkpoint area	\$ 0.00	0.0	2021-01-13 00:00	Daniel Thomas Sr.	
885	Door/Gate	Hangar	Work Complete	2020-12-09 01:51	Michele Renfroe	5A - Walk through door is sticking and hard to open/shut. FBO has key to open	\$ 0.00	0.0	2021-03-25 00:00	Daniel Thomas Sr.	
897	Facilities	Terminal Building	Work Complete	2020-12-18 20:19	Daniel Thomas Sr.	There is a strong sewer smell in the FAA 5th floor ATCT and the sink drains very slowly.	\$ 0.00	0.0	2020-12-10 00:00	Daniel Thomas Sr.	
898	Holes	Hangar	In Progress	2020-12-21 16:51	Michele Renfroe	16C - roof hole still present on panel to right when looking into the hangar from the ramp area.	\$ 0.00	0.0			
899	Wildlife	Hangar	Work Complete	2020-12-21 16:51	Michele Renfroe	15B - Customer sent photos of birds on tracks, pigeon matter on doors and floors, nest on tracks	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles	
900	Other	Hangar	Work Complete	2020-12-21 16:55	Michele Renfroe	16B - floors need to be cleaned and pressure washed to remove painted material coming up off the floor. Tenant moved out so complete cleaning needs to be done	\$ 0.00	0.0	2021-03-18 00:00	Daniel Thomas Sr.	
901	Other	Hangar	In Progress	2020-12-21 16:56	Michele Renfroe	16C - Walls need to be painted to cover the red and blue paint on walls and around where the walls meet the floor as well as by the light fixture.	\$ 0.00	0.0			
902	Hazard	Hangar	Work Complete	2020-12-21 20:14	Michele Renfroe	15C - clean floor and put temporary fix to doors for pigeon issue.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles	
903	Lighting	Hangar	Work Complete	2020-12-21 20:15	Michele Renfroe	H13 - ballast need to be changed in several of the lights in the office for Airventures in H13.	\$ 0.00	0.0	2021-03-26 00:00	Daniel Thomas Sr.	
904	Wildlife	Hangar	Work Complete	2020-12-21 20:15	Michele Renfroe	15F - hangar floor needs to be cleaned and temporary fix put in place to keep birds out until permanent fixture can be put in place.	\$ 0.00	0.0	2021-01-05 00:00	Jose Aviles	
905	Plumbing	Terminal Building	Work Complete	2020-12-21 20:27	Daniel Thomas Sr.	FAA - 2nd-floor male bathroom urinal keeps running after you flush it.	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.	
906	HVAC	Terminal Building	Work Complete	2020-12-21 20:42	Daniel Thomas Sr.	FAA - 5th-floor ATCT A/C and heat units. The roofers removed the HVAC off of the rooftop while reroofing the airport terminal building. The roofers placed the HVAC units back on the roof. They need to be hooked back up. 2-Temporary small units were placed in the ATCT area until the main units can come back online.	\$ 0.00	0.0	2020-12-29 00:00	Daniel Thomas Sr.	
907	Paint	Terminal Building	In Progress	2020-12-21 20:46	Daniel Thomas Sr.	FAA 5th floor ATCT (CAB) - the handrail (2) that leads up the stairs to the CAB needs to be sanded down and repainted with low odor paint.	\$ 0.00	0.0			

908	Facilities	Terminal Building	Work Complete	2020-12-21 20:51	Daniel Thomas Sr.	FAA 5th floor ATCT - There are ceiling tiles that are stained brown spots (water stains) and need to be replaced. these ceiling tiles are located as soon as you get off of the elevator on the 5th floor.	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.		
909	Lighting	Terminal Building	Work Complete	2020-12-21 20:59	Daniel Thomas Sr.	FAA 5th floor - there are dead bugs in the light cover lens as soon as you get off of the elevator on the 5th floor. clean the light lens.	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.		
910	Facilities	Terminal Building	In Progress	2020-12-21 21:02	Daniel Thomas Sr.	FAA 5th floor - patch/cover small holes in the wall and repaint (low odor paint) the walls in the areas.	\$ 0.00	0.0				
911	Facilities	Terminal Building	Work Complete	2020-12-21 21:18	Daniel Thomas Sr.	The main elevator and escalators state inspection needs to be done.	\$ 0.00	0.0	2021-02-19 00:00	Daniel Thomas Sr.		
912	Electrical	Terminal Building	Work Complete	2020-12-21 21:22	Daniel Thomas Sr.	The main stairs door exit sign is missing on the seconded floor and needs to be replaced.	\$ 0.00	0.0	2021-01-13 00:00	Daniel Thomas Sr.		
913	Lighting	Ramp	In Progress	2020-12-21 21:28	Daniel Thomas Sr.	The light poles (5-light poles x 3 lights per pole = 15 lights) next to the Airport Terminal has a lot of lights out and are old. They need to be converted over to LED. The back apron/ramp is dark right now with low light.	\$ 0.00	0.0				
914	FAA Mouser Light	Airside	Work Complete	2020-12-21 23:19	Daniel Thomas Sr.	FAA RWY 6 REIL light on I-185 - A vehicle lost control on a rainy day on the I-185 southbound side and ran off the road and hit the FAA REIL Light fence and part of the REIL Light Tower Frame. Reported this to ATCT.	\$ 0.00	0.0	2021-03-04 00:00	Daniel Thomas Sr.		
916	Door/Gate	Hangar	Work Complete	2020-12-22 18:00	Michele Renfroe	1C - Doors are pushed to wrong side. Need to unlock and put doors back on the correct side so they can open.	\$ 0.00	0.0	2020-12-23 00:00	Daniel Thomas Sr.		
917	Electrical	Crash Station	In Progress	2020-12-26 17:24	Richard Baran	Bay 2-South door(facing taxiway) electrical motor inoperative. Door must be raised/lowered by hand.	\$ 0.00	0.0				
918	Electrical	Crash Station	In Progress	2020-12-26 17:25	Richard Baran	3 of 11 overhead lights in apparatus bays inoperative.	\$ 0.00	0.0				
919	Electrical	Crash Station	In Progress	2020-12-26 17:26	Richard Baran	Station air-compressor remains inoperative. Compressor will not turn on.	\$ 0.00	0.0				
920	Lighting	Hangar	In Progress	2020-12-27 12:26	Daniel Thomas Sr.	5-C Hangar - The floodlight above hangar 5C that is supposed to illuminate the ramp between hangars 4 & 5 was completely inoperative last night (December 26th).	\$ 0.00	0.0				
921	Electrical	Hangar	Work Complete	2020-12-27 12:30	Daniel Thomas Sr.	4-D Hangar -The electrical outlet in hangar 4D does not work / does not seem to have power. All three circuit breakers in the outside panel on hangar 4 were closed, but all of those are relatively high amp breakers (60 A?) each. I assume there must be a sub-panel inside one of the hangars.	\$ 0.00	0.0	2021-03-09 00:00	Daniel Thomas Sr.		
923	Lighting	Perimeter Fence	Work Complete	2020-12-27 23:10	Daniel Thomas Sr.	Gate 6 light is out	\$ 0.00	0.0	2021-03-19 00:00	Daniel Thomas Sr.		
924	Lighting	Parking Lot	Work Complete	2020-12-27 23:14	Daniel Thomas Sr.	AVIS bay-1 for the rental car wash area light does not work for that bay	\$ 0.00	0.0	2021-03-17 00:00	Daniel Thomas Sr.		
925	Lighting	Parking Lot	Work Complete	2020-12-27 23:34	Daniel Thomas Sr.	The main airport sign light (one of two) is out.	\$ 0.00	0.0	2021-03-17 00:00	Daniel Thomas Sr.		
926	Lighting	Parking Lot	Work Complete	2020-12-28 00:51	Daniel Thomas Sr.	GEORGIA POWER POLE #17 IS FLASHING ON AND OFF.	\$ 0.00	0.0	2020-12-29 00:00	Daniel Thomas Sr.		
927	Lighting	Parking Lot	Work Complete	2020-12-28 00:59	Daniel Thomas Sr.	GP POLE # 20 HAS 1 OF 4 LIGHT HEADS OUT.	\$ 0.00	0.0	2020-12-29 00:00	Daniel Thomas Sr.		
928	Lighting	Parking Lot	Work Complete	2020-12-28 01:04	Daniel Thomas Sr.	GP LIGHT POLE # 23 HAS 1 OF ITS 4 LIGHT HEADS NOT WORKING	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.		
929	Lighting	Parking Lot	Work Complete	2020-12-28 01:10	Daniel Thomas Sr.	GP LIGHT POLE # 18 LIGHT IS OUT	\$ 0.00	0.0	2020-12-29 00:00	Daniel Thomas Sr.		
930	Lighting	Parking Lot	Work Complete	2020-12-28 01:16	Daniel Thomas Sr.	GP LIGHT POLE # W1090 AT THE CAR WASH AREA IS OUT	\$ 0.00	0.0	2020-12-29 00:00	Daniel Thomas Sr.		

931	Lighting	Parking Lot	Work Complete	2020-12-28 01:20	Daniel Thomas Sr.	GP LIGHT POLE # W1089 AT THE CAE WASH AREA IS OUT	\$ 0.00	0.0	2020-12-29 00:00	Daniel Thomas Sr.		
932	Lighting	Terminal Building	Work Complete	2020-12-28 14:23	Daniel Thomas Sr.	FAA Stairwell (all) has some lights out. replace burnt out light bulbs.	\$ 0.00	0.0	2020-12-29 00:00	Daniel Thomas Sr.		
933	Facilities	Terminal Building	Work Complete	2020-12-29 11:09	Daniel Thomas Sr.	FAA 3rd floor. The central vacuum is disassembled and not working.	\$ 0.00	0.0	2021-04-02 00:00	Daniel Thomas Sr.		
936	Lighting	Terminal Building	Work Complete	2020-12-29 20:44	Daniel Thomas Sr.	The main Elevator has 4 of the 6 lights out.	\$ 0.00	0.0	2020-12-29 00:00	Daniel Thomas Sr.		
937	Lighting Vault	Airside	Work Complete	2020-12-29 20:49	Daniel Thomas Sr.	The light vault UPS - CPU is not working. The ATCT does not have control of the airfield lights.	\$ 0.00	0.0	2020-12-30 00:00	Daniel Thomas Sr.		
938	Door/Gate	Crash Station	In Progress	2020-12-31 08:23	Andre Parker	Bay 3 door will not open. It appears that the clutch will not engage the door opening.	\$ 0.00	0.0				
939	Hazard	Hangar	Work Complete	2020-12-31 15:11	Daniel Thomas Sr.	Hangar 57 aircraft hanger bay needs emergency heat. the two ceiling-mounted heaters are not working and Holboork heating and a/c Co. are waiting for parts to come in to fix the two heaters. 12/23/2020	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.		
940	Other	Hangar	Work Complete	2020-12-31 15:59	Daniel Thomas Sr.	Hangar 57 does not have any working smoke or co alarm detectors in the office or bay areas,	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.		
941	Facilities	Terminal Building	In Progress	2020-12-31 18:29	Daniel Thomas Sr.	FAA 2nd floor - The thumb knob for the water fountain in the hallway by the Janitor room #250 broke off. needs to be replaced	\$ 0.00	0.0				
942	Lighting	Terminal Building	Work Complete	2020-12-31 18:34	Daniel Thomas Sr.	FAA 2nd floor - the light by the main desk by the FAA electric room #231 is out.	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.		
943	Lighting	Terminal Building	Work Complete	2020-12-31 18:44	Daniel Thomas Sr.	FAA 2nd floor - Replaced center light bulbs in The Ready Room #254. The light bulbs have turned yellow, dim, and about to go out - Daniel Thomas Sr	\$ 0.00	0.0	2020-12-31 00:00	Daniel Thomas Sr.		
944	Other	Hangar	In Progress	2021-01-04 17:49	Ann Prowell/FedEx	Active termites in hanger office need pest control assistance.	\$ 0.00	0.0				
945	Plumbing	Terminal Building	Work Complete	2021-01-05 08:19	Daniel Thomas Sr.	Both toilets in the men's restroom on the 2nd floor Delta holding areas are backed up and out of order	\$ 0.00	0.0	2021-03-18 00:00	Daniel Thomas Sr.		
946	Roof	Hangar	In Progress	2021-01-05 11:55	Michele Renfroe	15C - Customer stated that roof is leaking and has gotten worse over the aircraft.	\$ 0.00	0.0				
947	Door/Gate	Hangar	Work Complete	2021-01-05 11:56	Michele Renfroe	7A All three doors are stuck open, as well as hard to open 1st door all the time.	\$ 0.00	0.0	2021-01-05 00:00	Daniel Thomas Sr.		
948	Door/Gate	Hangar	In Progress	2021-01-05 11:56	Michele Renfroe	7A Hangar doors need to be greased and adjusted so all 3 doors will be easier to open	\$ 0.00	0.0				
949	Holes	Hangar	In Progress	2021-01-05 12:18	Michele Renfroe	17A - Customers sent photos which shows leaks in the hangar. Leaking at the floor level around the backside of the hangar wall, Leaking under the doors when the rain blows, Hole over airplane in roof area causing leaks, All files are attached that customer sent to me on 01/01/21.	\$ 0.00	0.0				
950	Other	Terminal Building	Work Complete	2021-01-08 11:46	Sonya Overton	Need assistance with desk. The desk needs to move to access the tangled cords behind it. The printer is unplugged, the wires are tangled and the power cord is now stuck behind the desk.	\$ 0.00	0.0	2021-01-08 00:00	Daniel Thomas Sr.		
952	Hazard	Parking Lot	Work Complete	2021-01-10 13:56	Daniel Thomas Sr.	The main fire sprinkler/fireplug water line going to the Airport Building cracked/broke in the rental car's new parking lot area. 1000s of gallons of water is flowing out into the parking lot.	\$ 0.00	0.0	2021-01-15 00:00	Daniel Thomas Sr.		
953	Plumbing	Foxtrot GA Ramp Area	Work Complete	2021-01-12 19:35	Travis Hope	Toilet within the outside restroom on foxtrot side of airfield across from H20 is currently stopped up and unable to flush.	\$ 0.00	0.0	2021-02-03 00:00	Daniel Thomas Sr.		
954	Lighting	Hangar	Work Complete	2021-01-13 14:21	Michele Renfroe	6E - Hangar light is out. Also please check right hand side of wall. it looks light it is coming down causing a gap entrance from the other bays in the hangar.	\$ 0.00	0.0	2021-03-23 00:00	Daniel Thomas Sr.		



956	Facilities	Terminal Building	Work Complete	2021-01-14 18:49	Daniel Thomas Sr.	With COVID-19 still very active. The main admin door is locked to keep the admin staff safe and healthy. The admin door needs a doorbell so the admin staff can hear someone needing customer service at the main admin door.	\$ 0.00	0.0	2021-01-14 00:00	Daniel Thomas Sr.		
957	Facilities	Terminal Building	Work Complete	2021-01-14 18:58	Daniel Thomas Sr.	With COVID-19 still very active. The badging office is locked to keep the staff and people taking the AOA/SIDA badging testing safe and healthy. The badging office door needs a doorbell so the badging office staff can hear someone needing customer service at their main door.	\$ 0.00	0.0	2021-01-14 00:00	Daniel Thomas Sr.		
958	Door/Gate	Terminal Building	Work Complete	2021-01-14 19:02	Daniel Thomas Sr.	Amber Clark the Airport Director office door needs the doorstop replaced.	\$ 0.00	0.0	2021-01-15 00:00	Daniel Thomas Sr.		
960	Lighting	Hangar	In Progress	2021-01-21 13:53	Michele Renfroe	3F - light needs to be replaced it is super dim and hard to put away aircraft at night	\$ 0.00	0.0				
962	Lighting	Hangar	Work Complete	2021-01-22 14:37	Michele Renfroe	H11 Bay 1 - Customer called and stated the lights are out in his hangar as well as the door being off track.	\$ 0.00	3.0	2021-01-29 00:00	Jose Aviles		
964	Lighting	Terminal Building	Work Complete	2021-01-26 11:20	Daniel Thomas Sr.	FAA 2nd floor room # 33 (FAA stairwell), all the lights in this area are out.	\$ 0.00	0.0	2021-01-26 00:00	Daniel Thomas Sr.		
965	HVAC	Terminal Building	Work Complete	2021-01-26 16:22	Shaundra Goodwin	AC in Monica's office, Shaundra Office is completely out, it's showing that it's on but appears to be blowing hot air. It is currently 77 degrees in these offices and Monica doesn't have a fan so it feels about 8 degrees in her office.	\$ 0.00	0.0	2021-02-19 00:00	Daniel Thomas Sr.		
966	Other	Terminal Building	Work Complete	2021-01-26 16:23	Adrian Sellers	These items pictured need to be removed from the terminal, they are starting construction on the east side of the terminal next week. TV's need to be taken down. I put in a work order months ago to have the sign as well as the tv's taken down. Now time is critical. These items have to be removed asap... TV's, Large freezer, displays, vending machines.	\$ 0.00	0.0	2021-01-28 00:00	Daniel Thomas Sr.		
967	Other	Terminal Building	Work Complete	2021-02-01 11:01	Adrian Sellers	In the A1 hold area, the chairs need to be shifted back and RAM board needs to be put on the floor to protect the carpet because the area will be high traffic when it is temporarily turned into DELTA baggage claim area. Please let me know if you need anything from me.	\$ 0.00	0.0	2021-02-03 00:00	Daniel Thomas Sr.		
968	Door/Gate	Hangar	In Progress	2021-02-02 17:07	Michele Renfroe	7A - Customer states the 1st door is still having issues opening seems to be hanging up maybe on the 2nd door.	\$ 0.00	0.0				
969	Lock	Hangar	Work Complete	2021-02-02 17:07	Michele Renfroe	5H - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-03-19 00:00	Daniel Thomas Sr.		
970	Lock	Hangar	Work Complete	2021-02-02 17:08	Michele Renfroe	5G - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-04-08 00:00	Daniel Thomas Sr.		
971	Lock	Hangar	Work Complete	2021-02-02 17:08	Michele Renfroe	5F - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-03-25 00:00	Daniel Thomas Sr.		
972	Lock	Hangar	Work Complete	2021-02-02 17:09	Michele Renfroe	5E - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-03-24 00:00	Daniel Thomas Sr.		
973	Lock	Hangar	Work Complete	2021-02-02 17:09	Michele Renfroe	5D - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-03-19 00:00	Daniel Thomas Sr.		
974	Lock	Hangar	Work Complete	2021-02-02 17:10	Michele Renfroe	5C - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-03-19 00:00	Daniel Thomas Sr.		
975	Lock	Hangar	Work Complete	2021-02-02 17:10	Michele Renfroe	5B - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-03-18 00:00	Daniel Thomas Sr.		
976	Lock	Hangar	Work Complete	2021-02-02 17:11	Michele Renfroe	5A - door handle needs to be replaced with outdoor handle also door is sticking and hard to open	\$ 0.00	0.0	2021-03-18 00:00	Daniel Thomas Sr.		
977	Holes	Parking Lot	Work Complete	2021-02-02 17:12	Michele Renfroe	Flightways Parking lot coming into parking lot there is a hole in the asphalt starting in between 3 & 4 but in the driveway of flightways.	\$ 0.00	0.0	2021-04-02 00:00	Daniel Thomas Sr.		

978	Door/Gate	Hangar	Work Complete	2021-02-02 17:13	Michele Renfroe	5A - Having issues with the door handle not catching and you have to slam the door to make it close on the walk through door.	\$ 0.00	0.0	2021-03-23 00:00	Daniel Thomas Sr.		
979	HVAC	Terminal Building	Work Complete	2021-02-02 17:34	Daniel Thomas Sr.	FAA 2nd floor has no heat /Ac. This unit is not working and needs to be replaced. It sits on the rooftop and it's the YORK unit.	\$ 0.00	0.0	2021-05-14 14:23	Daniel Thomas Sr.		
980	Other	Terminal Building	Work Complete	2021-02-02 17:44	Daniel Thomas Sr.	check out the main airport terminal building generator (PM service) and put diesel fuel in the fuel tank. crank the generator and allow it to run for ten minutes so the batteries can charge up.	\$ 0.00	0.0	2021-02-02 00:00	Daniel Thomas Sr.		
981	Plumbing	Crash Station	Work Complete	2021-02-03 09:43	Richard Baran	Hand nozzle in kitchen sink needs to be replaced. Nozzle sprays water from handle whenever sink water is turned on.	\$ 0.00	0.0	2021-02-19 00:00	Daniel Thomas Sr.		
983	Door/Gate	Terminal Building	Work Complete	2021-02-04 19:30	Adrian Sellers	Two of the main entrances sliding doors are down. I have put signage up temporarily until we can get them back online and people will use the side doors to enter the terminal.	\$ 0.00	0.0	2021-02-04 00:00	Daniel Thomas Sr.		
984	Lighting Vault	Airside	Work Complete	2021-02-04 19:47	Daniel Thomas Sr.	The lighting vault touch screen computer system has failed and needs to be replaced	\$ 0.00	0.0	2021-02-09 00:00	Daniel Thomas Sr.		
985	Other	Terminal Building	Work Complete	2021-02-08 17:36	Adrian Sellers	Ram Board should needs to be laid in front of the vending machines in the A1 hold room area by the restrooms.	\$ 0.00	0.0	2021-02-08 00:00	Daniel Thomas Sr.		
986	Other	Terminal Building	Work Complete	2021-02-08 17:36	Adrian Sellers	After accessing the main entrance vestibule, you and I decided that ram board may be the best option to lay down on the floor to mitigate the trip hazard.	\$ 0.00	0.0	2021-02-08 00:00	Daniel Thomas Sr.		
987	Electrical	Crash Station	Work Complete	2021-02-08 17:37	Richard Baran	Water Heater inoperative. LCD panel on unit says "Blower Motor".	\$ 0.00	0.0	2021-02-11 00:00	Daniel Thomas Sr.		
988	Paved Areas - Ponding/edge dams	Airport	In Progress	2021-02-09 21:02	Eric Rivers	Ponding on RW 24 at RW 13	\$ 0.00	0.0				
990	Other	Hangar	Work Complete	2021-02-12 12:27	Michele Renfroe	171 - Customer has moved out of hangar and needs to be checked for lighting and cleaning. Combo is 2586	\$ 0.00	0.0	2021-02-17 00:00	Daniel Thomas Sr.		
991	Facilities	Terminal Building	Work Complete	2021-02-17 17:22	Daniel Thomas Sr.	The Ram Board that was placed down to protect the carpet in the new holding area has been ripped up and is now a tripping hazard. Replace the old ram board with the new ram board.	\$ 0.00	0.0	2021-02-17 00:00	Daniel Thomas Sr.		
995	Plumbing	Terminal Building	Work Complete	2021-02-17 18:09	Anthony Pugh	First stall toilet in the admin female bathrooms has low water level	\$ 0.00	0.0	2021-03-18 00:00	Daniel Thomas Sr.		
996	Plumbing	Terminal Building	Work Complete	2021-02-17 18:10	Anthony Pugh	First stall toilet in the admin female bathrooms has low water level	\$ 0.00	0.0	2021-02-17 00:00	Daniel Thomas Sr.		
997	Plumbing	Terminal Building	Work Complete	2021-02-17 18:11	Anthony Pugh	The first urinal in the downstairs new male bathroom continuously flushing/running	\$ 0.00	0.0	2021-02-22 00:00	Daniel Thomas Sr.		
998	Facilities	Terminal Building	Work Complete	2021-02-17 18:13	Ashley Jankiewicz	TSA office - Hang boards/signs in offices.	\$ 0.00	0.0	2021-03-24 00:00	Daniel Thomas Sr.		
999	Other	Terminal Building	Work Complete	2021-02-18 15:46	Daniel Thomas Sr.	Move the old chairs in the old Delta 2nd floor holding area to hangar 12 (Greg Russell 706-527-0962 ) on Friday, Feb 19, 2021, at 8:30 am.	\$ 0.00	0.0	2021-02-19 00:00	Daniel Thomas Sr.		
1000	Plumbing	Crash Station	Work Complete	2021-02-18 15:52	Daniel Thomas Sr.	The water circulating pump by the hot water heater quit working.	\$ 0.00	0.0	2021-02-19 00:00	Daniel Thomas Sr.		
1001	Electrical	Crash Station	Work Complete	2021-02-18 15:59	Daniel Thomas Sr.	CRASH-The outside building generator is not coming on when the CRASH station loses power.	\$ 0.00	0.0	2021-02-24 00:00	Daniel Thomas Sr.		
1004	Door/Gate	Parking Lot	Work Complete	2021-02-19 09:02	connie perry	short term parking entry gate is showing error and not opening letting anyone park in short term parking	\$ 0.00	0.0	2021-02-19 00:00	Daniel Thomas Sr.		
1005	Other	Parking Lot	Work Complete	2021-02-19 09:40	Daniel Thomas Sr.	The directional sign (Deliveries, Flightways, Flight School) at the corner of Earnie Shelton and near the rental car wash area. The sign has been hit and now leaning over.	\$ 0.00	0.0	2021-02-23 00:00	Daniel Thomas Sr.		

1006	HVAC	Hangar	Work Complete	2021-02-19 17:00	Daniel Thomas Sr.	HG-57 The two hangar bay heaters need to be replaced. This issue has been ongoing in trying to repair these heaters.	\$ 0.00	0.0	2021-02-19 00:00	Daniel Thomas Sr.		
1007	Markings	Airside	Work Complete	2021-02-20 17:09	Daniel Thomas Sr.	Paint Non-Movement / Movement lines at Delta-1 and The GA Apron	\$ 0.00	0.0	2020-11-20 00:00	Daniel Thomas Sr.		
1008	Markings	Airside	Work Complete	2021-02-20 17:16	Daniel Thomas Sr.	Paint Non-Movement / Movement lines at Delta-2 and GA Apron	\$ 0.00	0.0	2020-11-20 00:00	Daniel Thomas Sr.		
1009	Markings	Airside	Work Complete	2021-02-20 17:23	Daniel Thomas Sr.	Paint Non-Movement / Movement lines at Foxtrot-1 and GA Apron	\$ 0.00	0.0	2020-11-20 00:00	Daniel Thomas Sr.		
1010	Markings	Airside	In Progress	2021-02-20 17:30	Daniel Thomas Sr.	Paint Non-Movement / Movement lines at Delta-3 and GA Apron	\$ 0.00	0.0				
1011	Markings	Airside	In Progress	2021-02-20 17:34	Daniel Thomas Sr.	Paint Non-Movement / Movement lines at Delta-4 and GA Apron	\$ 0.00	0.0				
1012	Markings	Airside	In Progress	2021-02-20 17:37	Daniel Thomas Sr.	Paint Non-Movement / Movement lines at Foxtrot-3 and GA Apron	\$ 0.00	0.0				
1013	Markings	Airside	In Progress	2021-02-20 17:42	Daniel Thomas Sr.	Paint Non-Movement / Movement lines at TWY Alfa and the Commercial Ramp	\$ 0.00	0.0				
1014	Markings	Airside	In Progress	2021-02-20 17:46	Daniel Thomas Sr.	Paint Non-Movement / Movement lines at TWY C-4 and the Commercial Ramp	\$ 0.00	0.0				
1015	Markings	Airside	In Progress	2021-02-20 17:49	Daniel Thomas Sr.	Paint Non-Movement / Movement lines at TWY C-7 and the Commercial Ramp	\$ 0.00	0.0				
1016	Lighting Vault	Airside	Work Complete	2021-02-20 17:54	Daniel Thomas Sr.	Taxiway Alfa and Ramp constant current regulator does not work in high step after a bad lighting storm on 02/15/2021.	\$ 0.00	0.0	2021-05-16 13:58	Daniel Thomas Sr.		
1017	Rotating Beacon Light	Airside	Work Complete	2021-02-20 18:09	Daniel Thomas Sr.	The Rotating Beacon Light is out. NOTAM CSG 02/009 OPENED ON 2/15/2021 AT 2207 ZULU AND CLOSES ON 3/31/2021 AT 2200 ZULU	\$ 0.00	0.0	2021-02-24 00:00	Daniel Thomas Sr.		
1018	Other	Terminal Building	Work Complete	2021-02-22 13:04	Daniel Thomas Sr.	The Ram Board that is protecting the carpet from damage has holes in it and is becoming a tripping hazard. this is where the new bathroom area is that Delta is using to offload passenger's bags.	\$ 0.00	0.0	2021-02-23 00:00	Daniel Thomas Sr.		
1022	Wildlife	Airside	In Progress	2021-02-23 08:23	Daniel Thomas Sr.	15-B hangar, birds are still getting in. recheck door seals and block off all access inside of this hangar where birds are getting into the hangar.	\$ 0.00	0.0				
1023	Door/Gate	Hangar	Work Complete	2021-02-25 16:42	Ernie Kelly	Hangar 11, Bay 3 doors hang up when opening. The middle door drags the ground and makes it difficult if not impossible to continue opening or closing the doors if only one person is trying to move the doors. It is so difficult, one of the members of River City Aero Club (Richard Foucher) injured himself trying to open the doors on 2/20/21.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.		
1024	Door/Gate	Hangar	In Progress	2021-02-25 16:43	Michele Renfroe	1E - Door needs to be rewelded and sheet metal fixed where the storm blew it off the track and bent the frame. MX has worked on this door already several times but not completed. Customer is asking how much longer it will be before they can return to their hangar.	\$ 0.00	0.0				
1025	Roof	Hangar	In Progress	2021-02-25 16:45	Michele Renfroe	8D - Vacate hangar needs to have roof leak located and repaired. Leak is on left side of hangar at the T portion of the beam.	\$ 0.00	0.0				
1026	FOD	Foxtrot GA Ramp Area	Work Complete	2021-02-25 16:50	Michele Renfroe	21H - Customer called and stated there is a lot of loose gravel starting at the hangar going out over the pavement to the grass area of hangar 21 taxiway side. Ask if we could run the sweeper truck over to pick up loose items.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.		

1027	Mowing	Landscaping	Work Complete	2021-02-25 16:58	Michele Renfroe	Fuel farm grass needs to be cut outside fence and possible weeding inside of fence area.	\$ 0.00	0.0	2021-02-26 00:00	Daniel Thomas Sr.		
1030	Other	Terminal Building	Work Complete	2021-03-01 10:06	connie perry	Rats running in ceiling above Delta New back room. Delta Agents hear them running and making nose above in the ceiling	\$ 0.00	0.0	2021-03-10 00:00	Daniel Thomas Sr.		
1031	Electrical	Hangar	Work Complete	2021-03-01 10:07	Amber Clark	16G needs new light line tech could not see to put the aircraft away	\$ 0.00	0.0	2021-03-02 00:00	Daniel Thomas Sr.		
1032	Electrical	Hangar	Work Complete	2021-03-02 17:34	Darryl Graham	Hangar 13 wall outlet in need of repair.	\$ 0.00	0.0	2021-03-17 00:00	Daniel Thomas Sr.		
1033	Other	Hangar	Work Complete	2021-03-02 17:34	Michele Renfroe	6E - right hand side of wall is open to hangar, please check wall and nail back up if needed.	\$ 0.00	0.0	2021-03-04 00:00	Daniel Thomas Sr.		
1034	Electrical	Hangar	Work Complete	2021-03-02 17:35	Michele Renfroe	6 - Entire hangar is out of power	\$ 0.00	0.0	2021-03-04 00:00	Daniel Thomas Sr.		
1035	Electrical	Hangar	Work Complete	2021-03-02 17:35	Michele Renfroe	7 - Entire hangar is out of power.	\$ 0.00	0.0	2021-03-03 00:00	Daniel Thomas Sr.		
1036	Other	Terminal Building	Work Complete	2021-03-02 17:36	Adrian Sellers	On the 2nd floor gate counter, we need everything that belongs to the airport moved into storage or to sonya's office if it's electronics .	\$ 0.00	0.0	2021-03-04 00:00	Daniel Thomas Sr.		
1037	Door/Gate	Perimeter Fence	Work Complete	2021-03-02 17:47	Daniel Thomas Sr.	Gate 6 has no power going to it.	\$ 0.00	0.0	2021-03-03 00:00	Daniel Thomas Sr.		
1041	Electrical	Terminal Building	Work Complete	2021-03-04 09:21	Bernadette	Pay parking computer system needs a plug-in battery back-up to keep it from going of line on a power outage. The secure room by the terminal main door needs to be unlocked for entrance purposes.	\$ 0.00	0.0	2021-03-04 00:00	Daniel Thomas Sr.		
1042	Other	Terminal Building	Work Complete	2021-03-04 09:23	Sonya Overton	All wallpaper needs to be removed in the Public Safety, Human Resources & Maintenance Manager office area on the second floor admin offices.	\$ 0.00	0.0	2021-03-17 00:00	Daniel Thomas Sr.		
1043	Facilities	Terminal Building	Work Complete	2021-03-04 09:24	Connie Perry	A water leak in the new ceiling in the Delta operation room. Contact the Delta employee, Connie for more information and to show you where this issue is.	\$ 0.00	0.0	2021-05-11 13:17	Daniel Thomas Sr.		
1044	Hazard	Terminal Building	Work Complete	2021-03-04 09:26	Connie Perry	Wires and cords by the delta ticket counter. The passenger tipped and almost fell. Contact the Delta employee, Connie for more information and to show you where this issue is.	\$ 0.00	0.0	2021-05-05 13:08	Daniel Thomas Sr.		
1045	Facilities	Terminal Building	In Progress	2021-03-04 09:27	Connie Perry	A water leak in the new ceiling over the toilet in the employee restroom. Contact the Delta employee, Connie for more information and to show you where this issue is.	\$ 0.00	0.0				
1046	Door/Gate	Hangar	In Progress	2021-03-04 13:04	Daniel Thomas Sr.	57-HG Landside door seals need to be trimmed up. they are now dragging the concrete making it hard to open the door.	\$ 0.00	0.0				
1048	Door/Gate	Hangar	In Progress	2021-03-05 13:19	Michele Renfroe	211 - Customer states doors are hard to open and close	\$ 0.00	0.0				
1049	Signs	Parking Lot	Work Complete	2021-03-05 15:35	Daniel Thomas Sr.	Signs Unlimited is coming on Fridays, March 5th to fix the Construction in Progress signs located at the Airport Thruway at Earnie Shelton Dr. Entrance (Across from Wal-Mart) and also to move the sign back at the main airport entrance.	\$ 0.00	0.0	2021-03-05 00:00	Daniel Thomas Sr.		
1050	Taxiway Light	Charlie-1 Safety Area	In Progress	2021-03-05 15:41	Daniel Thomas Sr.	At Charlie-1 Safety Area there is 1-Taxiway light that is out.	\$ 0.00	0.0				
1051	Taxiway Light	Charlie-2 Safety Area	In Progress	2021-03-05 15:43	Daniel Thomas Sr.	At Charlie-2 Safety Area there is 1-Taxiway light that is out.	\$ 0.00	0.0				
1052	Taxiway Light	Charlie-4 Safety Area	In Progress	2021-03-05 15:45	Daniel Thomas Sr.	At Charlie-4 Safety Area there is 1-Taxiway light that is out.	\$ 0.00	0.0				
1053	Taxiway Light	Airside	In Progress	2021-03-05 15:47	Daniel Thomas Sr.	At Foxrot-1 Safety Area there is 1- Taxiway light that is out.	\$ 0.00	0.0				

105 4	Taxiway Light	Airside	In Progress	2021-03-05 15:49	Daniel Thomas Sr.	At Foxtro-3 Safety Area there is 1- Taxiway light that is out.	\$ 0.00	0.0				
105 5	Taxiway Light	Airside	In Progress	2021-03-05 15:52	Daniel Thomas Sr.	At Delta-4 Safety Area there is 2-LED Taxiway light that is out.	\$ 0.00	0.0				
105 6	Taxiway Light	Airside	In Progress	2021-03-05 15:53	Daniel Thomas Sr.	At Delta-3 Safety Area there is 1-LED Taxiway light that is out.	\$ 0.00	0.0				
105 7	Taxiway Light	Airside	In Progress	2021-03-05 15:58	Daniel Thomas Sr.	At RWY13 RSA, There is 1-LED taxiway light that is out.	\$ 0.00	0.0				
106 3	Hazard	Delta GA Ramp Area	In Progress	2021-03-09 18:28	Amber Clark	Drainage Grate is broken on ramp in prime aircraft traffic area. Area barricaded however, this issue has existed for over a year. This issue poses a safety risk even with barricades and also does not provide the best service for our FBO customers having to try to avoid each da.	\$ 0.00	0.0				
106 4	Paint	Parking Lot	In Progress	2021-03-09 18:29	R. Baran	During this shift I observed 6 different vehicles travelling in the wrong direction on the one-way portions of the terminal roads. Suggest lanes be painted with one-way arrows and one-way/do not enter signs be placed in order to assist patrons who are unfamiliar with the terminal traffic-flow. D. Thomas observed some of these vehicles at the same time and suggested I initiate this request.	\$ 0.00	0.0				
106 5	Other	Terminal Building	Work Complete	2021-03-10 17:26	Daniel Thomas Sr.	Both elevator emergency phones are very old and don't work correctly.	\$ 0.00	0.0	2021-03-10 00:00	Daniel Thomas Sr.		
106 6	Door/Gate	Hangar	Work Complete	2021-03-10 17:31	Daniel Thomas Sr.	HG- 57. The airside small hanger door is not shutting correctly.	\$ 0.00	0.0	2021-03-16 00:00	Daniel Thomas Sr.		
106 7	Door/Gate	Hangar	Work Complete	2021-03-10 17:35	Daniel Thomas Sr.	HG-57. On the airfield side. The second hangar door track where the gap is. One part of the track is sticking up a little higher than the other part is. This makes the door hard to open.	\$ 0.00	0.0	2021-03-15 00:00	Daniel Thomas Sr.		
107 0	HVAC	Terminal Building	Work Complete	2021-03-16 08:50	Shaundra Goodwin	Hot in the office. AC not working	\$ 0.00	0.0	2021-03-16 00:00	Daniel Thomas Sr.		
107 1	Lighting	Hangar	Work Complete	2021-03-16 08:50	Michele Renfroe	4D - Customer states lights are not working in the hangar. Work order 117 was closed in December 2019 stating work was complete.	\$ 0.00	0.0	2021-03-12 00:00	Daniel Thomas Sr.		
107 2	Door/Gate	Hangar	In Progress	2021-03-16 08:51	Michele Renfroe	H13 - Tower side doors are not closing and doors are by passing each other. Customer on that side of hangar has mentioned the aircraft not being secured.	\$ 0.00	0.0				
107 3	Other	Terminal Building	Work Complete	2021-03-16 08:52	Adrian Sellers	The covers needs to come off all the chairs and they need to be plugged in a moved into place because they will began to be used this week. Move the old green chairs in front of the TSA checkpoint to Greg Russell hangar 12.	\$ 0.00	0.0	2021-03-17 00:00	Daniel Thomas Sr.		
107 4	Lighting Vault	Airside	Work Complete	2021-03-16 10:59	Daniel Thomas Sr.	The outside airfield lighting vault door light is out.	\$ 0.00	0.0	2021-03-16 00:00	Daniel Thomas Sr.		
107 5	Electrical	Hangar	In Progress	2021-03-16 12:22	Michele Renfroe	5E - Electrical panel needs to be worked on internally as well as replace face plate. door cut off switch.	\$ 0.00	0.0				
107 6	Other	Terminal Building	Work Complete	2021-03-17 14:43	Adrian Sellers	The paper and plastic needs to come up in this area(new hold area).	\$ 0.00	0.0	2021-03-18 00:00	Daniel Thomas Sr.		
107 7	Other	Terminal Building	Work Complete	2021-03-17 14:44	Adrian Sellers	Move the boxes of lettering that was taken down in the terminal behind a locked door to be used at a later time.	\$ 0.00	0.0	2021-03-17 00:00	Daniel Thomas Sr.		
107 8	Other	Terminal Building	Work Complete	2021-03-17 14:45	Adrian Sellers	Move the green chairs that are in the check point area. They will go to Greg Russell, coordinate with him to see if you can take them to his hangar.	\$ 0.00	0.0	2021-03-23 00:00	Daniel Thomas Sr.		

1080	Plumbing	Terminal Building	Work Complete	2021-03-17 17:44	Adrian Sellers	There is a leak in the main lobby check point area, after speaking with Ryan his team believes the leak is coming from the FAA restroom floor drain. They do not have any scope of work related to this restroom or pipe so he suggest CSG Maintenance investigate and confirm it is in fact a maintenance item as opposed to new construction item.	\$ 0.00	0.0	2021-04-02 00:00	Daniel Thomas Sr.		
1081	Other	Terminal Building	Work Complete	2021-03-18 08:46	Connie Perry	Water leaking in the new delta operation room were computers are.	\$ 0.00	0.0	2021-05-11 13:09	Daniel Thomas Sr.		
1082	Landscaping	Parking Lot	Work Complete	2021-03-18 08:51	Daniel Thomas Sr.	A large limb broke off a tree in the long-term parking lot from stormy weather. limb needs to be cut up and removed.	\$ 0.00	0.0	2021-03-18 00:00	Daniel Thomas Sr.		
1083	Other	Terminal Building	Work Complete	2021-03-18 10:02	Adrian Sellers	This hand sanitizer station needs to be removed and placed in another location for the public to use. This is right next to the old entrance of the elevator (now Isa area)	\$ 0.00	0.0	2021-03-18 00:00	Daniel Thomas Sr.		
1084	Door/Gate	Terminal Building	Work Complete	2021-03-18 10:20	Daniel Thomas Sr.	Move the Glass doors and the plexiglass wall from the maintenance dept./TSA hallway into the maintenance dept. tool/parts room. These items were removed and were scheduled for the trash from the TSA checkpoint area. We are retaining these items for future airport projects.	\$ 0.00	0.0	2021-03-18 00:00	Daniel Thomas Sr.		
1085	Other	Parking Lot	Work Complete	2021-03-19 17:34	Daniel Thomas Sr.	At the main airport sign by W. Britt David Rd. The two large lights casing are showing their age by the paint on the light housing fading and show large bare metal. Paint the light housing black again.	\$ 0.00	0.0	2021-03-19 00:00	Daniel Thomas Sr.		
1088	Plumbing	Terminal Building	Work Complete	2021-03-23 08:47	Amber Clark	Ladies restroom in Admin first stall chain broke in tank of toilet will not flush	\$ 0.00	0.0	2021-03-23 00:00	Daniel Thomas Sr.		
1089	Lock	Terminal Building	Work Complete	2021-03-23 08:49	R. Baran	One of the two double-doors leading from the escalator area into the secure TSA/Ops/Maintenance corridor(I believe this is door 8) is unlocked/unsecured/unalarmed. The door can be opened from the public area under the escalator by simply pushing on the door; when opened no alarm sounds. When standing under the escalator this is the door that does not have any signs on it.	\$ 0.00	0.0	2021-03-23 00:00	Daniel Thomas Sr.		
1090	Lock	Terminal Building	Work Complete	2021-03-23 08:51	R. Baran	The single interior door leading from exterior door-7 is not secured in any way. These doors are those used now by DGS personnel to return checked baggage to passengers. The interior door is located at the base of the escalators, and can be opened by simply pushing on the door. This provides access to door-7 and to the stairwell leading into the upstairs storage room.	\$ 0.00	0.0	2021-03-23 00:00	Daniel Thomas Sr.		
1092	Door/Gate	Hangar	Work Complete	2021-03-23 17:17	Daniel Thomas Sr.	HG-5- I (storage room) - door handle needs to be replaced with outdoor handle	\$ 0.00	0.0	2021-03-23 00:00	Daniel Thomas Sr.		
1094	Electrical	Terminal Building	Work Complete	2021-03-25 16:00	Daniel Thomas Sr.	FAA 2nd floor hallway light switches are not working. You are unable to turn the hallway lights on.	\$ 15.58	1.0	2021-03-25 00:00	Daniel Thomas Sr.		
1095	Door/Gate	Perimeter Fence	In Progress	2021-03-25 16:51	Daniel Thomas Sr.	Need to put Towing signs at each Gates.	\$ 0.00	0.0				
1096	Lighting	Airside	Work Complete	2021-03-29 17:12	Daniel Thomas Sr.	In front of the Airport Terminal parking lot. There are 14- sidewalk waist high light poles that need their light change out to newer LED 100 watt brighter light bulbs. A couple of lights have already burnt out. This will make the sidewalk area much brighter and cost less for power by using LED light bulbs. Pictures are attached	\$ 0.00	0.0	2021-04-02 00:00	Daniel Thomas Sr.		
1097	Electrical	Hangar	Work Complete	2021-04-01 09:21	Daniel Thomas Sr.	HG-13 Mr. Jack (hg2a 706-573-1423) called me and reported they had no power in the EAA part of hangar 13. Circuit breaker # 5 is bad and has to be replaced.	\$ 0.00	0.0	2021-03-31 00:00	Daniel Thomas Sr.		
1098	Wildlife	Hangar	Work Complete	2021-04-01 10:01	Daniel Thomas Sr.	Hg 11-2. Mr.Desport came to me (Daniel) a showed me this hangar bay and where there was a lot of bird mess and small feathers on the floor. He requested to have this cleaned up because the aircraft that belongs in this hangar was coming back and will be parked in this hangar again.	\$ 0.00	0.0	2021-04-01 00:00	Daniel Thomas Sr.		

1100	Plumbing	Terminal Building	Work Complete	2021-04-02 19:25	Daniel Thomas Sr.	FAA 2nd floor kitchen sink will not drain.	\$ 0.00	0.0	2021-04-02 00:00	Daniel Thomas Sr.		
1101	Plumbing	Terminal Building	Work Complete	2021-04-02 19:31	Daniel Thomas Sr.	FAA 2nd floor men's bathroom toilet has a small water leak.	\$ 0.00	0.0	2021-04-09 00:00	Daniel Thomas Sr.		
1102	Weedeating	Flightways	Work Complete	2021-04-02 19:35	Darryl Graham	Inside fence of Fuel Farm needs landscaping and weed control.	\$ 0.00	0.0	2021-04-08 00:00	Daniel Thomas Sr.		
1104	Door/Gate	Hangar	Work Complete	2021-04-05 11:13	Ernie Kelly	Rolling doors on Hangar 11, Bay 3, are hanging up and are difficult to open. The number 1 door (full travel, with lock and hasp) hangs up about halfway across. The metal frame hits the ground and rail and will stop the door if you are not moving very quickly. The number 2 door (middle section) will stop roughly one-third to one-half way between fully closed and fully open. Both doors hang up whether opening or closing. It's difficult for many of our members to open the doors alone. Impossible for some.	\$ 0.00	0.0	2021-04-06 00:00	Daniel Thomas Sr.		
1106	Other	Terminal Building	Work Complete	2021-04-06 19:23	Ashley Jankiewicz TSA	@ TSA. Hang bulletin boards, hang 2 TVs, secure lockers to the wall, hang coat rack Contact Ashley 706-936-1612 to schedule a time to get into office...Thanks!	\$ 0.00	0.0	2021-04-06 00:00	Daniel Thomas Sr.		
1107	Door/Gate	Hangar	Work Complete	2021-04-06 19:24	Michele Renfroe	5E - Add a Childproof cover to the inside handle of the door to keep from accidentally locking the handle. The hangar has a combo lock on the door to keep it secured.	\$ 0.00	0.0	2021-04-06 00:00	Daniel Thomas Sr.		
1108	Door/Gate	Hangar	Work Complete	2021-04-06 19:25	Michele Renfroe	5F - Add a Childproof cover to the inside handle of the door to keep from accidentally locking the handle. The hangar has a combo lock on the door to keep it secured.	\$ 0.00	0.0	2021-04-06 00:00	Daniel Thomas Sr.		
1109	Door/Gate	Hangar	In Progress	2021-04-06 19:25	Michele Renfroe	8D - Hangar door stop is completely gone. Please add angle iron to end of door track so door does not run off track when opening.	\$ 0.00	0.0				
1110	Door/Gate	Hangar	Work Complete	2021-04-06 19:26	Michele Renfroe	8F - Hangar door stop is completely gone. Please add angle iron to end of door track so door does not run off track when opening.	\$ 0.00	0.0	2021-04-08 00:00	Daniel Thomas Sr.		
1111	Door/Gate	Hangar	In Progress	2021-04-06 19:26	Michele Renfroe	7A - Metal on door I-beams need to be trimmed back to keep the door from rubbing and slowing down the door opening. 1st door still extremely hard to open.	\$ 0.00	0.0				
1112	Door/Gate	Hangar	In Progress	2021-04-07 09:51	Amber Clark	12-Need new seals on bottoms of doors large gap on opposite side of ramp, The ramp-side doors have a smaller gap. Wind and rain are blowing debris in hangar and causing standing water. needs seals along doors where gaps appear to prevent bird entry.	\$ 0.00	0.0				
1113	Other	Hangar	In Progress	2021-04-07 09:55	Amber Clark	12-Pin holes in side wall of hangars. Witnessed some on right side wall (if facing hangar from ramp) close to ramp-side doors. Please look at all walls to determine if there are any additional pin holes.	\$ 0.00	0.0				
1114	Lighting	Hangar	In Progress	2021-04-07 09:57	Amber Clark	12-Two lights in the middle of hangar closer to the ramp-side doors inop. The smaller light needs to be replaced with a light that matches the rest of the hangar lighting. The other light needs to be troubleshot to determine why it is out and needs to be fixed as necessary	\$ 0.00	0.0				
1115	Electrical	Hangar	In Progress	2021-04-07 10:00	Amber Clark	12-Lights go off in office after being turned on for a period of time. Do not believe the breaker is tripping. Could not confirm. Tenant believes there may be a short in wiring. May want to look at upgrading or adding electrical circuits, tenant stated that a fan plugged in the hangar will trip the breaker.	\$ 0.00	0.0				
1116	Door/Gate	Hangar	In Progress	2021-04-07 12:11	Amber Clark	12-Doors are sagging. Inflatable wheels may need to be replaced. also replace metal wheels, check tracks and concrete as well	\$ 0.00	0.0				
1117	Other	Hangar	In Progress	2021-04-07 12:13	Amber Clark	12-Tenant states water is seeping up from the ground in hangar. I recommend first completing door seals and roof leak repairs first to get a better idea of where the water is seeping in at.	\$ 0.00	0.0				

1118	Door/Gate	Hangar	In Progress	2021-04-07 12:17	Amber Clark	57-Hangar doors are very hard to open. Tenant recommends to replace wheels and wheel bearings. Wheel and bearings should be properly greased. Please take off a wheel from landside hangar door to determine correct size and type of bearings.	\$ 0.00	0.0			
1119	Lighting	Terminal Building	Work Complete	2021-04-08 18:20	Joseph Anthony Pugh	Half the lights aren't working in admin, however this might be due to construction.	\$ 0.00	0.0	2021-04-08 00:00	Daniel Thomas Sr.	
1120	Litter Pick-Up	Hangar	Work Complete	2021-04-08 18:21	Michele Renfroe	Please add trash cans to the ends of each hangar on the southwest side for hangar 16, 17, 18 and 21. Amber approved to either purchase or pull from other hangars it is your decision.	\$ 0.00	0.0	2021-04-09 00:00	Daniel Thomas Sr.	
1121	Other	Hangar	In Progress	2021-04-08 18:22	Amber Clark	12-Please put hangar 12 on a weekly cleaning schedule until the bird mitigation is completed on hangar.	\$ 0.00	0.0			
1122	Landscaping	Landscaping	Work Complete	2021-04-08 18:23	Amber Clark	Planters with plants will be installed today. Please put on a watering schedule with the Ground Department. Also note that water will eventually leak out the hole in the bottom and wet the curb in front of the terminal. Consider this when deciding on a time to water.	\$ 0.00	0.0	2021-04-28 19:09	Daniel Thomas Sr.	
1123	Door/Gate	Terminal Building	Work Complete	2021-04-08 19:23	Daniel Thomas Sr.	TSA needs to have a Door Peep Hole in the passenger's waiting area for safety and to let in pilots, officers, and high valued personal. Right now they are unable to see unless they open the door and exposing a sterile area and themselves to potential dangers. Chief has approved this Door Peep Hole to be installed at this door.	\$ 0.00	0.0	2021-04-09 00:00	Daniel Thomas Sr.	
1124	HVAC	Terminal Building	Work Complete	2021-04-09 19:13	Daniel Thomas Sr.	The 2nd floor old Delta holding area is hot.	\$ 0.00	0.0	2021-04-09 00:00	Daniel Thomas Sr.	
1125	Door/Gate	Hangar	Work Complete	2021-04-09 19:41	Daniel Thomas Sr.	8E - Hangar door stop is completely gone. Please add angle iron to the end of the door track so the door does not run off track when opening.	\$ 0.00	0.0	2021-04-09 00:00	Daniel Thomas Sr.	
1126	Paved Areas - Cracks/spalling/heaves	Airport	In Progress	2021-04-13 04:52	Eric Rivers	Grass growing in cracks of RW 24-6	\$ 0.00	0.0			
1127	Lighting	Terminal Building	Work Complete	2021-04-15 17:52	Daniel Thomas Sr.	FAA 2nd floor conference room. The lights are not coming on.	\$ 0.00	0.0	2021-04-15 00:00	Daniel Thomas Sr.	
1128	HVAC	Terminal Building	Work Complete	2021-04-15 17:58	Daniel Thomas Sr.	The 2nd floor AC unit in the old Delta holding area keeps going offline. The Maintenance Dept has to keep resetting the unit.	\$ 0.00	0.0	2021-04-28 18:44	Daniel Thomas Sr.	
1129	Door/Gate	Hangar	Work Complete	2021-04-15 17:58	Michele Renfroe	3A - Customer called and stated it looks like the door to his hangar has been hit in the past month he was not here. Stated that the locking latch looks to be bent back and screws are missing. Can you please take a look at both the door and latch.	\$ 0.00	0.0	2021-05-05 18:35	Daniel Thomas Sr.	
1131	HVAC	Flightways	Work Complete	2021-04-21 08:10	Michele Renfroe	Flightways Columbus air-conditioners need to be blown out for the drip pan and over flow with CO2.	\$ 0.00	0.0	2021-04-28 19:04	Daniel Thomas Sr.	
1132	Signs	Parking Lot	In Progress	2021-04-21 08:11	Adrian Sellers	RAC signs need to go up in the newly renovated RAC lot.	\$ 0.00	0.0			
1133	Holes	Hangar	In Progress	2021-04-23 12:12	Michael Henley	Hanger 18-A leaking roof. blue x taped on floor marks the spot. Water source is two holes in roof in hanger to the right, water runs down channel to my hanger.	\$ 0.00	0.0			
1142	Other	Terminal Building	In Progress	2021-04-27 14:39	connie perry	water leaking from ceiling in the new delta opps mainframe room when it rains	\$ 0.00	0.0			
1143	Other	Terminal Building	Work Complete	2021-04-27 14:42	connie perry	water leaking from the ceiling at the new delta ticket counter door	\$ 0.00	0.0	2021-05-11 13:03	Daniel Thomas Sr.	
1144	Wildlife	Hangar	In Progress	2021-04-27 14:45	Michele Renfroe	6E - Customer called and stated pigeons present and active in his hangar. They could be coming in from another hangar bay since the walls do not go all the way up in the hangar.	\$ 0.00	0.0			
1145	Other	Terminal Building	Work Complete	2021-04-30 16:40	Sonya Overton	Remove podium and flags from terminal and place back into the Layfield conference room	\$ 0.00	0.0	2021-04-30 16:46	Daniel Thomas Sr.	



114 6	HVAC	Terminal Building	Work Complete	2021-04-30 16:41	Shaundra and Monica	AC not working. It's hot in Shaundra and Monica.	\$ 0.00	0.0	2021-05-05 15:23	Daniel Thomas Sr.		
114 7	Other	Terminal Building	Work Complete	2021-04-30 16:42	Sonya Overton	Remove CVB box from the vestibule and place in trash. Per Airport Director. CVB no longer carries the posters and will not come to retrieve.	\$ 0.00	0.0	2021-05-03 14:06	Daniel Thomas Sr.		
114 8	Holes	Hangar	In Progress	2021-04-30 16:42	Michael Henley	Hanger 18-A leaking roof, blue x taped on floor marks the spot. Water source is two holes in roof in hanger to the right, water runs down channel to my hanger.	\$ 0.00	0.0				
114 9	Lighting - Damaged/missing	Airport	In Progress	2021-05-03 01:01	Richard Baran	Taxiway Light at F1 needs to be replaced. Pieces in Fire Station	\$ 0.00	0.0				
115 0	Wildlife	Hangar	In Progress	2021-05-05 13:28	Michele Renfroe	H13 - Netting needs to be completed in the rest of the hangar to keep out the birds. Birds have started roosting above the current netting.	\$ 0.00	0.0				
115 1	Wildlife	Hangar	In Progress	2021-05-05 13:29	Michele Renfroe	15B - Customer states that pigeons are still getting in through the small opening that is attached in the photo.	\$ 0.00	0.0				
115 2	Plumbing	Terminal Building	Work Complete	2021-05-05 13:30	Leann Seffrin	Leak in ceiling - TSA Office	\$ 0.00	0.0	2021-05-03 14:15	Daniel Thomas Sr.		
115 3	HVAC	Terminal Building	Work Complete	2021-05-05 13:32	Adrian Sellers	The conference room air, Monicas office, Daniels office, and Shaundra office is out and has been since yesterday 5/3/21	\$ 0.00	0.0	2021-05-04 13:58	Daniel Thomas Sr.		
115 4	Plumbing	Flightways	In Progress	2021-05-05 13:33	Michele Renfroe	Flightways men's restroom toilet is not flushing with force. Handle might need to be adjusted as well as in the ladies restroom	\$ 0.00	0.0				
115 5	Door/Gate	Hangar	In Progress	2021-05-05 13:33	Michele Renfroe	5D - Flightways employee stated that the guide wire on the scissor door is off the roller and might need adjusting.	\$ 0.00	0.0				
115 6	Door/Gate	Hangar	In Progress	2021-05-05 13:34	Michele Renfroe	5A - Striker plate has fallen off new door handle. needs to be screwed back on to the door jam	\$ 0.00	0.0				
115 7	Pavements	Landscaping	In Progress	2021-05-15 12:18	Amber Clark	Please pressure wash all concrete curbs around front terminal loop, all concrete islands (parking arms/ticket machine), all sidewalks (including taxi stand area), smoking patio, etc. All front entrance concrete should be pressure washed to reflect clean appearance of terminal. Would like complete by August 1st 2021	\$ 0.00	0.0				
115 8	Plumbing	Terminal Building	Work Complete	2021-05-15 12:23	Leann Seffrin	Leak in front of TSA checkpoint	\$ 0.00	0.0	2021-05-18 12:11	Daniel Thomas Sr.		
115 9	Other	Terminal Building	Work Complete	2021-05-15 12:24	Sonya Overton	CSG Vending machine on second floor needs to be moved to the side AND the CSG vending machine in the gate area next to Delta gate needs to be moved in with the other vending machines on the second floor until we can get them sold or reused. New vending will be installed by refreshing Georgia on Thursday 5/13/2021	\$ 0.00	0.0	2021-05-15 12:52	Daniel Thomas Sr.		
116 0	Other	Terminal Building	Work Complete	2021-05-15 12:24	Sonya Overton	Arconas crate in the terminal needs to be moved so that the ATM machines can be installed. Inside the crate are the seat covers for the terminal, gate and waiting areas. Seat covers need to be placed on the chairs in terminal waiting areas, gate area and upstairs to provide spacing at maximum seating. (5 seats/ 2 covers) (3 seats/1 cover) Please see Sonya for questions	\$ 0.00	0.0	2021-05-18 12:05	Daniel Thomas Sr.		
116 1	Plumbing	Flightways	In Progress	2021-05-15 12:25	Michele Renfroe	FBO restroom needs new toilet lids X 3 and the water flow plungers need to be replaced.	\$ 0.00	0.0				
116 2	HVAC	Flightways	Work Complete	2021-05-15 12:27	Michele Renfroe	FBO conference room unit is not blowing cold air and also need to check the wall unit in the server room to see why it is not working	\$ 0.00	0.0	2021-05-26 18:02	Daniel Thomas Sr.		
116 3	Other	Terminal Building	In Progress	2021-05-15 12:29	Monica Stone	A hole needs to be repaired behind the coffee machine. The hole was created when the water line drilled.	\$ 0.00	0.0				
116 4	Other	Terminal Building	Work Complete	2021-05-15 12:30	Monica Stone	Chair rails for wall the chairs are damaging the wall. Will we install chair rails?	\$ 0.00	0.0	2021-06-25 19:51	Daniel Thomas Sr.		

1165	Other	Terminal Building	In Progress	2021-05-15 13:43	Daniel Thomas Sr.	Ryan-Can you have one of your subcontractors (Maybe Alexander) look at the internet cables in the Maintenance Department break room that feeds the internet Airfield Operations Supervisor Office ( Get in contact with me (Daniel) before entering this office) and the Facilities Supervisors office. I had A-com come out and they said that there is no switch in the data rack for the fiber to plug into and an internet wire can plug into. The internet wires for the Operations Supervisor offices deadends and are not plugged in at the data rack in the Maintenance Department break room.	\$ 0.00	0.0			
1166	Other	Terminal Building	Work Complete	2021-05-15 13:50	Daniel Thomas Sr.	Monica (HR) Needs the Help of the Maintenance Department to move back into her office after the new carpet was installed.	\$ 0.00	0.0	2021-05-14 13:51	Daniel Thomas Sr.	
1167	Paint	Terminal Building	Work Complete	2021-05-15 13:56	Daniel Thomas Sr.	Paint Marys's new office space area.	\$ 0.00	0.0	2021-05-13 13:56	Daniel Thomas Sr.	
1168	Other	Terminal Building	Work Complete	2021-05-15 14:00	Daniel Thomas Sr.	Replace the old ceiling tiles in Marys's new office space area.	\$ 0.00	0.0	2021-05-15 14:00	Daniel Thomas Sr.	
1169	Other	Terminal Building	Work Complete	2021-05-15 14:06	Daniel Thomas Sr.	Help Shaundra move back into her office after the new carpet has been installed.	\$ 0.00	0.0	2021-05-14 14:06	Daniel Thomas Sr.	
1170	Paint	Terminal Building	In Progress	2021-05-15 14:12	Daniel Thomas Sr.	Remove the wallpaper, patch the holes in the walls, sand down the walls, and paint the walls in the hallway by Monica, Shaundra, and Mary's new office area.	\$ 0.00	0.0			
1171	Other	Terminal Building	In Progress	2021-05-15 14:14	Daniel Thomas Sr.	Replace the old ceiling tile in the hallway by Monica, Shaundra, and Mary's new office area.	\$ 0.00	0.0			
1172	Lighting	Terminal Building	In Progress	2021-05-15 14:20	Daniel Thomas Sr.	Replace the old ceiling lights (T-12 U-shape light bulbs) with new LED lights in the hallway by Monica, Shaundra, and Mary's new office area.	\$ 0.00	0.0			
1173	Paint	Terminal Building	In Progress	2021-05-15 14:25	Daniel Thomas Sr.	Remove the old wallpaper, patch the holes in the walls, sand the walls, and paint the walls over the two escalators.	\$ 0.00	0.0			
1174	Paint	Terminal Building	In Progress	2021-05-15 14:31	Daniel Thomas Sr.	Remove the old wallpaper, patch the holes in the walls, sand the walls, and paint the walls on the 2nd floor from the new admin entrance doors to the begging of the escalators. This also includes the 2nd-floor elevator.	\$ 0.00	0.0			
1175	Lighting	Terminal Building	In Progress	2021-05-15 14:35	Daniel Thomas Sr.	Remove the old wallpaper, patch the holes in the walls, sand the walls, and paint the walls on the old Delta 2nd floor holding area. Also, remove the Delta sign on the wall.	\$ 0.00	0.0			
1176	Landscaping	Airside	In Progress	2021-05-15 14:44	Daniel Thomas Sr.	Over by the Aflac Hagar by the construction stockpile. Water has nowhere to drain to, causing the area to wet and unable to cut the grass and trees.	\$ 0.00	0.0			
1177	Erosion	Airside	Work Complete	2021-05-15 14:49	Daniel Thomas Sr.	The drain in the Foxtrot-3 area has erosion around it. Backfill with dirt and rocks around the drain.	\$ 0.00	0.0	2021-05-19 11:55	Daniel Thomas Sr.	
1178	Erosion	Airside	Work Complete	2021-05-15 14:52	Daniel Thomas Sr.	The drain in the Delta-1 by the Delta-2 entrance area has erosion around it. Backfill with dirt and rocks around the drain.	\$ 0.00	0.0	2021-05-19 11:39	Daniel Thomas Sr.	
1179	Erosion	Airside	In Progress	2021-05-15 14:55	Daniel Thomas Sr.	The drain by the Charlie-7 sign area has erosion around it. Backfill with dirt and rocks around the drain.	\$ 0.00	0.0			
1180	Electrical	Terminal Building	Work Complete	2021-05-15 15:06	Daniel Thomas Sr.	FAA 5th Floor ATCT - The UPS 750 computer System for the airfield lighting control Battery is bad and needs to be replaced.	\$ 0.00	0.0	2021-05-15 15:06	Daniel Thomas Sr.	
1181	Electrical	Airside	Work Complete	2021-05-16 14:05	Daniel Thomas Sr.	Taxiway Charlie-East constant current regulator does not work in high step after a bad lighting storm on 02/15/2021.	\$ 0.00	0.0	2021-05-16 14:05	Daniel Thomas Sr.	
1182	Electrical	Airside	Work Complete	2021-05-16 14:10	Daniel Thomas Sr.	Taxiway Foxtrot constant current regulator does not work in high step after a bad lighting storm on 02/15/2021.	\$ 0.00	0.0	2021-05-16 14:10	Daniel Thomas Sr.	

1187	Lighting - Taxiway lighting	Airport	In Progress	2021-05-19 11:24	Marion Anderson	TWY light out at F/1 near RWY end Lights at 13	\$ 0.00	0.0			
1188	Lighting - Taxiway lighting	Airport	In Progress	2021-05-19 11:24	Marion Anderson	TWY light out on D near 6-24 hold bar	\$ 0.00	0.0			
1189	Lighting - Taxiway lighting	Airport	In Progress	2021-05-19 11:24	Marion Anderson	TWY out on D near intersection of C	\$ 0.00	0.0			
1190	Lighting - Taxiway lighting	Airport	In Progress	2021-05-19 11:24	Marion Anderson	TWY light out at D/4	\$ 0.00	0.0			
1192	Other	Terminal Building	Work Complete	2021-05-19 11:45	Amber Clark	Please move Mary's Office to Daniel old Office.	\$ 0.00	0.0	2021-05-26 17:59	Daniel Thomas Sr.	
1193	Other	Terminal Building	Work Complete	2021-05-19 11:46	Adrian Sellers	Put the styrofoam/ backing on all chairs up against a wall.	\$ 0.00	0.0	2021-06-25 19:33	Daniel Thomas Sr.	
1194	FOD	Hangar	Work Complete	2021-05-19 11:47	Michele Renfroe	8D - customer asked if the sweeper could be ran in front of hangar. He stated a lot if loose gravel is present.	\$ 0.00	0.0	2021-06-01 17:34	Daniel Thomas Sr.	
1195	Erosion	Airside	Work Complete	2021-05-19 11:53	Daniel Thomas Sr.	There are 2-holes that need to be filled in at Delta-3 RSA	\$ 0.00	0.0	2021-05-19 11:53	Daniel Thomas Sr.	
1201	Wind Cone	Hangar	In Progress	2021-05-25 15:39	Michele Renfroe	Helicopter hangar wind sock is falling off the pole and light on top of wind sock needs to be replaced it is burned out.	\$ 0.00	0.0			
1202	Holes	Hangar	In Progress	2021-05-25 15:40	Michele Renfroe	21A - Hole in Roof, Walls and door that needs to be filled. This hangar has just come available so it is empty to do the work. Photos attached.	\$ 0.00	0.0			
1203	Roof	Hangar	In Progress	2021-05-25 15:40	Michele Renfroe	18F Office - false roof is starting to fall down as well as the tiles and insulation. Hole open at back where air conditioner was installed at one time.	\$ 0.00	0.0			
1204	Door/Gate	Hangar	In Progress	2021-05-25 15:41	Michele Renfroe	14C - 1st door on left needs a stop added to make the hangar secure. Door roll freely when combo locked together due to not have a stop on the 1st or 2nd door.	\$ 0.00	0.0			
1205	Other	Terminal Building	Work Complete	2021-05-25 15:42	Adrian Sellers	Daniel can you check the A/C in the admin area to make sure it is still working because it is heating up.	\$ 0.00	0.0	2021-06-17 22:08	Daniel Thomas Sr.	
1206	Other	Parking Lot	Work Complete	2021-05-26 12:41	Daniel Thomas Sr.	The American Flag is faded and ripped	\$ 0.00	0.0	2021-05-26 12:42	Daniel Thomas Sr.	
1207	Other	Parking Lot	In Progress	2021-05-26 12:49	Daniel Thomas Sr.	The Georgia flag needs to be replaced because it is faded and ripped	\$ 0.00	0.0			
1208	Other	Airside	Work Complete	2021-05-26 18:53	Daniel Thomas Sr.	There is an old abandon boat between The Maintenance Hangar and Hangar 11. This boat has been sitting there for years. Remove the boat from the airport property by taking it to the landfill.	\$ 0.00	0.0	2021-05-26 18:54	Daniel Thomas Sr.	
1210	Lighting - Taxiway lighting	Airport	In Progress	2021-06-01 14:53	Andre Parker	4 TWY Lights OUT at D & RWY 31	\$ 0.00	0.0			
1219	HVAC	Flightways	Work Complete	2021-06-01 15:41	Michele Renfroe	Flightways server room a/c is leaking water down the wall out of the unit since the pump has been installed. Please call Holbrook back out to see if the line is stopped up or if it was connected wrong.	\$ 0.00	0.0	2021-06-01 15:55	Daniel Thomas Sr.	
1220	Lock	Terminal Building	In Progress	2021-06-01 15:42	Joseph Anthony Pugh	Lockbox in 2nd floor delta holding area to be relocated behind tsa checkpoint next to janitor closet.	\$ 0.00	0.0			
1221	Door/Gate	Terminal Building	Work Complete	2021-06-01 15:47	Joseph Anthony Pugh	The door (Ben's Office) between TSA offices and the janitorial storage room will not unlock. The key will turn however the door won't open. This is in the TSA/Maintenance Dept. Hallway area. If you have any questions. Contact Anthony-Supervisor over housekeeping.	\$ 0.00	0.0	2021-06-24 17:00	Daniel Thomas Sr.	
1222	Door/Gate	Hangar	In Progress	2021-06-01 15:47	Michele Renfroe	1C - hangar door stops need to be extended so doors don't overlap when opening.	\$ 0.00	0.0			

1223	Door/Gate	Hangar	In Progress	2021-06-01 15:48	Michele Renfroe	1C - Handles need to be replaced to open doors. One fell off and the other is loose.	\$ 0.00	0.0			
1224	Roof	Hangar	In Progress	2021-06-01 15:49	Michele Renfroe	17A - Holes in roof need to be repaired.	\$ 0.00	0.0			
1225	Other	Terminal Building	Work Complete	2021-06-01 15:50	Ashley Jankiewicz	Move directv cable outlet from one wall to the other wall where tv is. Moving the Receptacle cover and dropping the wire down on the other wall...	\$ 0.00	0.0	2021-06-25 19:26	Daniel Thomas Sr.	
1226	Wildlife	Hangar	In Progress	2021-06-01 15:51	Terry Echols	Pigeons are nesting in H-16	\$ 0.00	0.0			
1227	Other	Hangar	In Progress	2021-06-01 15:51	Michele Renfroe	7D - hangar tenant has moved out and hangar needs to be cleaned	\$ 0.00	0.0			
1229	Door/Gate	Terminal Building	Work Complete	2021-06-02 17:36	Adrian Sellers	Per Officer Anderson the front doors were working fine when they closed the terminal last night but when they went to open the doors were at working properly. The outside double doors for the 2nd vestibule. They are currently in the open position and are not closing.	\$ 0.00	0.0	2021-06-17 22:05	Daniel Thomas Sr.	
1230	HVAC	Terminal Building	Work Complete	2021-06-02 17:37	Adrian Sellers	In the terminal upstairs it is extremely hot, the air is not on at all.	\$ 0.00	0.0	2021-06-17 22:03	Daniel Thomas Sr.	
1231	Other	Terminal Building	Work Complete	2021-06-03 10:33	Adrian Sellers	This outlet needs to be repaired. It is in the stairwell next to the escalator by the double doors.	\$ 0.00	0.0	2021-06-25 19:04	Daniel Thomas Sr.	
1235	Paved Areas - FOD: gravel/debris/sand	Airport	In Progress	2021-06-04 18:16	Eric Rivers	Weeds starting to grow in cracks of TW Foxtrot	\$ 0.00	0.0			
1236	Lighting	Crash Station	In Progress	2021-06-06 21:11	Andre Parker	CRASH STATION - All Bay Lights Are OUT	\$ 0.00	0.0			
1239	Other	Terminal Building	In Progress	2021-06-14 10:13	Connie Perry	Get with Connie in Delta - Water leaking on belt at delta ticket counter	\$ 0.00	0.0			
1240	Other	Terminal Building	Work Complete	2021-06-14 10:14	Sonya Overton	Ace Flyer play set needs to be put together. Can be temporarily stored in the second floor overflow waiting area. Flyer found in Marketing dept.	\$ 0.00	0.0	2021-06-17 22:00	Daniel Thomas Sr.	
1241	Other	Terminal Building	Work Complete	2021-06-14 10:15	Sonya Overton	Expired Soda bottles need to be removed from the Admin break room. Will need the Big grey dumpster on wheels to remove. Please discard in dumpster.	\$ 0.00	0.0	2021-06-25 17:39	Daniel Thomas Sr.	
1242	Lighting	Hangar	In Progress	2021-06-15 18:02	Michele Renfroe	5C - Customer stated that outside lighting is not working. Looks like water has filled up the housing and blown the interior led light.	\$ 0.00	0.0			
1243	Landscaping	Hangar	Work Complete	2021-06-15 18:02	Michele Renfroe	H13 - Can you please cut the grass around and behind the hangar. Thank you	\$ 0.00	0.0	2021-06-17 21:55	Daniel Thomas Sr.	
1244	Lighting - Taxiway lighting	Airport	In Progress	2021-06-17 21:47	Marion Anderson	A TWY light is strobing at the curve area around C6 close to service road.	\$ 0.00	0.0			
1245	Other	Terminal Building	Work Complete	2021-06-17 21:50	Sonya Overton	Need a ladder and assistance to change the battery in my clock above the storage cabinets in the Marketing office.	\$ 0.00	0.0	2021-06-30 13:56	Daniel Thomas Sr.	
1246	Other	Hangar	In Progress	2021-06-17 21:50	Michele Renfroe	1B - Customer called and stated the bottom rail has came loose and is making it hard to close the doors.	\$ 0.00	0.0			
1249	Door/Gate	Terminal Building	Work Complete	2021-06-24 10:25	Daniel Thomas Sr.	The old jet bridge door on the 2-floor holding area has a large air gap at the bottom of the door. Close the air Gap at the bottom of the door and make sure the door is secured and will not open by accident	\$ 0.00	0.0	2021-06-25 18:11	Daniel Thomas Sr.	
1250	Door/Gate	Terminal Building	Work Complete	2021-06-25 17:26	Daniel Thomas Sr.	The floor door strip to the admin kitchen is coming up. This issue almost made Amber the director trip and fall. Please repair this issue ASAP. There is a cardboard box there, for now, to keep people from tripping.	\$ 0.00	0.0	2021-06-28 22:05	Daniel Thomas Sr.	
1251	Plumbing	Crash Station	Work Complete	2021-06-25 17:36	Daniel Thomas Sr.	The CRASH Station hot water is not working	\$ 0.00	0.0	2021-06-25 17:36	Daniel Thomas Sr.	

125 2	Electrical	Terminal Building	Work Complete	2021-06-25 18:22	Daniel Thomas Sr.	There is a power outlet in the admin hallway by the conference room that does not work.	\$ 0.00	0.0	2021-06-25 18:22	Daniel Thomas Sr.		
125 3	Door/Gate	Terminal Building	Work Complete	2021-06-25 18:53	Daniel Thomas Sr.	The front doors to the right of the main airport terminal and not sensing people unless you are standing close to the doors. The doors at times do not work at all.	\$ 0.00	0.0	2021-06-24 18:53	Daniel Thomas Sr.		
125 4	HVAC	Terminal Building	Work Complete	2021-06-25 18:58	Daniel Thomas Sr.	The conference room on the second floor in the admin office area is stuffy and warm. Replace the AC thermostat	\$ 0.00	0.0	2021-07-22 18:02	Daniel Thomas Sr.		
125 5	Facilities	Flightways	In Progress	2021-06-25 19:55	Darryl Graham	Fuel Farm back gate area floods during heavy rain, and needs a drainage system.	\$ 0.00	0.0				
125 7	Door/Gate	Terminal Building	In Progress	2021-06-28 21:18	Daniel Thomas Sr.	Follow up to work order #1221 that was completed on Thursday, 06/24/2021. Ryan with Sauer Inc called out a lock smith to open the door to hospitality supervisor office in the Maintenance/TSA area hallway. The door locking area was taped to keep the door from locking again. This door key core will be replaced when all the doors in CSG that are under the airport termail contract gets there new key record.	\$ 0.00	0.0				
125 8	Electrical	Terminal Building	Work Complete	2021-06-29 17:52	Pamela Knight	Pam office-Lights or bulbs changed to improve lighting in my office (Finance)	\$ 0.00	0.0	2021-07-22 18:14	Daniel Thomas Sr.		
125 9	Other	Terminal Building	Work Complete	2021-06-29 18:08	Daniel Thomas Sr.	clean out the trash and move the items out of the temporary room on the 2nd floor. The Temporary wall and door will be removed by Ryan.	\$ 0.00	0.0	2021-06-29 18:08	Daniel Thomas Sr.		
126 0	Other	Terminal Building	Work Complete	2021-06-30 13:20	Sonya Overton	Cushioned chairs in the upstairs waiting area need to be moved into the Layfield Conference Room for use. The Pink/purple chairs can be stacked and moved to the far end corner of the admin office hallway next to the old water fountain outside the breakroom. If you have any questions please see Sonya.	\$ 0.00	0.0	2021-07-01 14:03	Daniel Thomas Sr.		
126 3	Other	Terminal Building	Work Complete	2021-07-07 13:47	Daniel Thomas Sr.	Pan needs a newer office chair.	\$ 0.00	0.0	2021-07-07 13:47	Daniel Thomas Sr.		
126 4	Lighting	Terminal Building	In Progress	2021-07-07 14:28	Daniel Thomas Sr.	Admin copier room and closet ceiling lights are old and they are starting to not work. Upgrade by replacing the ceiling lights with LED lights (277 volts)(3-2' x 4' and 1-2' x 2').	\$ 0.00	0.0				
126 5	Lighting	Terminal Building	Work Complete	2021-07-07 14:33	Daniel Thomas Sr.	Admin Female Bathroom -ceiling lights are old and they are starting to not work. Upgrade by replacing the ceiling lights with LED lights (277 volts)(1-2' x 4' and 1-2' x 2').	\$ 0.00	0.0	2021-07-22 17:58	Daniel Thomas Sr.		
126 6	Lighting	Terminal Building	In Progress	2021-07-07 14:37	Daniel Thomas Sr.	Admin Male Bathroom -ceiling lights are old and they are starting to not work. Upgrade by replacing the ceiling lights with LED lights (277 volts)(1-2' x 4' and 1-2' x 2').	\$ 0.00	0.0				
126 7	Lighting	Terminal Building	Work Complete	2021-07-07 14:40	Daniel Thomas Sr.	Admin kitchen -ceiling lights are old and they are starting to not work. Upgrade by replacing the ceiling lights with LED lights (277 volts)(2-2' x 4').	\$ 0.00	0.0	2021-07-22 17:38	Daniel Thomas Sr.		
126 8	Other	Terminal Building	In Progress	2021-07-07 14:47	Daniel Thomas Sr.	Admin copier room and closet ceiling tiles are old and yellow. Replace the ceiling tiles with new bright white ceiling tiles	\$ 0.00	0.0				
126 9	Other	Terminal Building	In Progress	2021-07-07 14:49	Daniel Thomas Sr.	Admin Female restroom ceiling tiles are old and yellow. Replace the ceiling tiles with new bright white ceiling tiles (2' x 2' )	\$ 0.00	0.0				
127 0	Other	Terminal Building	In Progress	2021-07-07 14:50	Daniel Thomas Sr.	Admin Male restroom ceiling tiles are old and yellow. Replace the ceiling tiles with new bright white ceiling tiles (2' x 2' )	\$ 0.00	0.0				
127 1	Other	Terminal Building	In Progress	2021-07-07 14:53	Daniel Thomas Sr.	Admin Kitchen ceiling tiles are old and yellow. Replace the ceiling tiles with new bright white ceiling tiles (2' x 2' )	\$ 0.00	0.0				
127 2	Other	Terminal Building	Work Complete	2021-07-07 15:05	Daniel Thomas Sr.	Pam the Director of Finance Office furniture needs to be moved around. Get with Daniel on this. This move will start on Thursday 7/8/2021 at 8:30 am.	\$ 0.00	0.0	2021-07-08 11:42	Daniel Thomas Sr.		

127 3	Pavements	Airside	In Progress	2021-07-08 11:49	Daniel Thomas Sr.	There are weeds growing up through the cracks on the Commercial Ramp/Apron areas that need to be cut and sprayed with weed killer.	\$ 0.00	0.0			
127 4	Pavements	Airside	In Progress	2021-07-08 11:51	Daniel Thomas Sr.	There are weeds growing up through the cracks on the GA Ramp/Apron areas that need to be cut and sprayed with weed killer.	\$ 0.00	0.0			
127 5	Other	Terminal Building	Work Complete	2021-07-08 11:58	Daniel Thomas Sr.	There are 3-security cameras that need to be installed in the Admin Offices areas. The security cameras will view all the main entry/exit doorways points and the main hallways into the admin office areas.	\$ 0.00	0.0	2021-07-08 17:55	Daniel Thomas Sr.	
127 6	Door/Gate	Terminal Building	Work Complete	2021-07-09 16:58	Connie Perry	See Connie with Delta - Door going from delta ticket counter to tsa and delta opps is brokencan not use	\$ 0.00	0.0	2021-07-09 08:29	Daniel Thomas Sr.	
127 8	Other	Terminal Building	Work Complete	2021-07-13 15:45	Adrian Sellers	Inside the TSA and DELTA space there are bugs flying around, a lot of them. They look like gnats and mosquitoes but they advised when they open the roll up door to the BHS system they fly in so I'm not sure if there is a standing water issue outside that door or not.	\$ 0.00	0.0	2021-07-22 17:31	Daniel Thomas Sr.	
127 9	HVAC	Terminal Building	Work Complete	2021-07-20 08:26	Jerry Helms	Delta New ATO Space-Contact Jerry Helms-The air in the new Delta ATO space is not cooling. Sauer has been notified several times and the HVAC company has been onsite as well. Employees are expressing concerns due to working in the extreme heat on the ramp and then returning to a hot office.	\$ 0.00	0.0	2021-07-22 17:16	Daniel Thomas Sr.	
128 0	Lighting	Hangar	In Progress	2021-07-20 08:30	Michele Renfroe	11 bay 4 Office - lights only have 1 illumined for the whole office. Pictures attached.	\$ 0.00	0.0			
128 1	Lock	Hangar	In Progress	2021-07-20 08:30	Michele Renfroe	11 bay 4 - office lock is not hitting the striker plate so you can pull on the knob when locked and it will open. Picture attached.	\$ 0.00	0.0			
128 2	Lighting	Terminal Building	In Progress	2021-07-20 08:31	Shaundra Goodwin	Lights in Shaundra office When I turn on the lights all of them don't come on at once after a while the rest of them come on.	\$ 0.00	0.0			
128 3	HVAC	Terminal Building	Work Complete	2021-07-20 08:32	Shaundra Goodwin	No AC in Shaundra and Monica office. Very HOT.	\$ 0.00	0.0	2021-07-22 17:26	Daniel Thomas Sr.	
128 4	Facilities	Terminal Building	Work Complete	2021-07-20 08:32	connie perry	no AC in terminal.	\$ 0.00	0.0	2021-07-22 17:25	Daniel Thomas Sr.	
128 5	Door/Gate	Terminal Building	In Progress	2021-07-20 08:34	connie perry	Delta-See Connie-door by delta ticket counter going into tsa bag screening room and delta office is not opening when badging on door is sticking	\$ 0.00	0.0			
128 6	Other	Terminal Building	Work Complete	2021-07-20 08:35	David Noland	TSA-see David-Need 2 magnetic white boards leveled and hung. One in TSA space by main entrance and second one in TSA baggage room. Boards are 36x24	\$ 0.00	0.0	2021-07-23 18:55	Daniel Thomas Sr.	
128 7	Other	Terminal Building	Work Complete	2021-07-20 08:36	Adrian Sellers	The conference room needs to be vacuumed and wiped down for tomorrow's meeting at 5pm.	\$ 0.00	0.0	2021-07-20 09:14	Daniel Thomas Sr.	
128 8	Other	Terminal Building	Work Complete	2021-07-20 08:37	Adrian Sellers	The Tables needs to be removed from the conference room today or tomorrow . The thermostat needs to be placed in the conference room at 4pm tomorrow.	\$ 0.00	0.0	2021-07-20 09:17	Daniel Thomas Sr.	
128 9	Door/Gate	Terminal Building	In Progress	2021-07-20 08:37	David Noland	New baggage belt gate that exits the TSA baggage room going out to Baggage makeup area does not automatically raise when the belt system is turned on. In order to raise the gate it you have to turn it to manual mode and hit the raise gate button.	\$ 0.00	0.0			
129 3	HVAC	Terminal Building	Work Complete	2021-07-22 18:17	Ashley Jankiewicz	A/c not working in TSA break room	\$ 0.00	0.0	2021-07-23 18:53	Daniel Thomas Sr.	
129 6	HVAC	Terminal Building	Work Complete	2021-07-28 17:29	adrian sellers	Delta-Jerry called and advised that his ac hasn't worked since yesterday and it is now 84 degrees inside his ATO space. Can someone reset the unit.	\$ 0.00	0.0	2021-07-28 17:47	Daniel Thomas Sr.	
129 7	Other	Terminal Building	In Progress	2021-07-28 17:42	Ashley Jankiewicz	TSA Office Area-Hang a small tv monitor on the wall, no cable, used for video loop in the TSA break room.	\$ 0.00	0.0			

1298	Other	Terminal Building	In Progress	2021-07-28 17:43	Adrian Sellers	Admin Office-The men's restroom in the admin area toilet is leaking.	\$ 0.00	0.0				
1299	Other	Hangar	In Progress	2021-07-28 17:43	Michele Renfroe	16D - Customer states water is coming in from the outside bottom of the wall on the runway side. Right side looking in at the bottom of the hangar wall as well as a small roof leak on the right side above the wing area.	\$ 0.00	0.0				
1300	HVAC	Terminal Building	Work Complete	2021-07-28 17:44	adrian sellers	The air is out in the terminal nd down at the car rental.	\$ 0.00	0.0	2021-08-04 19:26	Daniel Thomas Sr.		
1301	Lighting - Obscured/dirty/operable	Airport	In Progress	2021-08-02 15:43	Andre Parker	Taxiway/Runway lights are obstructed by grass	\$ 0.00	0.0				
1302	Lighting - Runway lighting	Airport	In Progress	2021-08-02 15:43	Andre Parker	Dim Runway Lights at C2	\$ 0.00	0.0				
1304	Public Protection - Fencing/gates/signs	Airport	In Progress	2021-08-02 15:44	Eric Rivers	Fence was hit on Airport Thruway. Temporary fence installed. .	\$ 0.00	0.0				
1305	Signs - Obscured/operable	Airport	In Progress	2021-08-02 15:45	Andre Parker	SIGN #28 A/TERMINAL OUT	\$ 0.00	0.0				
1310	Wildlife	Hangar	In Progress	2021-08-04 19:42	Terry Echols	Work request # 502 was submitted and approved June 1, 2021. As of today it has been over a month and no action take, please advise me of the status of this work order, and why no action has been taken. I have cleaned pigeon crap off my plane and floor to many times, I thought the hanger rent increase was to bring our hangers up from the minimum standards, looks like this has not been the case.	\$ 0.00	0.0				
1312	Other	Terminal Building	In Progress	2021-08-12 18:30	Sonya Overton	ALL items on the second floor need to be removed for the AA inaugural celebration. The vending machines, airplane and Columbus Airport Model are the only things that are ok to remain. All seating, boxes, etc. need to be moved in preparation of the celebration. This needs to be completed by Friday, August 13, 2021.	\$ 0.00	0.0				
1313	Electrical	Hangar	In Progress	2021-08-12 18:31	Michele Renfroe	21H - Customer states that the timer light switch is connected to the power outlet so when you have anything plugged into the wall outlet when the timer for the light goes off the outlet goes off. Needs to be wired and separated from the timer light switch.	\$ 0.00	0.0				
1314	Wildlife	Hangar	In Progress	2021-08-12 18:31	Michele Renfroe	5H - 2 rats found in the hangar. please contact pest control company to check bait boxes. Photos are attached that the customer sent over.	\$ 0.00	0.0				
1315	HVAC	Terminal Building	Work Complete	2021-08-12 18:32	Shaundra Goodwin	AC not working in my office	\$ 0.00	0.0	2021-08-12 18:45	Daniel Thomas Sr.		
1316	Lighting - Taxiway lighting	Airport	In Progress	2021-08-13 17:20	Steve Cato	Red barricade TWY light out near delta 4	\$ 0.00	0.0				
1317	Signs	Terminal Building	In Progress	2021-08-19 18:05	Ashley Jankiewicz	TSA checked baggage room- hang bulletin board	\$ 0.00	0.0				
1318	Electrical	Terminal Building	In Progress	2021-08-19 18:06	Ashley Jankiewicz	Electrical outlet on wall at front of checkpoint by gate not working	\$ 0.00	0.0				
1319	Other	Terminal Building	In Progress	2021-08-19 18:06	Michele Coleman	Need to get benches moved to the area between the back of TSA checkpoint and American Airline boarding get area for passengers to get situated and put themselves together after screening	\$ 0.00	0.0				
1320	Other	Terminal Building	In Progress	2021-08-19 18:07	Adrian Sellers	Need power surge at my desk, because I only have 4 outlets	\$ 0.00	0.0				
1321	Other	Terminal Building	In Progress	2021-08-19 18:08	Sonya Overton	Pictures that were removed post construction need to be rehung. ie. Business view plaque, Columbus Airport pieces. Get with Marketing to coordinate.	\$ 0.00	0.0				
1322	Lighting - Taxiway lighting	Airport	In Progress	2021-08-23 17:37	Marion Anderson	D4 TWY sign #61 light is out.	\$ 0.00	0.0				

1323	Other	Terminal Building	In Progress	2021-08-23 17:42	Michele Coleman	TSA-Benches-Need to get benches moved to the area between the back of TSA checkpoint and American Airline boarding get area for passengers to get situated and put themselves together after screening	\$ 0.00	0.0				
1324	Other	Terminal Building	Work Complete	2021-08-23 17:43	Adrian Sellers	Trash that was put out by American Airlines right in front of their space. It needs to be taken to the trash can/ dumpster.	\$ 0.00	0.0	2021-08-23 17:47	Daniel Thomas Sr.		
1325	Other	Terminal Building	In Progress	2021-08-23 17:44	Adrian Sellers	Can someone with maintenance get with me to move seating around inside the terminal next week ASAP... they need to be moved to the east end of the terminal.	\$ 0.00	0.0				
1326	Other	Terminal Building	In Progress	2021-08-23 17:44	Sonya Overton	Need to get furniture from the old Cyber spot area out of storage closet on the second floor and arrange it on the second floor for passenger seating. Needs to be done as soon as possible as there is no seating upstairs.	\$ 0.00	0.0				
1327	Door/Gate	Terminal Building	In Progress	2021-08-26 18:05	David Noland	The Checkpoint side exit door needs a Door stopper installed in order to keep the door handle from hitting the wall when opened.	\$ 0.00	0.0				
1328	HVAC	Flightways	Work Complete	2021-08-26 18:20	Daniel Thomas Sr.	FBO-The lobby area AC system is not working making it hot in that area.	\$ 0.00	0.0	2021-08-26 18:21	Daniel Thomas Sr.		
1329	Lighting - Damaged/missing	Airport	In Progress	2021-08-30 14:45	Norman Russ	Taxiway Light across from C2 and towards C1 are out	\$ 0.00	0.0				
1332	Lighting	Delta GA Ramp Area	In Progress	2021-09-09 20:12	Leann Seffrin	An illuminated EXIT sign above each exit door from the hallway connecting Ramp area to Delta ticket counter.	\$ 0.00	0.0				
1333	Holes	Hangar	In Progress	2021-09-09 20:13	Michele Renfroe	2A - Customer came by and stated that the roof is still leaking on his airplane and other spots in the hangar. Pictures are attached.	\$ 0.00	0.0				
1334	HVAC	Terminal Building	Work Complete	2021-09-09 20:13	Shaundra Goodwin	AC is not working in Shaundra and Monica office.	\$ 0.00	0.0	2021-11-15 07:57	Daniel Thomas Sr.		
1335	Lighting	Terminal Building	Work Complete	2021-09-09 20:14	Sonya Overton	Lighting needs to be replaced in the copy room AND the vault room where supplies are in the Admin office. Lights are going out and bulbs need to be replaced.	\$ 0.00	0.0	2021-11-15 07:55	Daniel Thomas Sr.		
1336	Other	Terminal Building	In Progress	2021-09-09 20:15	Sonya Overton	Tables on the second floor gate are coming undone and need to be glued at the base. Two tables at the far end of the gate area next to the coke machine are the ones that are damaged. Please check the third one next to the toy plane to make sure that it is not damaged as well.	\$ 0.00	0.0				
1337	Paved Areas - FOD: gravel/debris/sand	Airport	In Progress	2021-09-14 23:06	Eric Rivers	Weeds starting to grow in cracks of Taxiway Foxtrot	\$ 0.00	0.0				
1338	Paved Areas - FOD: gravel/debris/sand	Airport	In Progress	2021-09-14 23:07	Eric Rivers	Weeds starting to grow in cracks of RW 13-31	\$ 0.00	0.0				
1339	Paved Areas - FOD: gravel/debris/sand	Airport	In Progress	2021-09-14 23:07	Eric Rivers	weeds starting to grow in cracks of Taxiway Delta	\$ 0.00	0.0				
1340	Paved Areas - FOD: gravel/debris/sand	Airport	In Progress	2021-09-14 23:07	Eric Rivers	Weeds starting tom grow in cracks of Taxiway Charlie	\$ 0.00	0.0				
1349	Facilities	Charlie / Foxtrot Safety Area	In Progress	2021-09-21 15:05	Austin Edwards	Water leaking from roof. Water leaking from rear corner floor.	\$ 0.00	0.0				
1350	Other	Terminal Building	Work Complete	2021-09-21 15:06	Adrian Sellers	Please move the tables out of the conference room and also the excess of chairs.	\$ 0.00	0.0	2021-09-21 15:32	Daniel Thomas Sr.		
1351	Other	Terminal Building	Work Complete	2021-09-21 15:07	Adrian Sellers	Please put some type of felt or silicone covers/ furniture pads on the blue ottoman like seats inside the terminal.	\$ 0.00	0.0	2021-11-15 07:52	Daniel Thomas Sr.		
1352	Other	Terminal Building	In Progress	2021-09-21 15:08	Adrian Sellers	PLease find something to cover or to mask the sound of the baggage belt buzzer/ light.	\$ 0.00	0.0				
1353	HVAC	Terminal Building	Work Complete	2021-09-28 18:50	Shaundra Goodwin	It's hot in Shaundra's office. Please check AC.	\$ 0.00	0.0	2021-11-15 07:50	Daniel Thomas Sr.		



135 4	Lighting	Parking Lot	Work Complete	2021-10-04 01:36	Daniel Thomas Sr.	Sidewalk lights in short-term and long-term parking areas need to be changed from white to pink for breast cancer awareness month (Oct).	\$ 0.00	0.0	2021-10-04 01:36	Daniel Thomas Sr.		
135 5	Lighting	Crash Station	Work Complete	2021-10-05 10:53	Daniel Thomas Sr.	CRASH Station-The male's main restroom lights are not working correctly.	\$ 0.00	0.0	2021-10-05 10:53	Daniel Thomas Sr.		
135 6	Electrical	Terminal Building	Work Complete	2021-10-08 10:33	Sonya Overton	Admin-Copier room-The paper shredder in the copy room is not working. Not sure if it is the outlet or if the shredder itself has gone bad. Please assess.	\$ 0.00	0.0	2021-11-15 07:47	Daniel Thomas Sr.		
135 7	Other	Terminal Building	In Progress	2021-10-08 10:33	Sonya Overton	Two televisions need to be installed downstairs in the gate area. Get with Sonya on the two televisions when ready to install.	\$ 0.00	0.0				
135 8	Electrical	Parking Lot	In Progress	2021-10-08 10:34	Richard Connell	There are multiple areas where wires are exposed and fittings are broken, this is a serious accident waiting to happen.	\$ 0.00	0.0				
135 9	Plumbing	Parking Lot	In Progress	2021-10-08 10:35	Richard Connell	Rental Car Wash Rack: Virtually every spigot has an issue with some not able to turn off without the spray nozzle.	\$ 0.00	0.0				
136 0	Pavements	Parking Lot	In Progress	2021-10-08 10:35	Richard Connell	Rental Car Wash Rack: There is an expanding hole in the drive lane of the service bay, it is only a matter of time before damage occurs despite our best efforts to drive around it.	\$ 0.00	0.0				
136 1	Lighting	Terminal Building	Work Complete	2021-10-08 16:43	Daniel Thomas Sr.	Admin Office-Females bathroom light over sink area is out	\$ 0.00	0.0	2021-10-08 16:47	Daniel Thomas Sr.		
136 2	Lighting - Damaged/missing	Airport	In Progress	2021-10-13 16:51	Eric Rivers	FAA (CENTER) end of runway light has been hit ON RUNWAY 06 and is no longer there. This is the same light that was replaced by the FAA Tech Ops in the past that the MD-80 took out. Parts to the light are in the CRASH station.	\$ 0.00	0.0				
136 3	Other	Terminal Building	Work Complete	2021-10-13 17:02	Joseph Anthony Pugh	FAA 5th floor-The railing in the tower is very loose and is a hazard for people going up or down.	\$ 0.00	0.0	2021-10-25 18:17	Daniel Thomas Sr.		
136 4	Door/Gate	Airside	Work Complete	2021-10-13 17:04	Connie Perry	Connie - Unifi- Jet bridge door will not working	\$ 0.00	0.0	2021-10-25 18:18	Daniel Thomas Sr.		
136 5	HVAC	Terminal Building	Work Complete	2021-10-13 17:05	Adrian Sellers	There is a leak or possible AC condensation inside the incoming baggage belt system area	\$ 0.00	0.0	2021-11-15 07:39	Daniel Thomas Sr.		
136 6	Electrical	Commercial Ramp	Work Complete	2021-10-13 17:07	Connie Perry	Connie-Unifi- out lets on building by jet bridge 1 do not work.	\$ 0.00	0.0	2021-11-15 07:44	Daniel Thomas Sr.		
136 7	Other	Commercial Ramp	Work Complete	2021-10-13 17:09	Connie Perry	Connie-Unifi-Jet bridge 1 not working	\$ 0.00	0.0	2021-10-13 17:17	Daniel Thomas Sr.		
136 8	Lighting - Taxiway lighting	Airport	In Progress	2021-10-25 17:43	Norman Russ	taxiway lights out near intersection of charlie and foxtrot	\$ 0.00	0.0				
136 9	Other	Ramp	Work Complete	2021-10-25 17:50	Connie Perry	Jet bridge was moved back to far by a morning agent, locking it So it will not move.	\$ 0.00	0.0	2021-10-25 17:59	Daniel Thomas Sr.		
137 0	Door/Gate	Terminal Building	Work Complete	2021-10-25 17:51	Connie Perry	Door at jet bridge 1 and 3 will not let us badge and open into gatw area.	\$ 0.00	0.0	2021-10-25 18:01	Daniel Thomas Sr.		
137 1	Lighting	Hangar	Work Complete	2021-10-25 17:53	Michele Renfroe	14B - Light needs to be changed out to LED. Lighting was changed to Led and pictures are attached.	\$ 0.00	0.0	2021-10-25 18:10	Daniel Thomas Sr.		
137 2	Lighting	Hangar	Work Complete	2021-10-25 17:54	Michele Renfroe	3F - Lighting needs to be changed to Led. Changed lighting to LED.	\$ 0.00	0.0	2021-10-25 18:10	Daniel Thomas Sr.		
137 3	Other	Terminal Building	Work Complete	2021-10-25 17:54	Adrian Sellers	Please move the coffee machine over some in front of the plug and water line, because people have been unplugging that machine and they have already come out once to fix it. not sure if it was because it was unplugged.	\$ 0.00	0.0	2021-10-25 18:02	Daniel Thomas Sr.		
137 4	Other	Hangar	Work Complete	2021-10-25 17:55	Michele Renfroe	3F - Hangar needs to be cleaned as soon as you can so I can move the new tenant in by the end of the month.	\$ 0.00	0.0	2021-10-25 18:13	Daniel Thomas Sr.		

1375	Other	Hangar	In Progress	2021-10-25 17:55	Michele Renfroe	5B - Please check to see if it needs to be cleaned so I can move new customer in by the end of the month, may just need to be swept out	\$ 0.00	0.0				
1376	Other	Ramp	In Progress	2021-10-25 17:56	Adrian Sellers	The rubber part of the rotating mechanism of the jet bridge is flipped up and looks like it just needs to be flipped back down.	\$ 0.00	0.0				
1377	Electrical	Terminal Building	In Progress	2021-10-25 17:57	Adrian Sellers	The outlets that were Installed specifically for the tugs are out again and per ryan, the breakers need to be flipped. Unifi has no other place to charge their tugs.	\$ 0.00	0.0				
1378	Electrical	Terminal Building	In Progress	2021-10-25 17:57	Adrian sellers	Flip breakers for the outlets for unifi to plug in their tugs	\$ 0.00	0.0				
1379	Plumbing	Hangar	In Progress	2021-10-25 17:58	Michele Renfroe	21 hangar - customer called and stated that the hose spigot at the end of the hangar was broken and spraying water.	\$ 0.00	0.0				
1380	Signs - Obscured/operable	Airport	In Progress	2021-10-26 15:53	Andre Parker	3/4 and 1/6 Thousand Foot sign OUT	\$ 0.00	0.0				
1381	Construction - Barricades/lights	Airport	In Progress	2021-11-05 18:31	Daniel Thomas Sr.	2-RWY Xs on RWY 13/31, TWY-F and TWY-D closed form RWY-06/24 to RWY-31 construction project. FAA NOTAMs CSG 10/029, CSG 10/30, AND CSG 10/031.	\$ 0.00	0.0				
1382	Other	Hangar	In Progress	2021-11-15 07:19	Michele Renfroe	18H - Customer stated that back wall of hangar is leaking water and needs to be sealed from the inside/outside wall.	\$ 0.00	0.0				
1383	Door/Gate	Terminal Building	Work Complete	2021-11-15 07:19	Connie Perry	Door from jet bridge 1 going into gate is sounding alarm after badging to open door	\$ 0.00	0.0	2021-11-15 07:28	Daniel Thomas Sr.		
1384	Other	Terminal Building	Work Complete	2021-11-15 07:20	Connie Perry	Claim area belt is closing then opening back up and alarming of a jam.	\$ 0.00	0.0	2021-11-15 07:31	Daniel Thomas Sr.		
1385	Other	Terminal Building	Work Complete	2021-11-15 07:21	Connie Perry	Agent pulled jet bridge back to far and locked jet bridge from moving.	\$ 0.00	0.0	2021-11-15 07:32	Daniel Thomas Sr.		
1386	Other	Terminal Building	Work Complete	2021-11-15 07:22	Connie Perry	Jet bridge 1 is locked and will not move.	\$ 0.00	0.0	2021-11-15 07:34	Daniel Thomas Sr.		
1387	Other	Terminal Building	Work Complete	2021-11-15 07:22	Connie Perry	Jet bridge got locked up and will not move	\$ 0.00	0.0	2021-11-15 07:35	Daniel Thomas Sr.		
1388	Holes	Terminal Building	In Progress	2021-11-15 07:23	Sonya Overton	Commission Wall and the Executive team wall needs to be repaired. Please patch all holes or any visible damage and repaint for new installation. PLease see Sonya for questions	\$ 0.00	0.0				
1389	Other	Terminal Building	Work Complete	2021-11-15 07:24	Connie Perry	Door into claim is half way down willnot go up or down	\$ 0.00	0.0	2021-11-15 07:37	Daniel Thomas Sr.		
1390	Lighting - Runway lighting	Airport	In Progress	2021-11-17 18:15	Marion Anderson	RWY light out near 4 marker on 24-6 across from C4.	\$ 0.00	0.0				
1391	Lighting - Runway lighting	Airport	In Progress	2021-11-17 18:15	Marion Anderson	RWY light out near windsock across from C5.	\$ 0.00	0.0				
1392	Lighting - Taxiway lighting	Airport	In Progress	2021-11-17 18:15	Marion Anderson	Down TWY light near F5 on TWY F.	\$ 0.00	0.0				
1393	Facilities	Ramp	In Progress	2021-11-17 18:24	Jerry Helms	Threshold in the American Airlines jet bridge is coming up and causing a safety hazard for passengers.	\$ 0.00	0.0				
1394	Other	Terminal Building	In Progress	2021-11-17 18:25	Sonya Overton	Ice chest needs to be replaced in Grab and Go Cart. Please see Sonya to get the new Chest to replace the cracked one. Return cracked chest to Marketing Dept.	\$ 0.00	0.0				
1395	Holes	Parking Lot	In Progress	2021-11-17 18:26	Hertz/Timothy Hardaway	HERTZ - There is a hole in the cleaning bay area on the floor as soon as you step in.	\$ 0.00	0.0				
1396	Lock	Parking Lot	In Progress	2021-11-17 18:27	Hertz/Timothy Hardaway	HERTZ - At the cleaning bay, there isn't a lock for the door. We need a lock on the door.	\$ 0.00	0.0				

139 7	Holes	Terminal Building	In Progress	2021-11-17 18:27	Hertz/Timothy Hardaway	HERTZ- We need holes drilled in the wall for two boards that we would like to hang up.	\$ 0.00	0.0				
139 8	Other	Terminal Building	In Progress	2021-11-17 18:28	Hertz/Timothy Hardaway	HERTZ - We have a rack that was originally used for our computer wires, but we replaced with a smaller rack. The larger rack is what we are requesting to be picked up.	\$ 0.00	0.0				
139 9	Lighting	Parking Lot	In Progress	2021-11-17 18:29	Hertz/Timothy Hardaway	HERTZ - The night lights do not work in the bay area for Hertz.	\$ 0.00	0.0				
140 0	HVAC	Terminal Building	In Progress	2021-11-17 18:30	Robert Blair	Avis-Despite setting the thermostat for heat and setting temperature the heat will not come on in the Avis or Budget rental car suites.	\$ 0.00	0.0				
140 1	Pavements	Parking Lot	In Progress	2021-11-17 18:31	Robert Blair	Avis-Car Wash Area-There is a pot hole 8 to 10" deep directly behind the Avis wash bay at the rental car service area where the concrete pad butts up the the pavement	\$ 0.00	0.0				
140 2	Plumbing	Parking Lot	In Progress	2021-11-17 18:32	Robert Blair	Avis-Budget-Car Wash Area-On both the Avis and Budget Rent a Car service areas the hose bibs are broken so the water will not shut off. The only regulation of the water is the shut off at the spray head of our hoses. If cold weather ruptures the hose water will run unchecked.	\$ 0.00	0.0				